

District I
1625 N. French Dr., Hobbs, NM 88240
District II
1301 W. Grand Avenue, Artesia, NM 88210
District III
1000 Rio Brazos Road, Aztec, NM 87410
District IV
1220 S. St. Francis Dr., Santa Fe, NM 87505

State of New Mexico
Energy Minerals and Natural Resources

Oil Conservation Division
1220 South St. Francis Dr.
Santa Fe, NM 87505

Form C-141
Revised October 10, 2003

Submit 2 Copies to appropriate
District Office in accordance
with Rule 116 on back
side of form

Release Notification and Corrective Action

ADI # 30-039-09812

OPERATOR

☒ Initial Report ☒ Final Report

Name of Company: Energen Resources

Contact: Kellie Campbell

Address: 2010 Afton Place

Telephone No.: 505-324-4152

Facility Name: Elk Horn 101S

Facility Type: On Shore Gas well

Surface Owner: FEDERAL

Mineral Owner: FEDERAL

Lease No. 3120672A

LOCATION OF RELEASE

Unit Letter A	Section 32	Township 32N	Range 5W	Feet from the 620'	North/South Line NORTH	Feet from the 770'	East/West Line EAST	County RIO ARRIBA
------------------	---------------	-----------------	-------------	-----------------------	---------------------------	-----------------------	------------------------	----------------------

Latitude 36.94233 Longitude -107.37939

NATURE OF RELEASE

Type of Release: FIRE	Volume of Release NA	Volume Recovered NA
Source of Release NA	Date and Hour of Occurrence 10/28/2009	Date and Hour of Discovery: 10/28/2009
Was Immediate Notice Given? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Not Required	If YES, To Whom? BRANDON POWELL	
By Whom? KELLIE CAMPBELL	Date and Hour 10/28/2009 1600	
Was a Watercourse Reached? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	If YES, Volume Impacting the Watercourse. NA	

RCVD NOV 5 '09

OIL CONS. DIV.

DIST. 2

If a Watercourse was Impacted, Describe Fully.*

NA

Describe Cause of Problem and Remedial Action Taken.*

Catalytic heater was started on 10/27/2009. On 10/28/2009 a fire was discovered in the pump house building. Gas supply was shutoff and fire went out.

Describe Area Affected and Cleanup Action Taken.*

Employee made notifications. The pump is being replaced.

I hereby certify that the information given above is true and complete to the best of my knowledge and understand that pursuant to NMOCD rules and regulations all operators are required to report and/or file certain release notifications and perform corrective actions for releases which may endanger public health or the environment. The acceptance of a C-141 report by the NMOCD marked as "Final Report" does not relieve the operator of liability should their operations have failed to adequately investigate and remediate contamination that pose a threat to ground water, surface water, human health or the environment. In addition, NMOCD acceptance of a C-141 report does not relieve the operator of responsibility for compliance with any other federal, state, or local laws and/or regulations.

Signature:

Printed Name: KELLIE CAMPBELL

Title: ENVIRONMENTAL SAFETY COORDINATOR

E-mail Address: kellie.campbell@energen.com

Date: 10/28/2009 Phone: 505-324-4152

OIL CONSERVATION DIVISION

Approved by District Supervisor:

Bob Pull For: CP

Approval Date: 11/9/09

Expiration Date:

Conditions of Approval:

Attached ☐

* Attach Additional Sheets If Necessary

Incident # NMD 8931628759