

**MEASUREMENT
AUDITORS
COMPANY**

DEKALB ENERGY COMPANY
P.O. BOX 400
AZTEC, N.M. 87410

GAS CHROMATOGRAPH ANALYSIS

MAC CUST/STAT : 6820010060
CUST STAT NO :
CUST STAT NAME: MKL #2R
FIELD :
COUNTY : SAN JUAN
STATE : NM

SAMPLING DATE : 04/12/91
SAMPLED BY : FRED CRUM
PRESSURE : 250
FLOW TEMP : N/A
ACCOUNT CODE : 0000-3200-01145NNNO1014

PRESSURE BASE : 14.696 DRY
SOURCE : MTR.RUN
ANALYZED BY : B.L.
DATE OF ANALYSIS : 04/13/91
RUN NUMBER : 2612

COMPONENT	CURRENT MOLE %	GPM @ 14.696 D	PREVIOUS
OXYGEN	0.00	0.000	0.00
CO2	0.00	0.000	0.00
NITROGEN	2.27	0.000	0.00
METHANE	89.17	0.000	0.00
ETHANE	4.68	1.249	0.00
PROPANE	2.22	0.610	0.00
I-BUTANE	0.44	0.144	0.00
N-BUTANE	0.53	0.167	0.00
I-PENTANE	0.18	0.066	0.00
N-PENTANE	0.13	0.047	0.00
HEXANES	0.38	0.156	0.00
HEPTANES +	0.00	0.000	0.00
HELIUM	N/A		
HYDROGEN	N/A		
H2S	N/A		
TOTAL	0.00	2.438	

SPECIFIC GRAVITY			
GROSS BTU/CU. FT. @15.025 DRY	0.6370		0.0000
GROSS BTU/CU. FT. @15.025 SAT	1126.1		0.0
GROSS BTU/CU. FT. @14.730 DRY	1106.9		0.0
GROSS BTU/CU. FT. @14.730 SAT	1103.9		0.0
GROSS BTU/CU. FT. @14.696 DRY	1084.2		0.0
GROSS BTU/CU. FT. @14.696 SAT	1101.4		0.0
	1082.2		0.0

REMARKS :

PERMANENT PRODUCTION FILE