



50 Road 4990
P.O. Box 159
Bloomfield, New Mexico 87413
505
632-8013

April 9, 1997

Roger Anderson
Environmental Bureau Chief
New Mexico OCD
2040 South Pacheco
Santa Fe, New Mexico 87505

Denny Foust
Deputy Oil & Gas Inspector
New Mexico OCD
1000 Rio Brazos Road
Aztec, New Mexico 87410

RECEIVED
APR 14 1997
OIL CON. DIV.
DIST. 3

Re: **Monthly Water Effluent Report**

Dear Sirs:

Attached is the March, 1997 waste water effluent (GW-001) and injection well (GW-130) report for Giant Refining Company's Bloomfield Refinery.

A Mechanical Integrity Test was performed on SWD #1 on March 27, 1997, with Ernest Cardona of the OCD Aztec office witnessing the test.

If you require additional information, please do not hesitate to contact me at (505) 632 8013.

Sincerely:

A handwritten signature in cursive script that reads "Lynn Shelton".

Lynn Shelton
Environmental Manager
Giant Refining Company - Bloomfield

TLS/tls

Enclosure

cc: John Stokes
Ron Weaver
Chad King

GIANT REFINING COMPANY - BLOOMFIELD

P.O. BOX 159
BLOOMFIELD, NEW MEXICO 87413

MONTHLY INJECTION WELL REPORT
DISCHARGE PLAN GW-130 EXP. DATE 11/4/98
NE1/4 SE1/4 SECTION 27, T29N, R11W
NMPM, SAN JUAN COUNTY, NEW MEXICO

PERIOD 1997	AMOUNT OF WATER FROM RIVER (GALLONS)	AMOUNT TO SOLAR EVAP PONDS (GALLONS)	TOTALIZER AMOUNT INJECTED (GALLONS)	CALCULATED AMOUNT INJECTED (GALLONS)	DOWN- TIME (HRS)	INJECTION PRESSURE			ANNULAR PRESSURE			ON-LINE FLOW RATES		
						MAX (PSIA)	MIN (PSIA)	AVG (PSIA)	MAX (PSIA)	MIN (PSIA)	AVG (PSIA)	MAX (GPM)	MIN (GPM)	AVG (GPM)
JAN	9,024,000	3,632,100	2,137,100	2,299,809	480	972.7	795.8	949.9	187.5	134.9	162.4	152	87.5	145.19
FEB	9,798,000	3,980,900	4,770,100	6,436,195	0	996.4	795.8	980.9	201.6	104.3	153.1	149.6	127.1	144.18
MAR	10,883,000	4,513,900	4,634,300	5,556,432	100	1035	763.0	988.73	500	98.1	167.0	150.5	55.1	143.8
APR														
MAY														
JUN														
JUL														
AUG														
SEP														
OCT														
NOV														
DEC														

CERTIFICATION: *Raymond Shelton*

DATE: 4/10/97