

WASTE WATER INJECTION LOG

Dates: From 11/14/95 to 11-19-95

		Obtained from Rustrak Recorder			P-670	OILERS	CRANKCASE	CHART	TIME	OPERATOR
		P-670	P-670	ANNULAR	DISCHARGED	LEVEL	LEVEL	CHANGED		INITIALS
		FLOW RATE	PRESSURE	PRESSURE	TOTALIZER					
					READING					
Monday	1	123.0	456.5	24.0	189216	✓	—	—	12:00	AL
	2									
Tuesday	1									
	2	153.4	837.7	1.3	189934	OK	OK	Yes	11:45	JA
Wednesday	1	92.7	706.3	2.2	190766	—	—	—	11:30	AL
	2	89.8	704.4	3.3	191367	—	—	Yes	12:10	JA
Thursday	1	86.7	701.8	4.6	191840	✓	✓		12:15	AL
	2	86.0	710.1	5.1	192318	—	—	Yes	23:00	JA
Friday	1	82.2	716.4	5.1	192893	✓	✓	✓	12:00	AL
	2	90.2	729.6	5.6	193420	—	—	Yes	23:40	JA
Saturday	1	99.8	759.3	6.0	193970	—	—	—	12:00	AL
	2	85.5	725.0	6.7	194390	—	—	—	9:30	AL
Sunday	1	85.5	727.6	7.2	195042	—	—	NO	12:15	AL
	2	85.6	729.9	7.8	195510	—	—	YES	11:00	AL

NOTES: (valve lineup at ponds, unusual conditions, etc.) Maintain 80-90 GPM for
time being 11-15
11:00 AM