

WASTE WATER INJECTION LOG

Dates: From 11-20-95 to 11-26-95

		Obtained from Rustrak Recorder			P-670 DISCHARGED TOTALIZER READING	OILERS LEVEL	CRANKCASE LEVEL	CHART CHANGED	TIME	OPERATOR INITIALS
		P-670 FLOW RATE	P-670 PRESSURE	ANNULAR PRESSURE						
Monday	1	87.3	734.3	8.5	196117	—	✓	Yes	12:40	RL
	2									
Tuesday	1	99.6	746.3	3.0	196267	Added	Added	✓	16:35	JA
	2			(Pump off)						
Wednesday	1	99.7	742.4	3.7	196565	✓	✓	✓	12:25	Pick
	2	99.5	755.7	5.8	197134	✓	✓	✓	23:30	ML
Thursday	1	99.2	760.2	5.5	197771	✓	✓		12:00	Pick
	2	98.9	766.5	6.3	198382	✓	✓	✓	12:00 AM	ML
Friday	1	99.0	772.4	6.5	198991	—	—		12:00	YH
	2	94.9	764.0	7.8	199593	✓	✓	✓	midnite	ML
Saturday	1	94.9	768.1	8.2	200142	—	—		11:25	YH
	2	95.3	771.7	10.4	200735	OK	OK	Yes	23:30	JA
Sunday	1	97.1	778.1	10.9	201361	—	—		12:00	AL
	2	97.2	778.5	12.1	201932	OK	OK	Yes	23:45	JA

NOTES: (valve lineup at ponds, unusual conditions, etc.) Shut inj. well down @ 20:30 (pump not staying on) couldn't reset pump out @ ponds! Wiring problems at P-671 Pick on @ 10:30 AM 11-2