

WASTE WATER INJECTION LOG

Dates: From 12-11-95 to 12-17-95

Obtained from Rustrak Recorder				gal x 100 P-670	OILERS LEVEL	CRANKCASE LEVEL	CHART CHANGED	TIME	OPERATOR INITIALS	
P-670 FLOW RATE	P-670 PRESSURE	ANNULAR PRESSURE	DISCHARGED TOTALIZER READING							
Monday	1	99.4	747.8	20.4	206969	✓	✓	yes	14:50	ML
	2	100.1	762.1	6.0	207383	✓	✓	yes	23:15	Rick
Tuesday	1	99.7	769.4	6.1	208023	✓	✓	✓	11:45	AL
	2	100.2	774.3	6.1	208700	✓	✓	yes	1:00	AL
Wednesday	1	100.0	779.1	8.5	209438	✓	✓	✓	15:00	AL
	2	99.7	781.9	9.4	209953	✓	✓	NO CHARTS	12:00 A	AL
Thursday	1	99.9	784.3	7.3	210389	✓	✓		10:00	AL
	2	100.9	792.7	13.1	211136	✓	✓	yes	12:30	AL
Friday	1	98.4	786.0	9.0	211722	✓	✓	✓	11:50	Rick
	2	99.6	790.1	11.0	212362	✓	✓	yes	12:20	AL
Saturday	1	100.3	792.1	11.6	212914	✓	✓		11:15	AL
	2	101.2	797.1	12.6	213581	✓	✓	yes	24:00	AL
Sunday	1	100.6	795.0	13.2	214146	✓	✓		11:00	R.S.
	2	101.6	799.3	15.5	214804	✓	✓	yes	24:00	AL

784500
gal/week

NOTES: (valve lineup at ponds, unusual conditions, etc.) Pump running again @ 12/11 14:45, Larry worked on switches,