

WASTE WATER INJECTION LOG

Dates: From 12-18-95 to 12-24-95

		Obtained from Rustrak Recorder			P-670 DISCHARGED TOTALIZER READING	OILERS LEVEL	CRANKCASE LEVEL	CHART CHANGED	TIME	OPERATOR INITIALS
		P-670 FLOW RATE	P-670 PRESSURE	ANNULAR PRESSURE						
Monday	1	99.6	795.5	16.2	215382	✓	✓		21:00	RD
	2	99.8	797.7	17.0	216072	✓	✓	Yes	24:00	AF
Tuesday	1	105.8	816.7	19.2	216763	✓	✓		12:30	AL
	2	104.4	813.3	17.3	217335	✓	✓	Yes	23:19	AF
Wednesday	1	106.9	824.9	18.1	217977	✓	✓		11:30	AL
	2	105.1	827.4	17.5	218647	✓	✓	Yes	23:50	AF
Thursday	1	105.0	834.0	19.0	219352	✓	✓		13:00	AL
	2	105.4	837.7	17.3	219737	✓	✓	Yes	23:00	AF
Friday	1	105.4	835.0	15.3	220451	✓	✓		12:15	AL
	2	105.7	836.2	16.6	221041	✓	✓	Yes	23:19	AF
Saturday	1	105.4	832.8	16.3	221818	✓	✓		13:30	AF
	2	106.1	830.1	15.3	222376	✓	✓	YES	24:00	AL
Sunday	1	106.1	827.8	13.6	223048	✓	✓	NO	12:00	AF
	2									

NOTES: (valve lineup at ponds, unusual conditions, etc.) Down 12-21-95 13:00. bad
 tank switches - back on @ 16:00. Changed out Chart
 At 17:00 Pump Shut OFF By ITSELF 17:30
 1/5 PM