

WASTE WATER INJECTION LOG

Dates: From 12/25/95 to 12/31/95

		Obtained from Rustrak Recorder			P-670 DISCHARGED TOTALIZER READING	OILERS LEVEL	CRANKCASE LEVEL	CHART CHANGED	TIME	OPERATOR INITIALS
		P-670 FLOW RATE	P-670 PRESSURE	ANNULAR PRESSURE						
Monday	1	104.0	815.9	23.6	223417	✓	✓	yes	19:20	AL
	2	105.1	822.4	22.4	224502	✓	✓		11:45	Rick
Tuesday	1	105.1	824.4	27.5	224772	✓	✓	—	17:10	TH
	2	105.3	825.8	25.8	225152	✓	✓	yes	23:45	ML
Wednesday	1	105.5	828.5	25.9	225759	✓	✓	—	11:10	TH
	2	105.3	830.7	30.4	226425	✓	✓	yes	23:30	ML
Thursday	1	120.6	886.0	28.5	227048	✓	✓	—	11:00	Rick
	2	122.5	899.4	18.7	22852	✓	✓	yes	23:45	ML
Friday	1	121.1	892.6	18.8	228583	✓	✓	✓	11:05	Rick
	2	128.8	919.0	21.2	229349	✓	✓	yes	23:30	ML
Saturday	1					All shut down		✗		
	2					—	—	yes	23:15	TH
Sunday	1									
	2									

NOTES: (valve lineup at ponds, unusual conditions, etc.)

STARTED pump A 19:20 12/25/95
 New 50 micron filter @ 11:00 - Increased down hole flow to 120. Up to 130 (checked well @ 03:30 found it had been going off + on since about 1:00) ~~Shut~~ Shut pump down @ 05:00 wouldn't stay running, Valve wasn't changing back to power Pressure from pond pump (130) Gauge out there showing pressure (filter might be plugged) 300 + ?