

WASTE WATER INJECTION LOG

Dates: From 2/5/96 to 2/11/96

		Obtained from Rustrak Recorder			P-670 DISCHARGED TOTALIZER READING	OILERS LEVEL	CRANKCASE LEVEL	CHART CHANGED	TIME	OPERATOR INITIALS
		P-670 FLOW RATE	P-670 PRESSURE	ANNULAR PRESSURE						
Monday	1	121.0	940.5	-0.2	264029	✓	✓	✓	14:00	AL
	2	122.2	948.0	-0.2	264618	✓	✓	Yes	23:30	34
Tuesday	1	119.5	932.2	-0.2	265398	✓	✓		12:10	ML
	2	111.4	905.0	-0.2	266053	✓	✓	Yes	23:00	Pick
Wednesday	1	132.5	985.2	✓	266810	✓	✓	✓	11:50	MC
	2	110.5	895.9	-0.2	267508	✓	✓	Yes	23:00	Pick
Thursday	1	129.6	968.2	-0.2	268310	✓	✓		12:30	ML
	2	123.3	939	-0.2	268964	✓	✓	Yes	23:00	Pick
Friday	1	116.9	910.5	✓	269981	✓	✓	✓	16:00	34
	2	123.5	933.2	-0.2	270394	✓	✓	Yes	23:00	Pick
Saturday	1	117.9	910.8	-0.3	271167	✓	✓	✓	11:50	34
	2	121.0	923.5	-0.2	271937	✓	✓	Yes	12:30	AL
Sunday	1	123.6	934.2	-0.2	272678	✓	✓	✓	12:00	34
	2	121.1	925.8	-0.2	273421	✓	✓	Yes	23:55	ML

NOTES: (valve lineup at ponds, unusual conditions, etc.) Maintain Discharge Pressure to Just Under 950# - adjusting Flow Rate when needed.
Adjusted BACK to 938.1 + 120.9
248) Adjusted BACK to 121 - 933.5
to 112.3 - 899.3