

WASTE WATER INJECTION LOG

Dates: From 5-13 to 5-19-96

		Obtained from Rustrak Recorder			P-670	OILERS	CRANKCASE	CHART	TIME	OPERAT
		P-670 FLOW RATE	P-670 PRESSURE	ANNULAR PRESSURE	DISCHARGED TOTALIZER READING	LEVEL	LEVEL	CHANGED		INITIALS
Monday	1	115.6	990.6	199.2	109549	Added ✓	OVER Flowing	✓	11:45	AL
	2	90.3	886.4	190.3	110491	—	—	YES	1:00	AL
Tuesday	1	88.1	879.1	166.1	111275	—	Pressured up	—	12:17	3H
	2	95.5	910.8	165.0	111948	✓	—	yes	00:00	AL
Wednesday	1	90.0	902.6	134.9	112839	—	—	—	14:00	3H
	2	86.3	899.6	220.6	113310	✓	✓	yes	23:30	AL
Thursday	1									
	2									
Friday	1									
	2									
Saturday	1	103.7	943.0	145.0	013908	—	—	YES	10:15A	AL
	2	107.3	961.5	172.6	014129	—	—	yes	00:10A	3H
Sunday	1	92.3	894.3	183.6	014949	—	—		11:30	AL
	2	102.3	935.0	171.4	015715	—	—	YES	00:00	3H

NOTES: (valve lineup at ponds, unusual conditions, etc.)

Pond pump kept losing suction since about 4:00 am ? Could not get it to pick up shut down pump.
Pump back on at 1400 5-17-96 [initials]

NEW chart 5/18/96 10:15 got pump started up