

WASTE WATER INJECTION LOG

Dates: From 6-3-96 to 6-10-96

		Obtained from Rustrak Recorder			P-670	OILERS	CRANKCASE	CHART	TIME	OPERATOR INITIALS
		P-670 FLOW RATE	P-670 PRESSURE	ANNULAR PRESSURE	DISCHARGED TOTALIZER READING	LEVEL	LEVEL	CHANGED		
Monday	1	955.8	113.4	116.7	948058	✓	✓		12:00	RLC
	2	108.5	941.3	115.6	849108	✓	✓	yes	23:00	Rich
Tuesday	1	108.5	940.3	102.3	850558	✓	✓	✓	12:15	RLC
	2									
Wednesday	1									
	2									
Thursday	1									
	2									
Friday	1	91.8	876.4	127.1	861015	✓	✓	yes	15:30	Rich
	2	117.2	951.3	105.4	861903	✓	✓	yes	12:45	AL
Saturday	1	127.8	994.3	173.2	953147	✓	✓	✓	12:30	RLC
	2	110.1	922.6	124.3	953804	✓	✓	yes	2:30	RLC
Sunday	1	116.8	936.5	65.8	855338	✓	✓	✓	12:25	RLC
	2	120.1	956.9	121.9	856288	✓	✓	yes	24:00	RLC

NOTES: (valve lineup at ponds, unusual conditions, etc.)

Shut Starter motor at 7:15 transfer Pump won't
come on
Back on 6-7-96 15:00