


TA 60/0



LEAK in HOSE

FIXED AND RESEALED
PC 4404

800 Connection

HYDROSTATIC Chart Test
Graphic Controls
TESTED BY FMC
CHART NO. MC MP-1000-1HR
METER TESTED FOR 35 MIN. 560 PSI
PC 4404

TAKEN OFF
6:35

CHART PUT ON
6:00 PM

LOCATION

REMARKS

LIKINS GAS Com A #2

30-048-0846B
34-30407W

15

20

25

30