

Continental Oil Company
Vaughn B-12 No. 2 Power Distribution

A plat is attached showing the proposed well location, existing road, new road, existing power line, proposed power line, also drawings of the pole design.

It is proposed to tie-in to an existing New Mexico Electric primary line and construct 2 spans (660') of primary line. The poles will be approximately 330' apart, 1-line pole and 1 pole with transformer bank. A 20' right-of-way will be required to install this line. The proposed line is staked.