



NOTE:
 1. TO NOT INSTALL
 GROUND WIRE FIRST
 NEUTRAL CONDUCTOR
 2. THIS CONSTRUCTION
 STANDARD TO BE
 USED ON ALL LINES
 BUILT ON NATIONAL
 RESOURCE LANDS

MATERIALS

ITEM	DESCRIPTION	REQ'D	ITEM	DESCRIPTION	REQ'D
1	POLE 40'	1	17	NEUTRAL CONDUCTOR	1
2	BRASS ARM 3/4" x 1/2" x 8"	1	18	ARMOR ROD	1
3	PLATE, WOOD	2	19	POLE GROUND WIRE #6 U.L.	5
4	STUD PAXX	2			
5	RIDGE PIN 1 1/2"	1			
6	SPool INSULATOR	1			
7	STEEL PIN 7/8 x 5"	2			
8	LVL SCREW 1/2" x 4"	2			
9	LARGE SCREW 3/8" x 4 1/2"	2			
10	MACHINE BOLT 3/8" x 10"	2			
11	MACHINE BOLT 5/8" x 4"	5			
12	WASHER 2 1/2" dia	3			
13	WIRE CONDUCTOR	3			
14	ARMOR W/D	3			
15	THE WIRE #6 AL	3			
	PIN INSULATOR 9 KV	3			

DATE: 7-15-77	TITLE: PRIMARY 11 KLV LINE POLE
DRAWN BY: J. WENTZ	12,000 VOLT ACGR.
DESIGN BY:	CONOCO
CHECKED BY: SW	PRODUCTION DEPT.
APPROVED BY: SW	JOB: 13 EL. STEEL
SCALE: 1/4" = 1'	DRAWING NO.: E9-26
	HOBBS DIVISION