

Romero, Lawrence S., EMNRD

From: Martin, Ed, EMNRD
Sent: Monday, September 24, 2007 8:18 AM
To: Romero, Lawrence S., EMNRD
Subject: FW: request to alter P&A Marker

Lawrence, would you please insert this into the well file? Thanks.

Ed Martin

District IV Supervisor
New Mexico Oil Conservation Division
1220 S. St. Francis
Santa Fe, NM 87505
505-476-3470 phone
505-476-3462 fax
505-690-2365 cell

From: Martin, Ed, EMNRD
Sent: Friday, September 21, 2007 9:07 AM
To: 'John Weisdorfer'
Cc: Holcomb, Danny
Subject: RE: request to alter P&A Marker

This request is approved. Please make your best effort to avoid damage to the installed plate and, if it becomes inadvertently covered with soil, please clear away the obstruction so that the plate is again visible.

Ed Martin

District IV Supervisor
New Mexico Oil Conservation Division
1220 S. St. Francis
Santa Fe, NM 87505
505-476-3470 phone
505-476-3462 fax
505-690-2365 cell

From: John Weisdorfer [mailto:jcweisd@springercoop.com]
Sent: Friday, September 21, 2007 10:03 AM
To: Martin, Ed, EMNRD
Subject: request to alter P&A Marker

Mr. Martin,

Springer Electric Cooperative Inc. is planning on building a 230kv switching station on section 5, T18N, R30E of Harding County. We intend on installing a ground grid below the surface for this site. The construction will consist of moving soil, drilling of holes and excavation of the property. Springer Electric Cooperative request at this time that the P&A marker located within the property boundary be cut off at ground level and a 1" steel plate be welded to the top of it. This will minimize the risk of damage to the well or construction equipment. Springer Electric Cooperative will avoid the well as to not construct or build directly over the well. The API number

9/24/2007

is 30-021-20035, unit letter is L-5-18N-30E, lease name and well number is Mitchell # 17 and the operator is Hess Corp.

John C. Weisdorfer, Operations Manager

Springer Electric Cooperative Inc.

Ph. (505) 483-2421 or 800-288-1353

Fax (505) 483-2692

Email jcweisd@springercoop.com

This inbound email has been scanned by the MessageLabs Email Security System.
