

GW – 190

**GENERAL
CORRESPONDENCE**

YEAR(S): 2009 - 2013

Lowe, Leonard, EMNRD

From: Joshua.Morrisette@bjservices.com
Sent: Wednesday, February 02, 2011 7:53 AM
To: Lowe, Leonard, EMNRD
Subject: Artesia Minor Modification Request (GW-190)
Attachments: Proposed Layout (1-2-11).pdf; Artesia Lube Island Layout.pdf
Importance: High

A 1

A 2

Leonard - Our Artesia Pressure Pumping yard is requesting a minor modification. The facility is proposing to move the Lube Island from its current position on the south side of the yard to approximately 60 ft north of the wash bay. All the existing tanks and containments will be moved and relocated. No new products will be stored and all containments hold 130% of tank capacity. Attached is a drawing that contains specific information on the Lube Island layout, dimensions, and tank contents. Also attached is a Facility diagram indicating the current location and the proposed location.

Following NM OCD Approval the facility's Discharge and SPCC plans will be updated accordingly. Please let me know if there is any other information or clarification needed. Thanks.

Josh

Josh Morrisette | Sr. HSE Specialist
Baker Hughes | HS&E Technical Support Team
Office: 713.879.1646 | Fax: 713.879.1868
Cell: 713.705.4875 | joshua.morrisette@bjservices.com
<http://www.bakerhughes.com> | *Advancing Reservoir Performance*

Email Attachments are next pages. H.

AIK 02.02.11




Figure 2: Facility Diagram		Revision Date: 01/02/11	Drawn By: JCM
BJ Services Company, USA 11211 FM 2920 Tomball, Texas 77375		Not To Scale	Artesia District 2401 Silvey Artesia, NM 88210

Layout of Lube Island



Lowe, Leonard, EMNRD

From: Lowe, Leonard, EMNRD
Sent: Wednesday, March 18, 2009 1:37 PM
To: 'Joshua.Morrisette@bjservices.com'
Subject: RE: Minor Modification Request for GW-190

The **OCD approves** your modification to GW-190.

I will annotate this to your file.

Please reflect this on your next discharge plan application.

Thank you for your attention.

llowe

Leonard Lowe

Environmental Engineer
Oil Conservation Division/EMNRD
1220 S. St. Francis Drive
Santa Fe, N.M. 87505
Office: 505-476-3492
Fax: 505-476-3462
E-mail: leonard.lowe@state.nm.us
Website: <http://www.emnrd.state.nm.us/ocd/>

From: Joshua.Morrisette@bjservices.com [mailto:Joshua.Morrisette@bjservices.com]
Sent: Wednesday, March 18, 2009 1:22 PM
To: Lowe, Leonard, EMNRD
Subject: RE: Minor Modification Request for GW-190

Yes the containment will hold 4,039 gallons, which is ~134% of 3,000 gallons.

Josh

BJ Services Company, USA
J. Morrisette
HSE Specialist
11211 FM 2920
Tomball, TX 77375
Office: 281.357.2573
Mobile: 713.705.4875
Fax: 281.357.2585

"Lowe, Leonard, EMNRD" <Leonard.Lowe@state.nm.us>

To <Joshua.Morrisette@bjservices.com>

cc

03/18/2009 02:19 PM

Subject RE: Minor Modification Request for GW-190

This AST being it's single walled will be bermed to 133% correct?

Leonard Lowe

Environmental Engineer
Oil Conservation Division/EMNRD
1220 S. St. Francis Drive
Santa Fe, N.M. 87505
Office: 505-476-3492
Fax: 505-476-3462
E-mail: leonard.lowe@state.nm.us
Website: <http://www.emnrd.state.nm.us/ocd/>

From: Joshua.Morrisette@bjservices.com [mailto:Joshua.Morrisette@bjservices.com]
Sent: Wednesday, March 18, 2009 1:17 PM
To: Lowe, Leonard, EMNRD
Subject: RE: Minor Modification Request for GW-190

No this is a single walled poly tank with secondary containment. I wasn't sure if the tank was going to be double walled or not and was providing guidance to them for both scenarios.

Josh

BJ Services Company, USA
J. Morrisette
HSE Specialist
11211 FM 2920
Tomball, TX 77375
Office: 281.357.2573
Mobile: 713.705.4875
Fax: 281.357.2585
"Lowe, Leonard, EMNRD" <Leonard.Lowe@state.nm.us>

03/18/2009 02:15 PM

To <Joshua.Morrisette@bjservices.com>
cc
Subject RE: Minor Modification Request for GW-190

This tank is the Tank within a tank design to be used as an AST, correct?
Your tank drawing doesn't specify that.
llowe

Leonard Lowe

Environmental Engineer
Oil Conservation Division/EMNRD
1220 S. St. Francis Drive
Santa Fe, N.M. 87505
Office: 505-476-3492
Fax: 505-476-3462
E-mail: leonard.lowe@state.nm.us
Website: <http://www.emnrd.state.nm.us/ocd/>

From: Joshua.Morrisette@bjsservices.com [mailto:Joshua.Morrisette@bjsservices.com]
Sent: Wednesday, March 18, 2009 12:53 PM
To: Lowe, Leonard, EMNRD
Subject: Minor Modification Request for GW-190

Leonard - Here is the information for the tank installation we were discussing on March 13th.

Material Stored - Mineral Oil

Capacity - 3,000 gallons

Tank Type - Vertical, poly, aboveground (See Attached Figure)

Containment - 12' x 15' x 3' (540 cu. Ft. or 4,039 gallon), 1/4 " carbon steel coated with an epoxy paint

Location - 4' to 6' east of the lube rack (See Attached Figure)

The Discharge Plan and the SPCC will be updated accordingly. This tank and containment will be inspected on a quarterly basis, at a minimum.

Let me know if any other information is needed. Please let me know if this minor modification is approved. Thanks Leonard.

Josh

BJ Services Company, USA
J. Morrisette
HSE Specialist
11211 FM 2920
Tomball, TX 77375
Office: 281.357.2573
Mobile: 713.705.4875
Fax: 281.357.2585

This inbound email has been scanned by the MessageLabs Email Security System.

Confidentiality Notice: This e-mail, including all attachments is for the sole use of the intended recipient(s) and may contain confidential and privileged information. Any unauthorized review, use, disclosure or distribution is prohibited unless specifically provided under the New Mexico Inspection of Public Records Act. If you are not the intended recipient, please contact the sender and destroy all copies of this message. -- This email has been scanned by the Sybari - Antigen Email System.

This inbound email has been scanned by the MessageLabs Email Security System.


Confidentiality Notice: This e-mail, including all attachments is for the sole use of the intended recipient(s) and may contain confidential and privileged information. Any unauthorized review, use, disclosure or distribution is prohibited unless specifically provided under the New Mexico Inspection of Public Records Act. If you are not the intended recipient, please contact the sender and destroy all copies of this message. -- This email has been scanned by the Sybari - Antigen Email System.

This inbound email has been scanned by the MessageLabs Email Security System.

TOP VIEW


NEW
MOLDED IN
LIFTING LUGS

Ø95.00"



16" LID ASSY. (STD.)
22" LID ASSY. (OPT.)

SIDE VIEW



				BAILIFF ENTERPRISES, INC. 8423 AIRLINE DRIVE, HOUSTON, TEXAS 77037 PHONE (281) 447-5372 FAX (281) 999-1223	
				CLIENT / DESCRIPTION 3,000 GALLON VERTICAL TANK	
				SCALE N.S.	PART NO. VTB3000-95
		DRAWN / DATE MPS/04/14/03		MATERIAL / SHOT WEIGHT HDPE 1.5 490 LBS.	
		APPRD. / DATE		HDPE 1.9 560 LBS.	
REV	DESCRIPTION	DATE	APPRD	NOTES:	
ALL DIMENSIONS ARE IN DECIMAL INCHES TOLERANCES UNLESS OTHERWISE SPECIFIED + .5% • 68° F				THIRD ANGLE PROJECTION ANSI 14.5M 	



Acid Dock

Wash Bay

LFC Benchmark Plant

LFC Mixing Shop

Bulk Plant and General Maintenance

Office and Shop

Mineral Oil AST Location

Fuel / Lube Oil Island

BJ Services - Artesia District
Mineral Oil AST Location