

District I
1625 N. French Dr., Hobbs, NM 88240
District II
811 S. First St., Artesia, NM 88210
District III
1000 Rio Brazos Road, Aztec, NM 87410
District IV
1220 S. St. Francis Dr., Santa Fe, NM 87505

State of New Mexico
Energy Minerals and Natural Resources
Department
Oil Conservation Division
1220 South St. Francis Dr.
Santa Fe, NM 87505

Form C-147
Revised April 3, 2017

Recycling Facility Only

Type of action: ☐ Permit ☒ Registration ☐ Modification ☐ Closure ☐ Other (explain) _____

Be advised that approval of this request does not relieve the operator of liability should operations result in pollution of surface water, ground water or the environment. Nor does approval relieve the operator of its responsibility to comply with any other applicable governmental authority's rules, regulations or ordinances.

1.
Operator: COG Operating LLC (For multiple operators attach page with information) OGRID #: 229137
Address: 600 W. Illinois Ave. Midland, Texas 79707
Facility or well name (include API# if associated with a well): Dominator 25 Fed Com O CTB Recycle Facility
OCD Permit Number: 1RF-439 (For new facilities the permit number will be assigned by the district office)
U/L or Qtr/Qtr O Section 25 Township 25 S Range 33 E County: Lea
Surface Owner: ☒ Federal ☐ State ☐ Private ☐ Tribal Trust or Indian Allotment

2.
☒ **Recycling Facility:**
Location of recycling facility (if applicable): Latitude 32.096648 Longitude -103.525092 NAD83
Proposed Use: ☐ Drilling* ☒ Completion* ☐ Production* ☐ Plugging*
**The re-use of produced water may NOT be used until fresh water zones are cased and cemented*
☐ Other, requires permit for other uses. Describe use, process, testing, volume of produced water and ensure there will be no adverse impact on groundwater or surface water.
☒ Fluid Storage
☒ Above ground tanks ☐ Activity permitted under 19.15.17 NMAC explain type _____
☐ Activity permitted under 19.15.36 NMAC explain type: _____ ☐ Other explain _____
☐ Closure Report (required within 60 days of closure completion): ☐ Recycling Facility Closure Completion Date: _____

3.
Variances:
Justifications and/or demonstrations that the proposed variance will afford reasonable protection against contamination of fresh water, human health, and the environment.
Check the below box only if a variance is requested:
☐ Variance(s): Requests must be submitted to the appropriate division district for consideration of approval. If a Variance is requested, include the variance information on a separate page and attach it to the C-147 as part of the application.
If a Variance is requested, it must be approved prior to implementation.

4.
Operator Application Certification:
I hereby certify that the information and attachments submitted with this application are true, accurate and complete to the best of my knowledge and belief.
Name (Print): Tim Reed Title: Water Resource Analyst
Signature: Tim Reed Date: 11/19/18
e-mail address: treed@concho.com Telephone: 432-238-8399

5.
OCD Representative Signature: Randolph Fajin Approval/Registration Date: 20Nov18
Title: Hydrologist OCD Permit Number: 1RF-439
☐ OCD Conditions _____
☐ Additional OCD Conditions on Attachment _____

CONCHO RECYCLED PRODUCED WATER SYSTEM OVERVIEW

Water will be sent to the Dominator 25 Fed Com O CTB pad site into one 60,000 bbl Buffer AST. Water will flow from the Buffer AST to the treatment system consisting of chemical treatment to reduce bacteria, total iron, H₂S, TPH and TSS.


From there, the water will flow into a series of clarifier/solids control tanks and then through a series of weir tanks and final filtration before flowing into two 30,000 bbl Treated Water AST.

Both the Buffer Tank and the Treated Water Tanks will be double lined with 30 mil LLDPE liners equipped with an automated leak detection system. Both tanks will be placed on a protective cushion.

The entire treatment area including tanks, treating systems and blending manifold will be located inside a 30 mil LL lined containment measuring approximately 600' x 350' x 2'. The lined secondary containment system tank pad will have capacity in excess of the largest single tank with sufficient additional capacity to include a significant rainfall event.

The facility will be manned and monitored at all times during operation.

Used filters will be stored in a roll-off bin located at the tank pad and will be disposed of at an approved facility.





March 19, 2015

Matt Smiley
General Manager -Fluids Management, Above-Ground Storage Tanks
Rockwater Energy Solutions
6000 Town Center Boulevard, Suite 165
Canonsburg, PA 15317

Subject: Transmittal - Analysis of Atlantis 48m +3, 18 Panel Above Ground Storage Tank


Dear Mr. Smiley:

As requested, I have analyzed the impact of adding three panels to the standard 48m Atlantis above ground storage tank such the resulting tank diameter is approximately 57.5m (188.6-ft). Results indicate that the loads imparted on the system by this configuration are within acceptable limits under the conditions analyzed. Key information related to this configuration is as follows:

- Minimum (Empty) Diameter: 188.46 ft
- Maximum (Full) Diameter: 188.60 ft
- Maximum (Full) Capacity: 59,721 BBL
- Capacity w/12-in Freeboard: 54,748 BBL
- Capacity w/24-in Freeboard: 49,774 BBL



Supporting calculations and shop drawings listing the basis of the analysis, applicable codes and standards and limitations are provided in the Enclosure. Please review the analysis carefully to ensure that site specific conditions meet the limitations and assumptions of the analysis before installing this system. Thank you for the opportunity to work with you on this project. Please contact me if you have any questions or require additional information.

Sincerely,



Stephen N. Valero, P.E.
Enclosure: Supporting Calculations & Shop Drawings



Enclosure - Supporting Calculations & Shop Drawings



NOTES:

- 1) For panel connection, assembly, and all other structural details refer to Drawing sheets 12167-5-001; 12167-5-002; and 12167-5-001 prepared for Open Range Energy, 48m Modular Water Tank by Dec's Engineering, Ltd. dated 12/17/2010.
- 2) For supporting analysis of the tank configuration illustrated above refer to Tank Structure Analysis Atlantis 48m + 3 Tank - Constructed using 8 Standard Atlantis 48m Diameter Tank Panels for total Diameter of Approximately 57.5m (188.6ft) prepared for Rockwater Energy Solutions by Stephen N. Valero, P.E. dated 5/19/2015.

DESIGNED BY:		STEPHEN N. VALERO, P.E.	
CHECKED BY:		STEPHEN N. VALERO, P.E.	
REVISION/ISSUE		0 03/19/2015 SHIP DRAWINGS	
DESIGNED FOR:		ROCKWATER ENERGY SOLUTIONS 6000 Tom Center Boulevard, Suite 105 Columbus, Pennsylvania 17017	
Project No.	201008	Client Name	Open Range Energy
Scale	1"=20'	Drawn By	03/18/2015
Checked By	03/18/2015	Drawn By	03/18/2015
ATLANTIS 48m (+3) 18 PANEL TANK		57.5 m (188.6 ft) DIA	
59,721 BBL MAX CAPACITY		TANK LAYOUT PLAN	



BECK ENGINEERING (1992) LTD.
www.beckeng.ab.ca

12167-S-001

DWG. NO.	REFERENCE DRAWINGS	REV	DATE	BY	CHKD	APPD	REVISIONS
12167-S-001	TANK WALL PANEL FRAMING DETAILS	A	14.12.10	BP	BP		DESIGN FOR REVIEW
12167-S-001	TANK ASSEMBLY LAYOUT PLAN & SECTIONS	0	17.12.10	BP	BP		DESIGN FOR CONSTRUCTION

CLIENT: OPEN RANGE ENERGY CORP

PROJECT: 48m dia. MODULAR WATER TANK

FRAMING PLAN, ELEVATION, SECTIONS & DETAILS

Job No.: 12167

Scale: AS NOTED

Rev. No.: 12167-S-001

Tank Structure Analysis
Atlantis 48m +3 Tank - Constructed using 18
Standard Atlantis 48.0m Diameter Tank Panels for
total Diameter of Approximately 57.5m (188.6ft)

Date: 3/19/2015

Prepared for:

*Rockwater Energy Solutions
6000 Town Center Blvd, Suite 165
Canonsburg, PA 15317*

Prepared by:




STEPHEN N. VALERO, P.E.

4010 New Chapel Hill Way, Cumming, GA 30041

P: 404-557-5884 | F: 678-807-2902

E: svalero@Wall-Eval.com



PROBLEM STATEMENT:

Evaluate the feasibility of using standard panels designed for the Atlantis 48m diameter tank to construct a 51.2m diameter tank by adding 1 panel from the standard set up configuration (Atlantis 48m +1). The analysis that follows will consider the adequacy of the following parts of the tank configuration:

- 1) Wall shell capacity
- 2) Wall panel connection assembly capacity
- 3) Impact of difference in tank radius and panel radius of curvature on system


Adequacy of lifting hooks, etc. will not be evaluated as this is not changed from standard Atlantis 48m tank.


INPUT INFORMATION:

Tank & Panel Geometry


$L := 10050\text{mm} = 32.97\text{ ft}$	Single wall panel length, per Ref 1
$H := 3.66\text{m} = 12.01\text{ ft}$	Tank height, per Ref 1
$n := 18$	Number of Panels used to construct tank, per Ref 2
$\text{Gap} := 5\text{mm} = 0.02\text{ ft}$	Gap between panel shells when tank is in service, per Ref 1
$\alpha_{\text{org}} := 24\text{deg}$	Original sector angle for panels in standard configuration, per Ref 1
$C_{\text{org}} := 9975\text{mm} = 32.73\text{ ft}$	Chord length of panels, per Ref 1
$c := 8$	Number of connection pin plates per panel side, per Ref 1
$i := 1..c + 1$	
$d_i :=$	Vertical distances between connection pin points on panel, per Ref 1
260mm	Top of Panel to Con 1
600mm	Con 1 to Con 2
600mm	Con 2 to Con 3
500mm	Con 3 to Con 4
500mm	Con 4 to Con 5
400mm	Con 5 to Con 6
300mm	Con 6 to Con 7
250mm	Con 7 to Con 8
250mm	Con 8 to Bottom of Panel

Copyright 2015 - Stephen N. Valero, PE










TYPICAL TANK WALL SECTION
SCALE 1 : 20



WALL SECTION AT PANEL JOINT
SCALE 1 : 20




ENLARGED TYPICAL PLAN - EXPLODED TO SHOW WELD DETAILS.
NOT TO SCALE



WALL PANEL CONNECTION PLATES
(x8 REQUIRED PER WALL PANEL)

The figure to the right shows the impact on tank/connection roundness due to the difference in panel radius of curvature and tank curvature due to changing the number of standard panels used. By inspection, the impact of this geometry is insignificant with regard to mid-panel bending failure. However, the small angle between the connection plate and repad plate will be taken into consideration when calculating maximum stress to be carried by the connection assembly.



$\beta := 2.0\text{deg}$

Angle between connection plate and repad plate for this tank configuration

Tank shell, Repad Plate, Connection Pin Plate and Connection Plate Steel Specifications

Steel := "CSA G40.21 300W Steel"

Steel specification, per Ref 1

Fu := 450MPa = 65266.98 psi

Ultimate strength, per Ref 3

Fy := 300MPa = 43.51 ksi

Yield strength, per Ref 3

Tank shell/rail specifications:

t_{shell} := 6mm = 0.24 in

Thickness, per Ref 1

d_{rail} := 102mm = 4.02 in

Depth of top/bottom rails connected to shell

Repad plate specifications:

t_{rp} := 13mm = 0.51 in

Thickness, per Ref 1

d_e_{rp} := 129.5mm = 5.1 in

Distance from connection pin plate hole to outside edge of plate, per Ref 1

b_{rp} := 300mm = 11.81 in

Width of repad plate, per Ref 1

d_{rp} := 3440mm = 135.43 in

Length of repad plate, per Ref 1

s_{rp} := 5mm = 0.2 in

Weld leg dimension for fillet welds between repad plate and shell, per Ref 1

Connection pin plate specifications

t_{pin} := 41mm = 1.61 in

Thickness, per Ref 1

h_{pin} := 114mm = 4.49 in

Height, per Ref 1

d_{ph}_{pin} := 27mm = 1.06 in

Distance from repad to inside of retaining pin hole, Per Ref 1

Connection plate specifications:

t_c_{plate} := 25mm = 0.98 in

Thickness, per Ref 1

h_c_{plate} := 216mm = 8.5 in

Height, per Ref 1

d_e_c_{plate} := 69mm = 2.72 in

Distance from pin hole to outside edge of plate, per Ref 1

h_{pinhole} := 122mm = 4.8 in

Dimensions of pin hole slots in connection plate, per Ref 1

w_{pinhole} := 45mm = 1.77 in

ASSUMPTIONS:

The following assumptions were required in order to complete this analysis:

Freeboard := 0 ft

Maximum permissible liquid depth (overflow condition)

$G_s := 1.0$

Specific gravity of contained liquid, assumed to be fresh water

$\gamma_{\text{water}} := 62.4 \text{ pcf}$

Unit weight of water

Resisting forces are provided by hoop tension in the wall panels/connections only.

$F_{E60} := 413 \text{ MPa} = 59.9 \text{ ksi}$

60 ksi electrodes used for all arc welding

The applied liquid pressure is considered a dead load as its maximum depth is limited by the maximum height of the tank walls. It is highly unlikely that the tank would remain full to the struck capacity for an extended period. Therefor, the following load factor will apply throughout these calculations

$LF := 1.4$

The only load applied to the system is due to the contained liquid. This analysis does not consider:

- Ice load
- Wind load
- Impact load
- Seismic load
- or any other potential internal/external load.

It is assumed that the tank is installed properly, on firm, level ground and that all steel, welds, etc. are in good condition.

REFERENCES:

1) Drawing sheets 12167-S-001; 12167-S-002; and 12167-E-001 prepared for Open Range Energy, 48m Modular Water Tank by Beck Engineering, Ltd. dated 12/17/2010.

2) CSA G40.20-13/G40.21-13 - General requirements for rolled or welded structural quality steel / Structural quality steel.

3) AISC Manual of Steel Construction, 13th Ed.

CALCULATIONS:

1) Determine the average (design) diameter of the tank:

$$\alpha := \frac{360\text{deg}}{n} = 20\text{-deg} \quad \text{Sector angle for each panel}$$

$$C_{\text{tot}} := C_{\text{org}} + \text{Gap} = 32.74 \text{ ft} \quad \text{Total segment length for each panel}$$

$$R := \frac{C_{\text{tot}}}{\sqrt{2 - 2 \cos(\alpha)}} = 94.28 \text{ ft} \quad \text{New radius of tank constructed with n panels}$$

$$D := 2 \cdot R = 188.56 \text{ ft} \quad \text{Inside diameter of tank}$$

2) Check stress level vs. capacity of tank shell:

$$z_{\text{cpshell}} := H - \text{Freeboard} - d_{\text{rail}} = 140.08\text{-in} \quad \text{Depth from top of tank to top of bottom rail, critical unsupported point of tank shell}$$

$$\gamma := LF \cdot G_s \cdot \gamma_{\text{water}} = 87.36\text{-pcf} \quad \text{Factored unit weight of contained liquid}$$

$$P_{\text{cpshell}} := (z_{\text{cpshell}} - \text{Freeboard}) \cdot \gamma = 7.08 \text{ psi} \quad \text{Maximum internal tank pressure at critical unsupported point in shell (between vertical stiffener rails and just above bottom rail).}$$

$$\sigma_{\text{shell}} := \frac{P_{\text{cpshell}} \cdot D}{2 \cdot t_{\text{shell}}} = 33917.21 \text{ psi} \quad \text{Use diameter Equation to estimate hoop tensile stress in shell at critical point (valid since } t_{\text{shell}}/\text{tank radius} \ll 0.10)$$

$$T_{\text{ashell}} := \min(0.9 \cdot F_y, 0.75 \cdot F_u) = 39160.19 \text{ psi} \quad \text{Allowable axial tensile stress per Ref 4}$$

$$\text{Check}_{\text{shell}} := \text{if}(\sigma_{\text{shell}} < T_{\text{ashell}}, \text{"OK"}, \text{"Shell thickness is insufficient"})$$

$$\text{Check}_{\text{shell}} = \text{"OK"} \quad \text{Check shell thickness}$$

3) Check stress level vs. capacity of panel connection assembly:

The connection assembly consists of: Repad plate welds to shell; repad plate, connection pins and connection plates.

3a) Check sufficiency of welds between repad plate and tank shell:

$$P_{\max_{\text{rpad}}} := (H - \text{Freeboard}) \cdot \gamma = 7.28 \text{ psi}$$

Maximum internal tank pressure at critical unsupported point in shell (between vertical stiffener rails and just above bottom rail).

$$T_{\max_{\text{rpad}}} := \frac{\frac{1}{2} \cdot P_{\max_{\text{rpad}}} \cdot H \cdot D}{2} = 593786.38 \text{ lbf}$$

Use Young-Laplace Equation to estimate total hoop tension to be transferred from shell to repad plate (valid since $t_{\text{shell}}/\text{tank radius} < 0.10$)

$$M_{\text{rpad}} := \left(\frac{H}{2} - \frac{H}{3} \right) \cdot T_{\max_{\text{rpad}}} = 14260223.97 \cdot \text{lbf} \cdot \text{in}$$

Torque on line welds transferring stress from shell to repad (5mm fillet along both sides)

$$C := \frac{\sqrt{b_{\text{rpad}}^2 + d_{\text{rpad}}^2}}{2} = 67.97 \cdot \text{in}$$

Distance from neutral axis to extreme fibers of welds

$$J_w := \frac{H}{6} \cdot \left(3b_{\text{rpad}}^2 + d_{\text{rpad}}^2 \right) = 450550.26 \cdot \frac{\text{in}^4}{\text{in}}$$

Polar moment of inertia of line welds

$$f := \frac{M_{\text{rpad}} \cdot C}{J_w} = 2151.41 \cdot \frac{\text{lbf}}{\text{in}}$$

Force of extreme fibers of welds

$$f_t := 0.75(0.6F_{E60}) \cdot (s_{\text{rpad}} \cdot 0.707) = 3751.45 \cdot \frac{\text{lbf}}{\text{in}}$$

Maximum allowable stress of welds

$$\text{Check}_{\text{rpadwelds}} := \text{if}(f < f_t, \text{"OK"}, \text{"Welds insufficient"})$$

$$\text{Check}_{\text{rpadwelds}} = \text{"OK"}$$

Check repad plate welds

3b) Determine critical connection pin location and load:

$$j := 2 \dots c - 1$$

$$z_0 := 0 \text{ in} \quad z_1 := d_1 + \frac{d_2}{2}$$

$$z_j := z_{j-1} + \left(\frac{d_j + d_{j+1}}{2} \right) \quad \text{Depth from top of wall panel to the bottom of contributory load area carried by each connection plate/pin set:}$$

$$z_8 := z_7 + \frac{d_8}{2} + d_9$$

$$j := 0 \dots c$$

$$z_j =$$

0	·in
22.05	
45.67	
67.32	
87.01	
104.72	
118.5	
129.33	
144.09	

Top of tank

Bottom of contributory area where load is carried by Connection 1



Bottom of contributory area where load is carried by Connection 8

$$P_j := \text{if} \left[z_j - \text{Freeboard} > 0 \text{ in}, \gamma \cdot (z_j - \text{Freeboard}), 0 \text{ psi} \right]$$

$$P_j =$$

0.00	psi	Top of tank
1.11		Con 1
2.31		Con 2
3.40		Con 3
4.40		Con 4
5.29		Con 5
5.99		Con 6
6.54		Con 7
7.28		Con 8

Pressure distribution inside tank at the bottom of contributory area carried by each connection point

$$k := 1 \dots c$$

$$T_{con_k} := \left[P_{k-1} \cdot (z_k - z_{k-1}) + \frac{1}{2} (P_k - P_{k-1}) \cdot (z_k - z_{k-1}) \right] \cdot \frac{D}{2} = \dots$$

Use Young-Laplace Equation to estimate total hoop tension to be transferred from repad plate to each connection (valid since tshell/tank radius << 0.10)

$$T_{con_k} =$$

13900.94	lbf	Con 1
45745.43		Con 2
69970.12		Con 3
86880.86		Con 4
97142.56		Con 5
87966.87		Con 6
76735.53		Con 7
115444.06		Con 8

Estimate of total tension carried at each connection point (actual load distribution is likely more evenly spread from repad plate to connections reducing total load carried by bottom connections). For this analysis, bottom connection will be considered critical and analyzed vs. total contribution load (conservative).

$$T_{con} := T_{con_c} = 115444.06 \text{ lbf}$$

Critical connection load, bottom connection

$$T_{con} := \frac{T_{con}}{\cos(\beta)} = 115514.42 \text{ lbf}$$

Effect of load vector due to change in geometry at connection point induced by difference in tank radius and radius of curvature of panels

$$d_{rpad} := z_c - z_{c-1} = 14.76 \cdot \text{in}$$

Contributory length of repad plate carrying critical load

3c) Check the repad plate for sufficient strength to transfer critical load to connection pins:

$$A_{grpad} := d_{rpad} \cdot t_{rpad} = 7.56 \cdot \text{in}^2$$

Theoretical gross section area subject to tension

$$A_{nrpad} := (d_{rpad} - h_{pin}) \cdot t_{rpad} = 5.26 \cdot \text{in}^2$$

Theoretical net section area subject to tension

$$A_{nsrpad} := 2 \cdot d_{erpad} \cdot t_{rpad} = 5.22 \cdot \text{in}^2$$

Theoretical net section area subject to shear (tear out)

$$T_{nrpad} := \min[0.9 \cdot F_y \cdot A_{grpad}, 0.75 \cdot F_u \cdot A_{nrpad}, 0.75 \cdot (0.6 \cdot F_u) \cdot A_{nsrpad}] = 153278.67 \text{ lbf}$$

Allowable tension on the repad considering yielding on the gross section, fracture on the net section and tear out.

$$\text{Check}_{rpad} := \text{if}(T_{con} < T_{nrpad}, \text{"OK"}, \text{"Repad insufficient"})$$

$$\text{Check}_{rpad} = \text{"OK"}$$

Check on thickness of repad plate

3d) Check the connection pin plates for sufficient strength to transfer critical load to connection plates.

$$R_{n_{pin}} := 0.75 \cdot (0.6 \cdot F_u) \cdot h_{pin} \cdot t_{pin} = 212778.29 \text{ lbf}$$

Allowable shear load on pin plate

$$M_{pin} := T_{con} \cdot \left(d_{ph_{pin}} - \frac{t_{cplate}}{2} \right) = 65943.27 \text{ lbf} \cdot \text{in}$$

Factored maximum moment on pin plate at intersection with repad plate (critical point) under worst case conditions (plate contacts retaining pin)

$$M_{n_{pin}} := 0.9 \cdot \frac{h_{pin} \cdot t_{pin}^2}{6} \cdot F_y = 76324.67 \text{ lbf} \cdot \text{in}$$

Allowable bending moment on pin plate

$$Check_{pin} := \text{if}(T_{con} < R_{n_{pin}}, \text{if}(M_{pin} < M_{n_{pin}}, "OK", "Pin Insufficient"), "Pin Insufficient")$$

Check_{pin} = "OK"

Check on pin dimensions

3e) Check the connection plate for sufficient strength to transfer critical load from connection pins to next panel:

$$A_{g_{cplate}} := h_{cplate} \cdot t_{cplate} = 8.37 \cdot \text{in}^2$$

Gross section area subject to tension

$$A_{t_{cplate}} := (h_{cplate} - h_{pinhole}) \cdot t_{cplate} = 3.64 \cdot \text{in}^2$$

Net section area subject to tension

$$A_{nbs_{cplate}} := \left(d_{cplate} + \frac{h_{cplate} - h_{pinhole}}{2} \right) \cdot t_{cplate} = 4.5 \cdot \text{in}^2$$

Net section area subject to block shear (tear out)

$$A_{vg_{cplate}} := \left(d_{cplate} + \frac{w_{pinhole}}{2} \right) \cdot t_{cplate} = 3.55 \cdot \text{in}^2$$

Gross section area subject to shear yield

$$A_{tg_{cplate}} := \left(\frac{h_{cplate}}{2} \right) \cdot t_{cplate} = 4.19 \cdot \text{in}^2$$

Gross section area subject to tensile yield

$$A_{ns_{cplate}} := d_{cplate} \cdot t_{cplate} = 2.67 \cdot \text{in}^2$$

Net section area subject to shear fracture

$$A_{nt_{cplate}} := \left(\frac{h_{cplate} - h_{pinhole}}{2} \right) \cdot t_{cplate} = 1.82 \cdot \text{in}^2$$

Net section area subject to tensile fracture

$$T_{ngen_{cplate}} := \min(0.9 \cdot F_y \cdot A_{g_{cplate}}, 0.75 \cdot 1.0 F_u \cdot A_{t_{cplate}}) = 178301.59 \text{ lbf}$$

Allowable general yield/fracture limit tension

$$T_{nbs_{cplate}} := 0.75 \cdot (0.6 \cdot F_u) \cdot A_{nbs_{cplate}} = 132019.05 \text{ lbf}$$

Allowable block shear tension

$$T_{nsy_{cplate}} := \min[0.75 \cdot (0.6 F_y \cdot A_{vg_{cplate}} + F_u \cdot A_{nt_{cplate}}), 0.75 \cdot (0.6 F_u \cdot A_{ns_{cplate}} + F_y \cdot A_{tg_{cplate}})] = 158574.61 \text{ lbf}$$

Allowable yield/fracture tension

$$T_{n_{cplate}} := \min(T_{ngen_{cplate}}, T_{nbs_{cplate}}, T_{nsy_{cplate}}) = 132019.05 \text{ lbf}$$

Block shear controls

$$Check_{cplate} := \text{if}(T_{con} < T_{n_{cplate}}, \text{"OK"}, \text{"Connection plate insufficient"})$$

$$Check_{cplate} = \text{"OK"}$$

Check on dimensions of connection plate

4) Summary of final Capacity and Dimensions

$$D = 188.56 \text{ ft}$$

Design inside diameter of tank

$$\alpha = 20 \cdot \text{deg}$$

Arc intersected by each panel

$$D_{min} := \frac{2C_{org}}{\sqrt{2 - 2\cos(\alpha)}} = 188.46 \text{ ft}$$

Minimum inside diameter of tank when empty

$$D_{max} := \frac{2 \left[C_{tot} + \left(\frac{w_{pinhole} - t_{pin}}{2} \right) \right]}{\sqrt{2 - 2\cos(\alpha)}} = 188.60 \text{ ft}$$

Maximum inside diameter of tank when full

$$\text{Freeboard} = 0 \cdot \text{in}$$

Design freeboard used in analysis

$$V_{design} := (H - \text{Freeboard}) \cdot \frac{\pi \cdot D^2}{4} = 59721 \cdot \text{BBL}$$

Design capacity (No freeboard)

$$V_{max} := H \cdot \pi \cdot \frac{D^2}{4} = 59721 \cdot \text{BBL}$$

Maximum capacity (filled to top)

Design capacity (with varying freeboard):

$$\text{Freeboard} := 12 \text{ in}$$

$$V_{design} := (H - \text{Freeboard}) \cdot \frac{\pi \cdot D^2}{4} = 54748 \cdot \text{BBL}$$

$$\text{Freeboard} := 24 \text{ in}$$

$$V_{design} := (H - \text{Freeboard}) \cdot \frac{\pi \cdot D^2}{4} = 49774 \cdot \text{BBL}$$

SKAPS TRANSNET™
HDPE GEONET TN 220



SKAPS INDUSTRIES

571 Industrial Pkwy,
Commerce, GA 30529
Phone: (706) 336-7000
Fax: (706) 336-7007
E-Mail: contact@skaps.com

SKAPS TRANSNET™ geonet consists of SKAPS Geonet made from HDPE resin.

PROPERTY	TEST METHOD	UNIT	VALUE	QUALIFIER
Thickness	ASTM D 5199	mil	200	MAV ⁽³⁾
Carbon Black	ASTM D 4218	%	2.0	MAV
Tensile Strength	ASTM D 7179	lb/in	45	MAV
Melt Flow	ASTM D 1238 ⁽²⁾	g/10 min	1.0	Maximum
Density	ASTM D 1505	g/cm ³	0.94	MAV
Transmissivity ⁽¹⁾	ASTM D 4716	gal/min/ft (m ² /sec)	9.67 (2.0 x 10 ⁻³)	MAV

Notes:

(1) Transmissivity measured using water at 21 ± 2 °C (70 ± 4 °F) with a gradient of 0.1 and a confining pressure of 10,000 psf between steel plates after 15 minutes. Values may vary with individual labs.

(2) Condition 190/2.16

(3) Minimum average value

This information is provided for reference purposes only and is not intended as a warranty or guarantee.

SKAPS assumes no liability in connection with the use of this information.

HYDRAFLEX™ HT30

CO-EXTRUDED TEXTURED LLDPE

RAVEN

PRODUCT DESCRIPTION

HydraFlex™ HT30 is a co-extruded one-side textured linear-low-density polyethylene (LLDPE) geomembranes containing carbon black and ultraviolet inhibitors to ensure protection against harmful UV degradation. HT-Series one-side textured LLDPE provides increased friction, elongation, and flexibility. Available in black and black/gray color options with the gray side providing a cooler surface against contrasting colors and a vital function for ease of damage detection during installation.

PRODUCT USE

HydraFlex™ HT30 is used in applications demanding increased friction resistance characteristics in sloped areas. These highly flexible geomembranes will conform to uneven subgrades.

SIZE & PACKAGING

HydraFlex™ HT30 can be fabricated into panels up to 35,000. sq. ft. All panels are accordion folded and rolled on a heavy duty core for ease of handling and time saving installation.



Reservoir Liner

PRODUCT

PART

HydraFlex™ HT30B

HydraFlex™ HT30BG

APPLICATIONS

Oilfield Pit Liners	Leachate Collections Ponds
Well Pad Liners	Brine Ponds
Secondary Containment	Canal and Frac Reservoir Liners
Waste Lagoon Liners	Landfill Caps
Farm Ponds	Golf Course Ponds
Soil Remediation Liners	Frac Reservoir Liners

HYDRAFLEX™ HT30

CO-EXTRUDED TEXTURED LLDPE

PRO-FORMA DATA SHEET		HYDRAFLEX™ HT30			
		IMPERIAL		METRIC	
		MINIMUM	TYPICAL	MINIMUM	TYPICAL
APPEARANCE		Black & Black/Gray		Black & Black/Gray	
THICKNESS, AVERAGE	ASTM D5994	27 mil	28.5 mil	0.69 mm	0.72 mm
WEIGHT		146 lbs/msf		713 g/m²	
ASPERITY HEIGHT	ASTM D7466	10 mil	14 mil	0.25 mm	0.36 mm
TENSILE STRENGTH AT BREAK	ASTM D6693	50 ppi	80 ppi	88 N/cm	140 N/cm
TENSILE ELONGATION AT BREAK	ASTM D6693	300 %	600 %	300 %	600 %
TEAR RESISTANCE	ASTM D1004	14 lbs	18 lbs	62 N	80 N
PUNCTURE RESISTANCE	ASTM D4833	39 lbs	57 lbs	173 N	254 N
STANDARD OIT OR HIGH PRESSURE HPOIT	ASTM D3895 ASTM D5885	100 min 400 min	150 min 600 min	100 min 400 min	150 min 600 min
CARBON BLACK (BLACK LAYERS ONLY)	ASTM D4218	2.0 - 3.0 %	2.5 %	2.0 - 3.0 %	2.5 %
HYDRAULIC CONDUCTIVITY		2.4 x 10 ⁻¹⁰ cm/sec			
MAXIMUM STATIC USE TEMPERATURE		180° F		82° C	
MINIMUM STATIC USE TEMPERATURE		-70° F		-57° C	
FACTORY SEAM REQUIREMENTS					
BONDED SEAM STRENGTH	ASTM D6392	45 lbf/in width	63 lbf/in width	200 N	280 N
SEAM PEEL ADHESION	ASTM D6392	38 lbf/in width	48 lbf/in width	169 N	214 N

PRO-FORMA Sheet Contents. The test values listed in this Pro-Forma data sheet are representative of initial production runs. These values may be revised at anytime without notice as additional test data becomes available.



HydraFlex™ HT30 is a co-extruded one-side textured linear-low-density polyethylene (LLDPE) geomembranes containing carbon black and ultraviolet inhibitors to ensure protection against harmful UV degradation. HT-Series one-side textured LLDPE provides increased friction, elongation, and flexibility. Available in black and black/gray color options with the gray side providing a cooler surface against contrasting colors and a vital function for ease of damage detection during installation.

Note: To the best of our knowledge, unless otherwise stated, these are typical property values and are intended as guides only, not as specification limits. Chemical resistance, odor transmission, longevity as well as other performance criteria is not implied or given and actual testing must be performed for applicability in specific applications and/or conditions. RAVEN INDUSTRIES MAKES NO WARRANTIES AS TO THE FITNESS FOR A SPECIFIC USE OR MERCHANTABILITY OF PRODUCTS REFERRED TO, no guarantee of satisfactory results from reliance upon contained information or recommendations and disclaims all liability for resulting loss or damage. Limited Warranty available at www.RavenEFD.com

RAVEN ENGINEERED FILMS
P.O. Box 5107 Sioux Falls, SD 57117-5107
Ph: +1 (605) 335-0174 • TF: +1 (800) 635-3456

efdsales@ravenind.com
www.ravenefd.com

RAVEN



Premium Quality - Built to Last

www.inlandtarp.com

Raw Material

Linear Low Density Polyethylene

A geomembrane manufactured from maximum quality linear low density polyethylene LLDPE resins, duly contrasted, that comply with the most rigorous requirements established for their use.

Contains 97,5% of pure polymer, and approximately 2,5% of Carbon Black, antioxidants and thermal stabilizers. The product does not contain plasticizers or fillers that can migrate over time.

The geomembrane is manufactured under permanent quality controls.

Surface	Smooth	Colour	Black
		RAL Code	-

	Tested Property	Unit	Test Method	Value		Tested Property	Unit	Test Method	Value
Raw Material Identification	Density of Raw Material	g/cm ³	ASTM D 792	0.915-0.926	Functional Properties	Low Temperature Brittleness (t ^o : -40°C)	-	ASTM D 746	No cracks
	Density of Geomembrane	g/cm ³	ASTM D 792	0.925-0.939		Water Permeability	m ³ /m ² ·day	EN 14150	< 1·10 ⁻⁶
	Melt Flow Index	g/10 min	ASTM D 1238 (190°C/2.16 Kg)	< 1,0		Coefficient of Linear Thermal Expansion	1/K	ASTM D 696	2,15·10 ⁻⁴
	Carbon Black Content	%	ASTM D 4218	2.0 - 2.5		Water Absorption	%	ASTM D 570 (24h)	≤ 0.2
	Carbon Black Dispersion	-	ASTM D 5596	Note (3)				ASTM D 570 (6 days)	≤ 1
Durability	Oxidative Induction Time (OIT) Standard OIT	min	ASTM D 3895 (200°C)	≥ 100					
	High Pressure OIT		ASTM D 5885	≥ 400					
	Oven aging at 85°C HP OIT, % retained after 90 days	%	ASTM D 5721 ASTM D 5885	≥ 60					
	UV Resistance.	%							
	HP OIT, % retained after 1600 hrs		ASTM D 5885	≥ 35					

Strength Characteristics Quality of Final Product	Tested Property		Unit	Test Method		Value					
	Thickness		mils	ASTM D 5199	30	40	60	80	100	120	
	Tolerance		%		-10						
	Mechanical Properties										
	Tensile strength at Break ⁽¹⁾		lb/in	ASTM D 6693 (Type IV), lo 2 in	125 (108)	171 (148)	256 (222)	342 (296)	428 (371)	513 (445)	
	Elongation at Break		%		≥ 800						
	Tear Resistance		lb	ASTM D 1004	≥ 15	≥ 21	≥ 32	≥ 43	≥ 53	≥ 64	
	Puncture Resistance		lb	ASTM D 4833	≥ 42	≥ 56	≥ 84	≥ 112	≥ 140	≥ 168	
	2% Modulus		lb/in	ASTM D 5323	≤ 1800	≤ 2400	≤ 3600	≤ 4800	≤ 6000	≤ 7200	
	Axi-Symmetric Break Resistance Strain		%	ASTM D 5617	≥ 30						
Dimensional Stability		%	ASTM D 1204 (100°C, 1h)	± 1.5							

	Parameter	Units	30	40	60	80	100	120
280717 PRESENTATION (Standard Sizes)	Roll width ⁽⁴⁾	ft	19.7					
	Roll Length ⁽⁴⁾	ft	1,332	999	666	498	399	333
	Surface	ft ²	26,240.4	19,680.3	13,120.2	9,810.6	7,860.3	6,560.1

⁽¹⁾ Values indicated are medium. In brackets minimum values.

⁽²⁾ Certificates belonging to the Environmental and Quality Integrated System of IIT.


⁽³⁾ Carbon black dispersion (only near spherical agglomerates) for 10 different views: 9 in Categories 1 or 2 and 1 in Category 3

⁽⁴⁾ Roll lengths and widths have a tolerance of ±1%.

This information is provided for reference purposes. IIT assumes no liability in connection with the use of this information or the final use of the product. It may be revised at any time or at least every two years, so it is subject to change permanently.

U.S. Fabrication & Distribution Centers

Moses Lake, Washington . . . 4172 North Frontage Road E, Moses Lake, WA 98837 • 800.346.7744 • Fax 509.766.0414
 Fostoria, Ohio . . . 1600 North Main Street, Fostoria, OH 44830 • 888.377.5640 • Fax 419.436.6007
 Odessa, Texas . . . 8784 W. Interstate 20, Odessa, TX 79763 • 432.272.9413







MUSCLE WALL®

Specifications:

- Material
 - Low density polyethylene
 - Elongation to yield: 20%
 - Impact strength: 190 ft-lb
 - Tensile strength at yield: 2600 psi
- All Season Compatible
 - Temperature range: -40° F to 180° F
 - 10 year UV rated
- Portable
 - Weight per unit (empty): 55lbs
 - Weight per unit (filled): 650lbs
 - Units nest together for transportation
- Ground Pressure
 - Empty: 0.0333 psi
 - Filled: 0.3939 psi
- Dimensions
 - Minimum polyethylene thickness: 0.25"
 - Footprint on ground: 11.5 ft²
 - 6 ft. wide x 2 ft. deep x 2 ft. high
 - Installed in 6 ft. sections
 - Fit 256 units on one 48 ft. flatbed trailer

2 Foot System

MUSCLE WALL®



Features:

- Walls interconnect
- Connection acts like a hinge allowing for 22° of motion
- Corner piece allows 90° turns
- Ratchet straps restrain adjacent panels
- Tongue and groove panel interface for easy staking
- Patent Protected
 - US 8.313.265 B2
 - USD 631977
 - US 634443

Contact us:

Please contact us with any questions you have regarding Muscle Wall and how we can help you with your water management needs.

Email – info@musclewall.com

Toll-free – 1.800. 801.8739

Fax – 435.514.6707

Mail – 675 North 600 West Suite 1

Logan, UT 84321

Web – www.musclewall.com