

Venegas, Victoria, EMNRD

From: Fulks, Brett <Brett.Fulks@dvn.com>
Sent: Tuesday, June 4, 2019 9:26 PM
To: Venegas, Victoria, EMNRD; Hamlet, Robert, EMNRD; Bratcher, Mike, EMNRD; Griswold, Jim, EMNRD
Cc: Mathews, Wesley; Davis, Amanda; DeHoyos, Kendra
Subject: [EXT] Notification - Burton Flat Deep Unit #43 (30-015-33626)

Notification - Burton Flat Deep Unit #43 (30-015-33626)

Good evening,

Devon Energy is reporting a fire and release on the Burton Flat Deep Unit #43 (30-015-33626)

Section 03, Township 21S Range 27E 990' FSL 660' FEL
32.5047226,-104.1709137 NAD83

The Release occurred on 6/3/19 @ 9:49 PM

Released: Approximately 108 bbls of produced water and condensate.

Recovered: on-going

This release occurred due to a lightning strike to one of the produced water tanks. The tank was inside a lined secondary containment, though damage from the fire caused the containment to leak some of the released fluids. This area is being evaluated and a C-141 will be submitted. If you have any additional questions please feel free to contact me.

Thank you,

Brett Fulks

EHS Supervisor

432-301-3223

Devon Energy Corporation

PO Box 250

Artesia, NM 88211



Devon - Internal

Confidentiality Warning: This message and any attachments are intended only for the use of the intended recipient(s), are confidential, and may be privileged. If you are not the intended recipient, you are hereby notified that any review, retransmission, conversion to hard copy, copying, circulation or other use of all or any portion of this message and any attachments is strictly prohibited. If you are not the intended recipient, please notify the sender immediately by return e-mail, and delete this message and any attachments from your system.