



December 8th, 2025

State of New Mexico
Energy, Minerals, and Natural Resources Department
Oil Conservation Division
1220 South St. Francis Dr.
Santa Fe, NM 87505

Re: 2RF-149 Solaris Water Midstream Eddy State Water Treatment and Reuse Facility C-147 Annual Extension

To Whom it May Concern,

Solaris Water Midstream, LLC. respectfully submits the enclosed C-147 form, summary of monthly inspections and leak detection for the Eddy State Water Treatment and Reuse Facility. For original site plans and submittals, please refer to the facility's original registration application, OCD Registration number 2RF-149, received November 2nd, 2020. In accordance with NMAC 19.15.34.10 RECYCLING CONTAINMENTS, Solaris Water Midstream wishes to seek a one-year extension to the facility. The annual extension dates requested will be from November 2nd, 2025, to November 2nd, 2026.

NMAC 19.15.34.10 RECYCLING CONTAINMENTS

C. Registered recycling containments may be operated for five years from the date on which the registration is filed with the division. The operator may extend the allowed time on an annual basis thereafter with division approval if, 30 days prior to the registration expiration, the operator files a form C-147 with an attached summary showing all monthly inspections at the containment, including the monitoring of the leak detection system, showing the containment's integrity has not been compromised.

Sincerely,

A handwritten signature in cursive script that reads "Chad Gallagher".

Chad Gallagher

Permitting Agent

State of New Mexico
Energy Minerals and Natural Resources
Department Oil Conservation Division
1220 South St. Francis Dr.
Santa Fe, NM 87505
<https://www.emnrd.nm.gov/ocd/ocd-e-permitting/>

Form C-147
Revised October 11, 2022

Recycling Facility and/or Recycling Containment

Type of Facility: ☒ Recycling Facility ☒ Recycling Containment*
Type of action: ☐ Permit ☐ Registration
☐ Modification ☒ Extension
☐ Closure ☒ Other (explain) Annual Extension

*** At the time C-147 is submitted to the division for a Recycling Containment, a copy shall be provided to the surface owner.**

Be advised that approval of this request does not relieve the operator of liability should operations result in pollution of surface water, ground water or the environment. Nor does approval relieve the operator of its responsibility to comply with any other applicable governmental authority's rules, regulations or ordinances.

1.
 Operator: Solaris Water Midsteam, LLC (For multiple operators attach page with information) OGRID #: 371643
 Address: 9651 Katy Fwy, Suite 400, Houston Texas 77024
 Facility or well name (include API# if associated with a well): Eddy State Water Treatment and Reuse Facility (AST)
 OCD Permit Number: 2RF-149 (For new facilities the permit number will be assigned by the district office)
 U/L or Qtr/Qtr K Section 2 Township 26S Range 29E County: Eddy
 Surface Owner: ☐ Federal ☒ State ☐ Private ☐ Tribal Trust or Indian Allotment

2.
☒ **Recycling Facility:**
 Location of recycling facility (if applicable): Latitude 32.07058° Longitude -103.95627° NAD83
 Proposed Use: ☒ Drilling* ☒ Completion* ☒ Production* ☒ Plugging *
**The re-use of produced water may NOT be used until fresh water zones are cased and cemented*
☐ Other, *requires permit for other uses. Describe use, process, testing, volume of produced water and ensure there will be no adverse impact on groundwater or surface water.*
☒ Fluid Storage
☒ Above ground tanks ☐ Recycling containment ☐ Activity permitted under 19.15.17 NMAC explain type _____
☐ Activity permitted under 19.15.36 NMAC explain type: _____ ☐ Other explain _____
☐ For multiple or additional recycling containments, attach design and location information of each containment
☐ **Closure Report (required within 60 days of closure completion):** ☐ Recycling Facility Closure Completion Date: _____

3.
☒ **Recycling Containment:**
☒ Annual Extension after initial 5 years (attach summary of monthly leak detection inspections for previous year)
 Center of Recycling Containment (if applicable): Latitude 32.07058° Longitude -103.95627° NAD83
☐ For multiple or additional recycling containments, attach design and location information of each containment
☒ Lined ☐ Liner type: Thickness 40&30 mil ☒ LLDPE ☐ HDPE ☐ PVC ☐ Other _____
☐ String-Reinforced
 Liner Seams: ☒ Welded ☐ Factory ☐ Other _____ Volume: 60,000 bbl Dimensions: L _____ x W _____ x D _____
☐ Recycling Containment Closure Completion Date: _____

4.

Bonding:

- ☐ Covered under bonding pursuant to 19.15.8 NMAC per 19.15.34.15(A)(2) NMAC (These containments are limited to only the wells owned or operated by the owners of the containment.)
- ☒ Bonding in accordance with 19.15.34.15(A)(1). Amount of bond \$ _____ (work on these facilities cannot commence until bonding amounts are approved)
- ☐ Attach closure cost estimate and documentation on how the closure cost was calculated.

5.

Fencing:

- ☐ Four foot height, four strands of barbed wire evenly spaced between one and four feet
- ☒ Alternate. Please specify See Variance

6.

Signs:

- ☐ 12"x 24", 2" lettering, providing Operator's name, site location, and emergency telephone numbers
- ☒ Signed in compliance with 19.15.16.8 NMAC

7.

Variances:

Justifications and/or demonstrations that the proposed variance will afford reasonable protection against contamination of fresh water, human health, and the environment.

Check the below box only if a variance is requested:

☒ Variance(s): Requests must be submitted to the appropriate division district for consideration of approval. If a Variance is requested, include the variance information on a separate page and attach it to the C-147 as part of the application.

If a Variance is requested, it must be approved prior to implementation.

8.

Siting Criteria for Recycling Containment

Instructions: The applicant must provide attachments that demonstrate compliance for each siting criteria below as part of the application. Potential examples of the siting attachment source material are provided below under each criteria.

General siting**Ground water is less than 50 feet below the bottom of the Recycling Containment.**

NM Office of the State Engineer - iWATERS database search; USGS; Data obtained from nearby wells

☐ Yes ☒ No
☐ NA

Within incorporated municipal boundaries or within a defined municipal fresh water well field covered under a municipal ordinance adopted pursuant to NMSA 1978, Section 3-27-3, as amended.

- Written confirmation or verification from the municipality; written approval obtained from the municipality

☐ Yes ☒ No
☐ NA

Within the area overlying a subsurface mine.

- Written confirmation or verification or map from the NM EMNRD-Mining and Minerals Division

☐ Yes ☒ No

Within an unstable area.

- Engineering measures incorporated into the design; NM Bureau of Geology & Mineral Resources; USGS; NM Geological Society; topographic map

☐ Yes ☒ No

Within a 100-year floodplain. FEMA map

☐ Yes ☒ No

Within 300 feet of a continuously flowing watercourse, or 200 feet of any other significant watercourse, or lakebed, sinkhole, or playa lake (measured from the ordinary high-water mark).

- Topographic map; visual inspection (certification) of the proposed site

☐ Yes ☒ No

Within 1000 feet from a permanent residence, school, hospital, institution, or church in existence at the time of initial application.

- Visual inspection (certification) of the proposed site; aerial photo; satellite image

☐ Yes ☒ No

Within 500 horizontal feet of a spring or a fresh water well used for domestic or stock watering purposes, in existence at the time of initial application.

- NM Office of the State Engineer - iWATERS database search; visual inspection (certification) of the proposed site

☐ Yes ☒ No

Within 500 feet of a wetland.

- US Fish and Wildlife Wetland Identification map; topographic map; visual inspection (certification) of the proposed site

☐ Yes ☐ No

9.

Recycling Facility and/or Containment Checklist:**Instructions:** Each of the following items must be attached to the application. Indicate, by a check mark in the box, that the documents are attached.

- ☒ Design Plan - based upon the appropriate requirements.
- ☒ Operating and Maintenance Plan - based upon the appropriate requirements.
- ☒ Closure Plan - based upon the appropriate requirements.
- ☒ Site Specific Groundwater Data -
- ☒ Siting Criteria Compliance Demonstrations -
- ☒ Certify that notice of the C-147 (only) has been sent to the surface owner(s)

10.

Operator Application Certification:

I hereby certify that the information and attachments submitted with this application are true, accurate and complete to the best of my knowledge and belief.

Name (Print): Chad Gallagher Title: Permit Agent
 Signature: *Chad Gallagher* Date: 12/8/2025
 e-mail address: chad.gallagher@ariswater.com Telephone: (575)444-9786

11.

OCD Representative Signature: *Victoria Venegas* Approval Date: 12/17/2025Title: Environmental Specialist OCD Permit Number: 2RF-149

- ☒ OCD Conditions _____
☒ Additional OCD Conditions on Attachment _____

Asset Name	User Full Name	Work Order Description	Date	Berm - Are there any breaks in the berm?	Bird Net - Is the bird net functional?	Freeboard Level - List the Freeboard level (in feet).	Detection - Is the Leak Detection functional?	Liner - Is there a tear in the liner?	Oil - Is there any oil on fluid?	Water - Is there any run-on storm	Tank Level - List the Tank level (in feet).	Wildlife - Is there any dead wildlife?
Eddy State AST	Agustin Carmona	Weekly AST Inspection	12/3/2025	Pass	Pass	3 ft	N/A	Pass	Fail	Pass	5 ft	Pass
Eddy State AST	Jesus Chavez	Weekly AST Inspection	11/26/2025	Pass	Pass	4 ft	N/A	Pass	Fail	Pass	6 ft	Pass
Eddy State AST	Agustin Carmona	Weekly AST Inspection	11/19/2025	Pass	Pass	1	Pass	Pass	Pass	Pass	8	Pass
Eddy State AST	Jesus Chavez	Weekly AST Inspection	11/12/2025	Pass	Fail	5 ft	N/A	Pass	Fail	Pass	5 ft	Pass
Eddy State AST	Agustin Carmona	Weekly AST Inspection	11/5/2025	Pass	Pass	3	Pass	Pass	Pass	Pass	7	Pass
Eddy State AST	Jesus Chavez	Weekly AST Inspection	10/29/2025	Pass	Fail	5 ft	N/A	Pass	Fail	Pass	5 ft	Pass
Eddy State AST	Agustin Carmona	Weekly AST Inspection	10/22/2025	Pass	Pass	2	Pass	Pass	Pass	Pass	7	Pass
Eddy State AST	Jesus Chavez	Weekly AST Inspection	10/15/2025	Pass	Fail	5 ft	N/A	Pass	Fail	Pass	5.5 ft	Pass
Eddy State AST	Agustin Carmona	Weekly AST Inspection	10/8/2025	Pass	Pass	2	Pass	Pass	Pass	Pass	7	Pass
Eddy State AST	Jesus Chavez	Weekly AST Inspection	10/1/2025	Pass	Fail	5 ft	N/A	Pass	Fail	Pass	5 ft	Pass
Eddy State AST	Agustin Carmona	Weekly AST Inspection	9/24/2025	Pass	Pass	4	Pass	Pass	Pass	Pass	5	Pass
Eddy State AST	Jesus Chavez	Weekly AST Inspection	9/17/2025	Pass	Fail	3 ft	N/A	Pass	Fail	Pass	7 ft	Pass
Eddy State AST	Agustin Carmona	Weekly AST Inspection	9/10/2025	Pass	Pass	3	Pass	Pass	Pass	Pass	7	Pass
Eddy State AST	Jesus Chavez	Weekly AST Inspection	9/3/2025	Pass	Pass	2 ft	N/A	Pass	Fail	Pass	8 ft	Pass
Eddy State AST	Agustin Carmona	Weekly AST Inspection	8/27/2025	Pass	Pass	4	Pass	Pass	Pass	Pass	6	Pass
Eddy State AST	Jesus Chavez	Weekly AST Inspection	8/20/2025	Pass	Fail	2.4 ft	N/A	Pass	Fail	Pass	7.8 ft	Pass
Eddy State AST	Agustin Carmona	Weekly AST Inspection	8/13/2025	Pass	Pass	8	Pass	Pass	Pass	Pass	1	Pass
Eddy State AST	Jesus Chavez	Weekly AST Inspection	8/6/2025	Pass	Fail	3 ft	N/A	Pass	Fail	Pass	7 ft	Pass
Eddy State AST	Agustin Carmona	Weekly AST Inspection	7/30/2025	Pass	Pass	1	Pass	Pass	Pass	Pass	8	Pass
Eddy State AST	Jesus Chavez	Weekly AST Inspection	7/23/2025	Pass	Fail	2.3 ft	N/A	Pass	Fail	Pass	7.8 ft	Pass
Eddy State AST	Agustin Carmona	Weekly AST Inspection	7/16/2025	Pass	Pass	2.5	Pass	Pass	Pass	Pass	6.5	Pass
Eddy State AST	Jesus Chavez	Weekly AST Inspection	7/9/2025	Pass	Fail	2 ft	N/A	Pass	Fail	Pass	7.8 ft	Pass
Eddy State AST	Agustin Carmona	Weekly AST Inspection	7/2/2025	Pass	Pass	4	Pass	Pass	Pass	Pass	6	Pass
Eddy State AST	Jesus Chavez	Weekly AST Inspection	6/25/2025	Pass	Fail	2.5 ft	N/A	Pass	Fail	Pass	7.5 ft	Pass
Eddy State AST	Agustin Carmona	Weekly AST Inspection	6/18/2025	Pass	Pass	4	Pass	Pass	Pass	Pass	6	Pass
Eddy State AST	Jesus Chavez	Weekly AST Inspection	6/11/2025	Pass	Fail	3 ft	N/A	Pass	Fail	Pass	7 ft	Pass
Eddy State AST	Agustin Carmona	Weekly AST Inspection	6/4/2025	Pass	Pass	3	Pass	Pass	Pass	Pass	5	Pass
Eddy State AST	Jesus Chavez	Weekly AST Inspection	5/28/2025	Pass	Fail	4 ft	N/A	Pass	Fail	Pass	6 ft	Pass
Eddy State AST	Agustin Carmona	Weekly AST Inspection	5/21/2025	Pass	Pass	3.5	Pass	Pass	Pass	Pass	6.5	Pass
Eddy State AST	Jesus Chavez	Weekly AST Inspection	5/14/2025	Pass	Fail	4 ft		Pass	Fail	Pass	6 ft	Pass
Eddy State AST	Agustin Carmona	Weekly AST Inspection	5/7/2025	Pass	Pass	4	Pass	Pass	Pass	Pass	5	Pass
Eddy State AST	Jesus Chavez	Weekly AST Inspection	4/30/2025	Pass	Fail	4 ft	N/A	Pass	Fail	Pass	6 ft	Pass
Eddy State AST	Jesus Chavez	Weekly AST Inspection	4/23/2025	Pass	Fail	5 ft	N/A	Pass	Fail	Pass	5 ft	Pass
Eddy State AST	Jesus Chavez	Weekly AST Inspection	4/16/2025	Pass	Fail	4 ft	N/A	Pass	Fail	Pass	6 ft	Pass
Eddy State AST	CMMS Administrator	Weekly AST Inspection	4/9/2025	Pass	Fail	5 ft	N/A	Pass	Fail	Pass	5 ft	Pass
Eddy State AST	Jesus Chavez	Weekly AST Inspection	4/2/2025	Pass	Fail	3 ft	N/A	Pass	Fail	Pass	7 ft	Pass
Eddy State AST	CMMS Administrator	Weekly AST Inspection	3/26/2025	Pass	Fail	5 ft	N/A	Pass	Fail	Pass	5 ft	Pass
Eddy State AST	Jesus Chavez	Weekly AST Inspection	3/19/2025	Pass	Fail	4 ft	N/A	Pass	Fail	Pass	6 ft	Pass
Eddy State AST	CMMS Administrator	Weekly AST Inspection	3/12/2025	Pass	Fail	5 ft	N/A	Pass	Fail	Pass	5 ft	Pass

Eddy State AST	Jesus Chavez	Weekly AST Inspection	3/5/2025	Pass	Fail	3.5 ft	N/A	Pass	Fail	Pass	6 ft	Pass
Eddy State AST	CMMS Administrator	Weekly AST Inspection	2/26/2025	Pass	Fail	5ft	N/A	Pass	Fail	Pass	5 ft	Pass
Eddy State AST	Jesus Chavez	Weekly AST Inspection	2/19/2025	Pass	Fail	4ft	N/A	Pass	Fail	Pass	6 ft	Pass
Eddy State AST	CMMS Administrator	Weekly AST Inspection	2/12/2025	Pass	Fail	5 ft	N/A	Pass	Fail	Pass	5 ft	Pass
Eddy State AST	Jesus Chavez	Weekly AST Inspection	2/5/2025	Pass	Fail	3.5 ft	N/A	Pass	Fail	Pass	6ft	Pass
Eddy State AST	Agustin Carmona	Weekly AST Inspection	1/29/2025	Pass	Pass	12	Pass	Pass	Pass	Pass	6.5	Pass
Eddy State AST	Jesus Chavez	Weekly AST Inspection	1/22/2025	Pass	Fail	3 ft	N/A	Pass	Fail	Pass	6 ft	Pass
Eddy State AST	Agustin Carmona	Weekly AST Inspection	1/15/2025	Pass	Pass	12	Pass	Pass	Pass	Pass	6	Pass
Eddy State AST	Jesus Chavez	Weekly AST Inspection	1/8/2025	Pass	Fail	3ft	N/A	Pass	Fail	Pass	6ft	Pass
Eddy State AST	Agustin Carmona	Weekly AST Inspection	1/1/2025	Pass	Pass	12	Pass	Pass	Pass	Pass	9	Pass
Eddy State AST	Jesus Chavez	Weekly AST Inspection	12/25/2024	Pass	Fail	3 ft	N/A	Pass	Fail	Pass	6 ft	Pass
Eddy State AST	Agustin Carmona	Weekly AST Inspection	12/18/2024	Pass	Pass	12	Pass	Pass	Pass	Pass	6	Pass
Eddy State AST	Jesus Chavez	Weekly AST Inspection	12/11/2024	Pass	Fail	4 ft	N/A	Pass	Fail	Pass	5.11 ft	Pass
Eddy State AST	Jesus Tambunga	Weekly AST Inspection	12/4/2024	Pass	Pass	5	Pass	Pass	Pass	Pass	7	Pass
Eddy State AST	Jesus Chavez	Weekly AST Inspection	11/27/2024	Pass	Fail	4 ft	N/A	Pass	Pass	Pass	5.11 ft	Pass
Eddy State AST	Agustin Carmona	Weekly AST Inspection	11/20/2024	Pass	Pass	12	Pass	Pass	Pass	Pass	6	Pass
Eddy State AST	Jesus Chavez	Weekly AST Inspection	11/13/2024	Pass	Fail	10 ft	N/A	Pass	Fail	Pass	6.5 ft	Pass
Eddy State AST	Jesus Tambunga	Weekly AST Inspection	11/6/2024	Pass	Pass	4	Pass	Pass	Pass	Pass	8	Pass
Eddy State AST	Jesus Chavez	Weekly AST Inspection	10/30/2024	Pass	Fail	10 ft	N/A	Pass	Fail	Pass	6.5 ft	Pass
Eddy State AST	Agustin Carmona	Weekly AST Inspection	10/23/2024	Pass	Pass	12	Pass	Pass	Pass	Pass	6	Pass
Eddy State AST	Jesus Chavez	Weekly AST Inspection	10/16/2024	Pass	Fail	10 ft	N/A	Pass	Fail	Pass	6.5 ft	Pass
Eddy State AST	Jesus Tambunga	Weekly AST Inspection	10/9/2024	Pass	Pass	4	Pass	Pass	Pass	Pass	8	Pass
Eddy State AST	Jesus Chavez	Weekly AST Inspection	10/2/2024	Pass	Fail	10 ft	N/A	Pass	Fail	Pass	6.5 ft	Pass
Eddy State AST	Jesus Tambunga	Weekly AST Inspection	9/25/2024	Pass	Pass	4	Pass	Pass	Pass	Pass	8	Pass
Eddy State AST	Jesus Chavez	Weekly AST Inspection	9/18/2024	Pass	Fail	10 ft	N/A	Pass	Fail	Pass	6.10 ft	Pass
Eddy State AST	Agustin Carmona	Weekly AST Inspection	9/11/2024	Pass	Pass	12	Pass	Pass	Pass	Pass	6	Pass
Eddy State AST	Jesus Chavez	Weekly AST Inspection	9/4/2024	Pass	Fail	10 ft	N/A	Pass	Fail	Pass	7.3 ft	Pass
Eddy State AST	Agustin Carmona	Weekly AST Inspection	8/28/2024	Pass	Fail	12	Pass	Pass	Pass	Pass	8	Pass
Eddy State AST	Jesus Chavez	Weekly AST Inspection	8/21/2024	Pass	Fail	10 ft	N/A	Pass	Fail	Pass	7.8 ft	Pass
Eddy State AST	Agustin Carmona	Weekly AST Inspection	8/14/2024	Pass	Fail	12	Pass	Pass	Pass	Pass	7	Pass
Eddy State AST	Jesus Chavez	Weekly AST Inspection	8/7/2024	Pass	Fail	10 ft	N/A	Pass	Fail	Pass	7.8 ft	Pass
Eddy State AST	Bradley Webb	Weekly AST Inspection	7/31/2024	Pass	Pass	5	Pass	Pass	Pass	Pass	7	Pass
Eddy State AST	Jesus Chavez	Weekly AST Inspection	7/24/2024	Pass	Fail	10 ft	N/A	Pass	Fail	Pass	8 ft	Pass
Eddy State AST	Bradley Webb	Weekly AST Inspection	7/17/2024	Pass	Pass	5	Pass	Pass	Pass	Pass	7	Pass
Eddy State AST	Jesus Chavez	Weekly AST Inspection	7/10/2024	Pass	Fail	10	N/A	Pass	Fail	Pass	6.7	Pass
Eddy State AST	Jesus Chavez	Weekly AST Inspection	7/3/2024	Pass	Fail	10	N/A	Pass	Fail	Pass	6.9	Pass

Asset ID	Asset Description	Date Completed	Tear in Liner?	Break in	Run on storm	Any dead	Bird net secure	Oil on fluid?	Leak Detection functional?	Freeboard level	Pond level
				berm?	water?	wildlife?	or bird box functional?				
EDDY STATE AST	REUSE - AST	6/29/2024	Pass	Pass	Pass	Pass	Fail	Fail	Pass	10	14
EDDY STATE AST	REUSE - AST	6/15/2024	Pass	Pass	Pass	Pass	Fail	Fail	Pass	10	13.5
EDDY STATE AST	REUSE - AST	5/21/2024	Pass	Pass	Pass	Pass	Fail	Fail	Pass	10	14
EDDY STATE AST	REUSE - AST	5/5/2024	Pass	Pass	Pass	Pass	Fail	Fail	Pass	10	6.5
EDDY STATE AST	REUSE - AST	5/3/2024	Pass	Pass	Pass	Pass	Fail	Pass	Pass	10	7.6
EDDY STATE AST	REUSE - AST	3/19/2024	Pass	Pass	Pass	Pass	Fail	Pass	Pass	5	7

Pond or AST	Date	Operator Name	Tear in	Break in	Dead	Oil on fluid	Leak	Freeboard	Pond Level
			Liner	Berms and	Wildlife		Detection	Fluid Level	
			(Y/N)?	run-on	(Y/N)?	(Y/N)?	Working	(ft)	(ft)
Eddy State AST	3/22/2024	Jesus Chavez	FALSE	FALSE	FALSE	TRUE	TRUE	10	7.3
Eddy State AST	3/10/2024	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	6	6
Eddy State AST	3/7/2024	Jesus Chavez	FALSE	FALSE	FALSE	TRUE	TRUE	10	7.4
Eddy State AST	2/25/2024	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	6	6
Eddy State AST	2/23/2024	Jesus Chavez	FALSE	FALSE	FALSE	TRUE	TRUE	10	7.4
Eddy State AST	2/12/2024	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	6	6
Eddy State AST	2/11/2024	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	6	6
Eddy State AST	2/8/2024	Jesus Chavez	FALSE	FALSE	FALSE	TRUE	TRUE	10	7.3
Eddy State AST	1/28/2024	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	6	6
Eddy State AST	1/24/2024	Jesus Chavez	FALSE	FALSE	FALSE	FALSE	TRUE	10	7.2
Eddy State AST	1/24/2024	Jesus Chavez	FALSE	FALSE	FALSE	FALSE	TRUE	10	7.2
Eddy State AST	1/18/2024	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	6	6
Eddy State AST	1/11/2024	Jesus Chavez	FALSE	FALSE	FALSE	FALSE	TRUE	10	10
Eddy State AST	1/3/2024	Jesus Chavez	FALSE	FALSE	FALSE	FALSE	TRUE	10	10
Eddy State AST	12/30/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	6	6
Eddy State AST	12/26/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	2	10
Eddy State AST	12/20/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	2	10
Eddy State AST	12/14/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	2	10
Eddy State AST	12/8/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	2	10
Eddy State AST	12/2/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	2	10
Eddy State AST	11/28/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	2	10
Eddy State AST	11/22/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	2	10
Eddy State AST	11/20/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	2	10
Eddy State AST	11/14/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	2	10
Eddy State AST	11/8/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	2	10
Eddy State AST	11/2/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	2	10
Eddy State AST	10/27/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	2	10
Eddy State AST	10/22/2023	Samuel Cantu	FALSE	FALSE	FALSE	TRUE	TRUE	10	2
Eddy State AST	10/17/2023	Samuel Cantu	FALSE	FALSE	FALSE	TRUE	TRUE	2	10
Eddy State AST	10/8/2023	Samuel Cantu	FALSE	FALSE	FALSE	TRUE	TRUE	2	10
Eddy State AST	10/1/2023	Samuel Cantu	FALSE	FALSE	FALSE	TRUE	TRUE	2	10
Eddy State AST	9/24/2023	Samuel Cantu	FALSE	FALSE	FALSE	TRUE	TRUE	2	10
Eddy State AST	9/19/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	2	10
Eddy State AST	9/16/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	2	10
Eddy State AST	9/10/2023	Samuel Cantu	FALSE	FALSE	FALSE	TRUE	TRUE	2	10
Eddy State AST	9/3/2023	Samuel Cantu	FALSE	FALSE	FALSE	TRUE	TRUE	2	10
Eddy State AST	8/27/2023	Samuel Cantu	FALSE	FALSE	FALSE	TRUE	TRUE	2	10
Eddy State AST	8/20/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	2	10
Eddy State AST	8/14/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	2	10
Eddy State AST	8/8/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	2	10
Eddy State AST	8/2/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	2	10

Eddy State AST	7/26/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	2	10
Eddy State AST	7/20/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	10	2
Eddy State AST	7/14/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	2	10
Eddy State AST	7/8/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	2	10
Eddy State AST	7/2/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	2	10
Eddy State AST	6/26/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	2	10
Eddy State AST	6/20/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	2	10
Eddy State AST	6/14/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	2	10
Eddy State AST	6/8/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	2	10
Eddy State AST	6/4/2023	Samuel Cantu	FALSE	FALSE	FALSE	FALSE	TRUE	2	10
Eddy State AST	6/2/2023	Samuel Cantu	FALSE	FALSE	FALSE	FALSE	TRUE	2	10
Eddy State AST	5/21/2023	Samuel Cantu	FALSE	FALSE	FALSE	FALSE	TRUE	1	10
Eddy State AST	5/16/2023	Samuel Cantu	FALSE	FALSE	FALSE	FALSE	TRUE	1	10
Eddy State AST	5/9/2023	Samuel Cantu	FALSE	FALSE	FALSE	FALSE	TRUE	1	10
Eddy State AST	5/2/2023	Samuel Cantu	FALSE	FALSE	FALSE	FALSE	TRUE	1	10
Eddy State AST	4/24/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	3	9
Eddy State AST	4/21/2023	[Term] Bradley Webb	FALSE	FALSE	FALSE	FALSE	TRUE	3	9
Eddy State AST	4/14/2023	[Term] Bradley Webb	FALSE	FALSE	FALSE	FALSE	TRUE	3	9
Eddy State AST	4/7/2023	[Term] Bradley Webb	FALSE	FALSE	FALSE	FALSE	TRUE	3	9
Eddy State AST	3/31/2023	[Term] Bradley Webb	FALSE	FALSE	FALSE	FALSE	TRUE	3	9
Eddy State AST	3/20/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	7	5
Eddy State AST	3/17/2023	[Term] Bradley Webb	FALSE	FALSE	FALSE	FALSE	TRUE	5	7
Eddy State AST	3/9/2023	[Term] Bradley Webb	FALSE	FALSE	FALSE	FALSE	TRUE	4.6	7.6
Eddy State AST	3/2/2023	[Term] Bradley Webb	FALSE	FALSE	FALSE	FALSE	TRUE	4	8
Eddy State AST	2/24/2023	[Term] Bradley Webb	FALSE	FALSE	FALSE	TRUE	TRUE	3	9
Eddy State AST	2/12/2023	[Term] Bradley Webb	FALSE	FALSE	FALSE	FALSE	TRUE	4	8
Eddy State AST	2/6/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	4	8
Eddy State AST	1/31/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	4	8
Eddy State AST	1/25/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	4	8
Eddy State AST	1/20/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	5	7
Eddy State AST	1/14/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	5	7
Eddy State AST	1/8/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	5	7
Eddy State AST	1/4/2023	[Term] Bradley Webb	FALSE	FALSE	FALSE	FALSE	TRUE	5	7
Eddy State AST	12/13/2022	Ricardo Lara	FALSE	FALSE	FALSE	FALSE	TRUE	4	8
Eddy State AST	12/6/2022	Ricardo Lara	FALSE	FALSE	FALSE	TRUE	TRUE	2	10
Eddy State AST	11/23/2022	[Term] Bradley Webb	FALSE	FALSE	FALSE	FALSE	TRUE	3.6	8.6
Eddy State AST	11/9/2022	Ricardo Lara	FALSE	FALSE	FALSE	FALSE	TRUE	4.5	7.5
Eddy State AST	11/2/2022	Ricardo Lara	FALSE	FALSE	FALSE	FALSE	TRUE	4.5	7.5
Eddy State AST	10/20/2022	Ricardo Lara	FALSE	FALSE	FALSE	FALSE	TRUE	4.5	7.5
Eddy State AST	10/19/2022	Ricardo Lara	FALSE	FALSE	FALSE	FALSE	TRUE	4.5	7.5
Eddy State AST	10/12/2022	Ricardo Lara	FALSE	FALSE	FALSE	FALSE	TRUE	4.5	7.5
Eddy State AST	10/5/2022	Ricardo Lara	FALSE	FALSE	FALSE	FALSE	TRUE	4.5	7.5



December 8th, 2025

State of New Mexico
Energy, Minerals, and Natural Resources Department
Oil Conservation Division
1220 South St. Francis Dr.
Santa Fe, NM 87505

Re: 2RF-149 Solaris Water Midstream Eddy State Water Treatment and Reuse Facility C-147 Annual Extension

To Whom it May Concern,

Solaris Water Midstream, LLC. respectfully submits the enclosed C-147 form, summary of monthly inspections and leak detection for the Eddy State Water Treatment and Reuse Facility. For original site plans and submittals, please refer to the facility's original registration application, OCD Registration number 2RF-149, received November 2nd, 2020. In accordance with NMAC 19.15.34.10 RECYCLING CONTAINMENTS, Solaris Water Midstream wishes to seek a one-year extension to the facility. The annual extension dates requested will be from November 2nd, 2025, to November 2nd, 2026.

NMAC 19.15.34.10 RECYCLING CONTAINMENTS

C. Registered recycling containments may be operated for five years from the date on which the registration is filed with the division. The operator may extend the allowed time on an annual basis thereafter with division approval if, 30 days prior to the registration expiration, the operator files a form C-147 with an attached summary showing all monthly inspections at the containment, including the monitoring of the leak detection system, showing the containment's integrity has not been compromised.

Sincerely,

A handwritten signature in cursive script that reads "Chad Gallagher".

Chad Gallagher

Permitting Agent

State of New Mexico
Energy Minerals and Natural Resources
Department Oil Conservation Division
1220 South St. Francis Dr.
Santa Fe, NM 87505

Form C-147
Revised October 11, 2022

<https://www.emnrd.nm.gov/ocd/ocd-e-permitting/>

Recycling Facility and/or Recycling Containment

Type of Facility: ☒ Recycling Facility ☒ Recycling Containment*
Type of action: ☐ Permit ☐ Registration
 ☐ Modification ☒ Extension
 ☐ Closure ☒ Other (explain) Annual Extension

*** At the time C-147 is submitted to the division for a Recycling Containment, a copy shall be provided to the surface owner.**

Be advised that approval of this request does not relieve the operator of liability should operations result in pollution of surface water, ground water or the environment. Nor does approval relieve the operator of its responsibility to comply with any other applicable governmental authority's rules, regulations or ordinances.

1.
 Operator: Solaris Water Midstream, LLC (For multiple operators attach page with information) OGRID #: 371643
 Address: 9651 Katy Fwy, Suite 400, Houston Texas 77024
 Facility or well name (include API# if associated with a well): Eddy State Water Treatment and Reuse Facility
 OCD Permit Number: 2RF-149 (For new facilities the permit number will be assigned by the district office)
 U/L or Qtr/Qtr K Section 2 Township 26S Range 29E County: Eddy
 Surface Owner: ☐ Federal ☒ State ☐ Private ☐ Tribal Trust or Indian Allotment

2.
☒ **Recycling Facility:**
 Location of recycling facility (if applicable): Latitude 32.07058° Longitude -103.95627° NAD83
 Proposed Use: ☒ Drilling* ☒ Completion* ☒ Production* ☒ Plugging *
**The re-use of produced water may NOT be used until fresh water zones are cased and cemented*
☐ Other, *requires permit for other uses. Describe use, process, testing, volume of produced water and ensure there will be no adverse impact on groundwater or surface water.*
☒ Fluid Storage
 ☒ Above ground tanks ☒ Recycling containment ☐ Activity permitted under 19.15.17 NMAC explain type _____
 ☐ Activity permitted under 19.15.36 NMAC explain type: _____ ☐ Other explain _____
 ☐ For multiple or additional recycling containments, attach design and location information of each containment
☐ **Closure Report (required within 60 days of closure completion):** ☐ Recycling Facility Closure Completion Date: _____

3.
☒ **Recycling Containment:**
☒ Annual Extension after initial 5 years (attach summary of monthly leak detection inspections for previous year)
 Center of Recycling Containment (if applicable): Latitude 32.071540 Longitude -103.958919° NAD83
☐ For multiple or additional recycling containments, attach design and location information of each containment
☒ Lined ☐ Liner type: Thickness secondary 40 mil ☐ LLDPE ☐ HDPE ☐ PVC ☐ Other Primary 60-mil
☐ String-Reinforced
 Liner Seams: ☒ Welded ☐ Factory ☐ Other _____ Volume: 1,150,000 bbl Dimensions: L _____ x W _____ x D _____ please see attachment
☐ Recycling Containment Closure Completion Date: _____

4.

Bonding:

- ☐ Covered under bonding pursuant to 19.15.8 NMAC per 19.15.34.15(A)(2) NMAC (These containments are limited to only the wells owned or operated by the owners of the containment.)
- ☒ Bonding in accordance with 19.15.34.15(A)(1). Amount of bond \$ _____ (work on these facilities cannot commence until bonding amounts are approved)
- ☐ Attach closure cost estimate and documentation on how the closure cost was calculated.

5.

Fencing:

- ☐ Four foot height, four strands of barbed wire evenly spaced between one and four feet
- ☒ Alternate. Please specify See Variance

6.

Signs:

- ☐ 12"x 24", 2" lettering, providing Operator's name, site location, and emergency telephone numbers
- ☒ Signed in compliance with 19.15.16.8 NMAC

7.

Variances:

Justifications and/or demonstrations that the proposed variance will afford reasonable protection against contamination of fresh water, human health, and the environment.

Check the below box only if a variance is requested:

☒ Variance(s): Requests must be submitted to the appropriate division district for consideration of approval. If a Variance is requested, include the variance information on a separate page and attach it to the C-147 as part of the application.

If a Variance is requested, it must be approved prior to implementation.

8.

Siting Criteria for Recycling Containment

Instructions: The applicant must provide attachments that demonstrate compliance for each siting criteria below as part of the application. Potential examples of the siting attachment source material are provided below under each criteria.

General siting**Ground water is less than 50 feet below the bottom of the Recycling Containment.**

NM Office of the State Engineer - iWATERS database search; USGS; Data obtained from nearby wells

☐ Yes ☒ No
☐ NA

Within incorporated municipal boundaries or within a defined municipal fresh water well field covered under a municipal ordinance adopted pursuant to NMSA 1978, Section 3-27-3, as amended.

☐ Yes ☒ No
☐ NA

- Written confirmation or verification from the municipality; written approval obtained from the municipality

Within the area overlying a subsurface mine.

☐ Yes ☒ No

- Written confirmation or verification or map from the NM EMNRD-Mining and Minerals Division

Within an unstable area.

☐ Yes ☒ No

- Engineering measures incorporated into the design; NM Bureau of Geology & Mineral Resources; USGS; NM Geological Society; topographic map

Within a 100-year floodplain. FEMA map

☐ Yes ☒ No

Within 300 feet of a continuously flowing watercourse, or 200 feet of any other significant watercourse, or lakebed, sinkhole, or playa lake (measured from the ordinary high-water mark).

☐ Yes ☒ No

- Topographic map; visual inspection (certification) of the proposed site

Within 1000 feet from a permanent residence, school, hospital, institution, or church in existence at the time of initial application.

☐ Yes ☒ No

- Visual inspection (certification) of the proposed site; aerial photo; satellite image

Within 500 horizontal feet of a spring or a fresh water well used for domestic or stock watering purposes, in existence at the time of initial application.

☐ Yes ☒ No

- NM Office of the State Engineer - iWATERS database search; visual inspection (certification) of the proposed site

Within 500 feet of a wetland.

☐ Yes ☐ No

- US Fish and Wildlife Wetland Identification map; topographic map; visual inspection (certification) of the proposed site

9.

Recycling Facility and/or Containment Checklist:

Instructions: Each of the following items must be attached to the application. Indicate, by a check mark in the box, that the documents are attached.

- ☒ Design Plan - based upon the appropriate requirements.
- ☒ Operating and Maintenance Plan - based upon the appropriate requirements.
- ☒ Closure Plan - based upon the appropriate requirements.
- ☒ Site Specific Groundwater Data -
- ☒ Siting Criteria Compliance Demonstrations -
- ☒ Certify that notice of the C-147 (only) has been sent to the surface owner(s)

10.

Operator Application Certification:

I hereby certify that the information and attachments submitted with this application are true, accurate and complete to the best of my knowledge and belief.

Name (Print): Chad Gallagher Title: Permit Agent
Signature: Chad Gallagher Date: 12/8/2025
e-mail address: chad.gallagher@ariswater.com Telephone: (575)444-9786

11.

OCD Representative Signature: Victoria Venegas Approval Date: 12/17/2025

Title: Environmental Specialist OCD Permit Number: 2RF-149

- ☒ OCD Conditions _____
- ☒ Additional OCD Conditions on Attachment _____

Asset Name	User Full Name	Date	Berm - Are there any breaks in the berm?	Bird Box - Is the bird box functional?	Freeboard Level - List the Freeboard level (in feet).	Leak Detection - Is the Leak Detection functional?	Liner - Is there a tear in the liner?	Oil - Is there any oil on fluid?	Pond Level - List the Pond level (in feet).	Storm Water - Is there any run-on storm water?	Wildlife - Is there any dead wildlife?
Eddy State Large Pond	Agustin Carmona	12/3/2025	No	Yes	1	Yes	No	No	14	No	No
Eddy State Large Pond	Jesus Chavez	11/26/2025	No	No	2 ft	Yes	No	No	13 ft	No	No
Eddy State Large Pond	Agustin Carmona	11/19/2025	No	Yes	1	Yes	No	No	14	No	No
Eddy State Large Pond	Jesus Chavez	11/12/2025	No	No	2 ft	Yes	No	No	13 ft	No	No
Eddy State Large Pond	Agustin Carmona	11/5/2025	No	Yes	1	Yes	No	No	14	No	No
Eddy State Large Pond	Jesus Chavez	10/29/2025	No	No	1 ft	Yes	No	No	14 ft	No	No
Eddy State Large Pond	Agustin Carmona	10/22/2025	No	Yes	2	Yes	No	No	14	No	No
Eddy State Large Pond	Jesus Chavez	10/15/2025	No	No	1 ft	Yes	No	No	14 ft	No	No
Eddy State Large Pond	Agustin Carmona	10/8/2025	No	Yes	1	Yes	No	No	14	No	No
Eddy State Large Pond	Jesus Chavez	10/1/2025	No	Yes	1 ft	Yes	No	No	14 ft	No	No
Eddy State Large Pond	Agustin Carmona	9/24/2025	No	Yes	0	Yes	No	No	15	No	No
Eddy State Large Pond	Jesus Chavez	9/17/2025	No	No	2 ft	Yes	No	No	13 ft	No	No
Eddy State Large Pond	Agustin Carmona	9/10/2025	No	Yes	6	Yes	No	No	5	No	No
Eddy State Large Pond	Jesus Chavez	9/3/2025	No	No	7 ft	Yes	No	No	8 ft	No	No
Eddy State Large Pond	Agustin Carmona	8/27/2025	No	Yes	7	Yes	No	No	8	No	No
Eddy State Large Pond	Jesus Chavez	8/20/2025	No	No	6.5 ft	Yes	No	No	8.6 ft	No	No
Eddy State Large Pond	Agustin Carmona	8/13/2025	No	Yes	9	Yes	No	No	9	No	No
Eddy State Large Pond	Jesus Chavez	8/6/2025	No	No	6.6 ft	Yes	No	No	8.6 ft	No	No
Eddy State Large Pond	Agustin Carmona	7/30/2025	No	Yes	7	Yes	No	No	8	No	No
Eddy State Large Pond	Jesus Chavez	7/23/2025	No	No	6 ft	No	No	No	8.5 ft	No	No
Eddy State Large Pond	Agustin Carmona	7/16/2025	No	No	7	No	No	No	8	No	No
Eddy State Large Pond	Jesus Chavez	7/9/2025	No	No	6 ft	Yes	No	No	8.6 ft	No	No
Eddy State Large Pond	Agustin Carmona	7/2/2025	No	Yes	7	Yes	No	No	8	No	No
Eddy State Large Pond	Jesus Chavez	6/25/2025	No	No	6 ft	Yes	No	No	8.5 ft	No	No
Eddy State Large Pond	Agustin Carmona	6/18/2025	No	Yes	7	Yes	No	No	8	No	No
Eddy State Large Pond	Jesus Chavez	6/11/2025	No	No	6.5 ft	Yes	No	No	8.5 ft	No	No
Eddy State Large Pond	Agustin Carmona	6/4/2025	No	Yes	7	Yes	No	No	8	No	No
Eddy State Large Pond	Jesus Chavez	5/28/2025	No	No	7 ft	Yes	No	No	8 ft	No	No
Eddy State Large Pond	Agustin Carmona	5/21/2025	No	Yes	5	Yes	No	No	8	No	No
Eddy State Large Pond	Jesus Chavez	5/14/2025	No	No	6 ft	Yes	No	No	9 ft	No	No
Eddy State Large Pond	Agustin Carmona	5/7/2025	No	Yes	9	Yes	No	No	7	No	No
Eddy State Large Pond	Jesus Chavez	4/30/2025	No	No	6 ft	Yes	No	Yes	9 ft	No	No
Eddy State Large Pond	Jesus Chavez	4/23/2025	No	No	6 ft	Yes	No	Yes	9 ft	No	No
Eddy State Large Pond	Jesus Chavez	4/16/2025	No	No	6 ft	Yes	No	Yes	9 ft	No	No
Eddy State Large Pond	CMMS Administrator	4/9/2025	No	No	5 ft	Yes	No	Yes	10 ft	No	No
Eddy State Large Pond	Jesus Chavez	4/2/2025	No	No	7 ft	Yes	No	Yes	8 ft	No	No
Eddy State Large Pond	CMMS Administrator	3/26/2025	No	No	5 ft	Yes	No	Yes	10 ft	No	No
Eddy State Large Pond	Jesus Chavez	3/19/2025	No	No	8 ft	Yes	No	Yes	7 ft	No	No
Eddy State Large Pond	CMMS Administrator	3/12/2025	No	No	5 ft	Yes	No	Yes	10 ft	No	No

Eddy State Large Pond	Jesus Chavez	3/5/2025	No	No	8 ft	Yes	No	Yes	7 ft	No	No
Eddy State Large Pond	Agustin Carmona	2/26/2025	No	Yes	18	Yes	No	No	7	No	No
Eddy State Large Pond	Jesus Chavez	2/19/2025	No	No	8 ft	Yes	No	Yes	7 ft	No	No
Eddy State Large Pond	Agustin Carmona	2/12/2025	No	Yes	18	Yes	No	No	7	No	No
Eddy State Large Pond	Jesus Chavez	2/5/2025	No	No	8 ft	Yes	No	Yes	7 ft	No	No
Eddy State Large Pond	Agustin Carmona	1/29/2025	No	Yes	16	Yes	No	No	8	No	No
Eddy State Large Pond	Jesus Chavez	1/22/2025	No	No	8 ft	Yes	No	Yes	7 ft	No	No
Eddy State Large Pond	Agustin Carmona	1/15/2025	No	Yes	18	Yes	No	No	6	No	No
Eddy State Large Pond	Jesus Chavez	1/8/2025	No	No	8ft	Yes	No	Yes	7ft	No	No
Eddy State Large Pond	Agustin Carmona	1/1/2025	No	Yes	18	Yes	No	No	7	No	No
Eddy State Large Pond	Jesus Chavez	12/25/2024	No	No		Yes	No	Yes		No	No
Eddy State Large Pond	Agustin Carmona	12/18/2024	No	Yes	18	Yes	No	No	8	No	No
Eddy State Large Pond	Jesus Chavez	12/11/2024	No	No	8ft	Yes	No	Yes	7ft	No	No
Eddy State Large Pond	Agustin Carmona	12/4/2024	No	Yes	18	Yes	No	No	8	No	No
Eddy State Large Pond	Jesus Chavez	11/27/2024	No	No	8 ft	Yes	No	Yes	7 ft	No	No
Eddy State Large Pond	Agustin Carmona	11/20/2024	No	Yes	18	Yes	No	No	10	No	No
Eddy State Large Pond	Jesus Chavez	11/13/2024	No	No	15 ft	Yes	No	Yes	7 ft	No	No
Eddy State Large Pond	Agustin Carmona	11/6/2024		Yes	18	Yes		No	8	No	No
Eddy State Large Pond	Jesus Chavez	10/30/2024	No	No	15 ft	Yes	No	Yes	7 ft	No	No
Eddy State Large Pond	Agustin Carmona	10/23/2024		Yes	18	Yes		No	7	No	No
Eddy State Large Pond	Jesus Chavez	10/16/2024	No	No	15 ft	Yes	No	Yes	7 ft	No	No
Eddy State Large Pond	Agustin Carmona	10/9/2024	No	Yes	18	Yes	No	No	8	No	No
Eddy State Large Pond	Jesus Chavez	10/2/2024	No	No	15 ft	Yes	No	Yes	7 ft	No	No
Eddy State Large Pond	Agustin Carmona	9/25/2024	No	Yes		Yes	No	No	7.5	No	No
Eddy State Large Pond	Jesus Chavez	9/18/2024	No	No	15 ft	Yes	No	Yes	7.1 ft	No	No
Eddy State Large Pond	Agustin Carmona	9/11/2024	No	Yes	18	Yes	No	No	7'5	No	No
Eddy State Large Pond	Jesus Chavez	9/4/2024	No	No	15 ft	Yes	No	Yes	14 ft	No	No
Eddy State Large Pond	Agustin Carmona	8/28/2024	No	Yes	3	Yes	No	No	15	No	No
Eddy State Large Pond	Jesus Chavez	8/21/2024	No	Yes	15 ft	Yes	No	Yes	14.10 ft	No	No
Eddy State Large Pond	Agustin Carmona	8/14/2024	No	Yes	18	Yes	No	No	15	No	No
Eddy State Large Pond	Jesus Chavez	8/7/2024	No	No	15 ft	Yes	No	Yes	14.2 ft	No	No
Eddy State Large Pond	Agustin Carmona	7/31/2024	No	Yes	2	Yes	No	No	13	No	No
Eddy State Large Pond	Jesus Chavez	7/24/2024	No	No	15 ft	Yes	No	Yes	7.11 ft	No	No
Eddy State Large Pond	Agustin Carmona	7/17/2024	No	Yes	5	Yes	No	No	10	No	No
Eddy State Large Pond	Jesus Chavez	7/10/2024	No	No	15	Yes	No	Yes	10	No	No
Eddy State Large Pond	Bradley Webb	7/3/2024	No	No	15	Yes	No	Yes	13.2	No	No

Asset ID	Asset Description	Date Completed	Tear in Liner?	Break in	Run on storm	Any dead	Bird net secure	Oil on fluid?	Leak Detection functional?	Freeboard level	Pond level
				berm?	water?	wildlife?	or bird box functional?				
EDDY STATE (LARGE)	REUSE - POND	6/29/2024	Pass	Pass	Pass	Pass	Fail	Fail	Pass	15	14
EDDY STATE (LARGE)	REUSE - POND	6/15/2024	Pass	Pass	Pass	Pass	Fail	Pass	Pass	15	13.5
EDDY STATE (LARGE)	REUSE - POND	6/12/2024	Pass	Pass	Pass	Pass	Fail	Pass	Pass	15	13.5
EDDY STATE (LARGE)	REUSE - POND	5/21/2024	Pass	Pass	Pass	Pass	Fail	Fail	Pass	14	14
EDDY STATE (LARGE)	REUSE - POND	5/5/2024	Pass	Pass	Pass	Pass	Pass	Pass	Pass	15	9
EDDY STATE (LARGE)	REUSE - POND	3/19/2024	Pass	Pass	Pass	Pass	Pass	Pass	Pass	12	6

Pond or AST	Date	Operator Name	Berms and				Leak		Freeboard Fluid Level (ft)	Pond Level (ft)
			Tear in Liner (Y/N)?	run-on storm water	Dead Wildlife (Y/N)?	Oil on fluid (Y/N)?	Detection Working (Y/N)?			
Eddy State (Big pond)	3/22/2024	Jesus Chavez	FALSE	FALSE	FALSE	FALSE	TRUE	15	6	
Eddy State (Big pond)	3/10/2024	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	4	11	
Eddy State (Big pond)	3/7/2024	Jesus Chavez	FALSE	FALSE	FALSE	TRUE	TRUE	15	6	
Eddy State (Big pond)	2/25/2024	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	15	6	
Eddy State (Big pond)	2/23/2024	Jesus Chavez	FALSE	FALSE	FALSE	TRUE	TRUE	15	6	
Eddy State (Big pond)	2/11/2024	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	15	6	
Eddy State (Big pond)	2/8/2024	Jesus Chavez	FALSE	FALSE	FALSE	TRUE	TRUE	15	7.5	
Eddy State (Big pond)	1/29/2024	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	15	7	
Eddy State (Big pond)	1/24/2024	Jesus Chavez	FALSE	FALSE	FALSE	FALSE	TRUE	15	7	
Eddy State (Big pond)	1/18/2024	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	14.6	3.6	
Eddy State (Big pond)	1/11/2024	Jesus Chavez	FALSE	FALSE	FALSE	TRUE	TRUE	15	3	
Eddy State (Big pond)	1/5/2024	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	15	3	
Eddy State (Big pond)	1/2/2024	Jesus Chavez	FALSE	FALSE	FALSE	TRUE	TRUE	15	3	
Eddy State (Big pond)	12/31/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	12	3	
Eddy State (Big pond)	12/24/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	12	3	
Eddy State (Big pond)	12/20/2023	Agustin Carmona	FALSE	FALSE	FALSE	TRUE	TRUE	12	3	
Eddy State (Big pond)	12/14/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	10	5	
Eddy State (Big pond)	12/8/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	10	5	
Eddy State (Big pond)	12/2/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	10	5	
Eddy State (Big pond)	11/26/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	10	5	
Eddy State (Big pond)	11/20/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	10	5	
Eddy State (Big pond)	11/14/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	10	5	
Eddy State (Big pond)	11/8/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	10	5	
Eddy State (Big pond)	11/2/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	10	5	
Eddy State (Big pond)	10/27/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	10	5	
Eddy State (Big pond)	10/22/2023	Samuel Cantu	FALSE	FALSE	FALSE	TRUE	TRUE	10	5	
Eddy State (Big pond)	10/15/2023	Samuel Cantu	FALSE	FALSE	FALSE	TRUE	TRUE	10	5	
Eddy State (Big pond)	10/8/2023	Samuel Cantu	FALSE	FALSE	FALSE	TRUE	TRUE	10	5	
Eddy State (Big pond)	10/1/2023	Samuel Cantu	FALSE	FALSE	FALSE	TRUE	TRUE	10	5	
Eddy State (Big pond)	9/24/2023	Samuel Cantu	FALSE	FALSE	FALSE	TRUE	TRUE	10	5	
Eddy State (Big pond)	9/19/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	10	5	
Eddy State (Big pond)	9/17/2023	Samuel Cantu	FALSE	FALSE	FALSE	TRUE	TRUE	10	5	
Eddy State (Big pond)	9/10/2023	Samuel Cantu	FALSE	FALSE	FALSE	TRUE	TRUE	10	5	
Eddy State (Big pond)	9/3/2023	Samuel Cantu	FALSE	FALSE	FALSE	TRUE	TRUE	10	5	
Eddy State (Big pond)	8/27/2023	Samuel Cantu	FALSE	FALSE	FALSE	TRUE	TRUE	10	5	
Eddy State (Big pond)	8/20/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	10	5	
Eddy State (Big pond)	8/13/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	10	5	
Eddy State (Big pond)	8/6/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	10	5	
Eddy State (Big pond)	7/30/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	9	6	
Eddy State (Big pond)	7/23/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	9	6	

Eddy State (Big pond)	7/16/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	9	6
Eddy State (Big pond)	7/9/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	9	6
Eddy State (Big pond)	7/2/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	9	6
Eddy State (Big pond)	6/27/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	6	9
Eddy State (Big pond)	6/20/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	9	6
Eddy State (Big pond)	6/14/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	9	6
Eddy State (Big pond)	6/8/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	9	6
Eddy State (Big pond)	6/4/2023	Samuel Cantu	FALSE	FALSE	FALSE	FALSE	TRUE	9	6
Eddy State (Big pond)	6/2/2023	Samuel Cantu	FALSE	FALSE	FALSE	FALSE	TRUE	9	6
Eddy State (Big pond)	5/26/2023	Jesus Tambunga	FALSE	FALSE	FALSE	FALSE	TRUE	12	5.11
Eddy State (Big pond)	5/26/2023	Jesus Tambunga	FALSE	FALSE	FALSE	FALSE	TRUE	12	5.11
Eddy State (Big pond)	5/26/2023	Jesus Tambunga	FALSE	FALSE	FALSE	FALSE	TRUE	12	6
Eddy State (Big pond)	5/21/2023	Samuel Cantu	FALSE	FALSE	FALSE	TRUE	TRUE	9	6
Eddy State (Big pond)	5/16/2023	Samuel Cantu	FALSE	FALSE	FALSE	TRUE	TRUE	9	6
Eddy State (Big pond)	5/9/2023	Samuel Cantu	FALSE	FALSE	FALSE	TRUE	TRUE	9	6
Eddy State (Big pond)	5/2/2023	Samuel Cantu	FALSE	FALSE	FALSE	FALSE	TRUE	9	6
Eddy State (Big pond)	4/25/2023	Jesus Tambunga	FALSE	FALSE	FALSE	FALSE	TRUE	11.5	6.5
Eddy State (Big pond)	4/21/2023	[Term] Bradley Webb	FALSE	FALSE	FALSE	FALSE	TRUE	8	7
Eddy State (Big pond)	4/14/2023	[Term] Bradley Webb	FALSE	FALSE	FALSE	FALSE	TRUE	8	7
Eddy State (Big pond)	4/7/2023	[Term] Bradley Webb	FALSE	FALSE	FALSE	FALSE	TRUE	8	7
Eddy State (Big pond)	4/1/2023	Jesus Tambunga	FALSE	FALSE	FALSE	TRUE	TRUE	11	7
Eddy State (Big pond)	3/21/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	6	9
Eddy State (Big pond)	3/17/2023	[Term] Bradley Webb	FALSE	FALSE	FALSE	FALSE	TRUE	4	11
Eddy State (Big pond)	3/9/2023	[Term] Bradley Webb	FALSE	FALSE	FALSE	TRUE	TRUE	4	11
Eddy State (Big pond)	3/2/2023	[Term] Bradley Webb	FALSE	FALSE	FALSE	TRUE	TRUE	4	11
Eddy State (Big pond)	2/26/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	4	11
Eddy State (Big pond)	2/24/2023	[Term] Bradley Webb	FALSE	FALSE	FALSE	TRUE	TRUE	4	11
Eddy State (Big pond)	2/13/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	7	8
Eddy State (Big pond)	2/12/2023	[Term] Bradley Webb	FALSE	FALSE	FALSE	FALSE	TRUE	7	8
Eddy State (Big pond)	2/6/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	7	8
Eddy State (Big pond)	2/2/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	7	8
Eddy State (Big pond)	1/27/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	6	9
Eddy State (Big pond)	1/21/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	5	10
Eddy State (Big pond)	1/15/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	4	11
Eddy State (Big pond)	1/10/2023	Agustin Carmona	FALSE	FALSE	FALSE	FALSE	TRUE	3	12
Eddy State (Big pond)	1/4/2023	[Term] Bradley Webb	FALSE	FALSE	FALSE	FALSE	TRUE	3	12
Eddy State (Big pond)	12/13/2022	Ricardo Lara	FALSE	FALSE	FALSE	FALSE	TRUE	3	14
Eddy State (Big pond)	12/6/2022	Ricardo Lara	FALSE	FALSE	FALSE	FALSE	TRUE	5	13
Eddy State (Big pond)	11/23/2022	[Term] Bradley Webb	FALSE	FALSE	FALSE	FALSE	TRUE	2	13
Eddy State (Big pond)	11/7/2022	[Term] Bradley Webb	FALSE	FALSE	FALSE	FALSE	TRUE	2	13
Eddy State (Big pond)	10/21/2022	[Term] Bradley Webb	FALSE	FALSE	FALSE	FALSE	TRUE	2	13

Venegas, Victoria, EMNRD

From: Venegas, Victoria, EMNRD
Sent: Wednesday, December 17, 2025 8:33 AM
To: chad.gallagher@ariswater.com
Subject: 2RF-149 - EDDY STATE WATER TREATMENT AND REUSE FACILITY ID [FVV2105730365]
Attachments: C-147 2RF-149 - EDDY STATE WATER TREATMENT AND REUSE FACILITY ID [FVV2105730365].pdf

2RF-149 - EDDY STATE WATER TREATMENT AND REUSE FACILITY ID [FVV2105730365]

Good morning Mr. Gallagher.

NMOCD has reviewed the annual registration /permit extension request for 2RF-149 - EDDY STATE WATER TREATMENT AND REUSE FACILITY ID [FVV2105730365], received from [371643] SOLARIS WATER MIDSTREAM, LLC on 12/16/2025, Application ID **535406**. The registration/permit extension request is approved with the following conditions of approval.

- 2RF-149 - EDDY STATE WATER TREATMENT AND REUSE FACILITY ID [FVV2105730365] is approved for one (1) year of operation from the date of the previous registration/permit expiration date of 11/02/2025. The new registration/permit expiration date is 11/02/2026.
- [371643] SOLARIS WATER MIDSTREAM, LLC will continue to operate, maintain, and close the for 2RF-2RF-149 - EDDY STATE WATER TREATMENT AND REUSE FACILITY ID [FVV2105730365] in compliance with 19.15.34 NMAC, to include but not limited to the performance of weekly inspections regardless of fluid levels in the containment; recording of detailed inspection reports; removal of debris, foreign objects and oil from the containment; and monthly reporting of recycling and reuse of produced water, drilling fluids, and liquid oil field waste via from C-148.
- [371643] SOLARIS WATER MIDSTREAM, LLC will maintain a liquid level in the containment that is at least equal to the weight of the liner plus 20%. [371643] SOLARIS WATER MIDSTREAM, LLC may maintain a higher liquid level if they choose.
- If less than 20% of the total fluid capacity is utilized every consecutive six months, operation of the facility is considered ceased and a notification of cessation of operations should be sent electronically through OCD Permitting. An extension to extend the cessation of operations, not to exceed six months, may be submitted using a C-147 form through the OCD Permitting.
- If after that 6-month extension period, the containment is not utilized at a minimum of 20% fluid capacity, no additional extensions would be granted, and the operator would be directed to remove all fluids and proceed with the closure requirements.
- The recycling containment is bonded pursuant to 19.15.8 NMAC per 19.15.34.15(A)(2) NMAC. Water reused and recycled from 2RF-149 - EDDY STATE WATER TREATMENT AND REUSE FACILITY ID [FVV2105730365] is limited to wells owned or operated by [371643] SOLARIS WATER MIDSTREAM, LLC.
- A minimum of 3-feet freeboard must be maintained in the recycling containment at all times.
- [371643] SOLARIS WATER MIDSTREAM, LLC will comply with 19.15.29 NMAC Releases in the event of any release of produced water or produced water or other oil field wastes at for 2RF-149 - EDDY STATE WATER TREATMENT AND REUSE FACILITY ID [FVV2105730365]. [371643] SOLARIS WATER MIDSTREAM, LLC will comply with all other OCD rules.
- [371643] SOLARIS WATER MIDSTREAM, LLC must perform weekly inspections of the containment and leak detection system.
- If [371643] SOLARIS WATER MIDSTREAM, LLC wishes to extend the registration/permit past 11/02/2026, a registration/permit extension request must be submitted to OCD. Extension requests are reviewed on a case-by-case basis and evaluated on their merit. Extensions are considered for a maximum length of one year. Additional requests must be submitted to OCD through OCD Online on Form C-147 as an Extension

request and should include a formal extension request letter, a summary of the prior registration/permit period inspection reports, and the copies of the detailed inspection records for the prior permit period. The extension request should be submitted no later than 10/02/2026.

Please let me know if you have any additional questions.
Regards,

Victoria Venegas • Senior Environmental Scientist
EMNRD - Oil Conservation Division
506 W. Texas Ave. Artesia, NM 88210
575.909.0269 | Victoria.Venegas@emnrd.nm.gov

Sante Fe Main Office
Phone: (505) 476-3441

General Information
Phone: (505) 629-6116

Online Phone Directory
<https://www.emnrd.nm.gov/oed/contact-us>

State of New Mexico
Energy, Minerals and Natural Resources
Oil Conservation Division
1220 S. St Francis Dr.
Santa Fe, NM 87505

CONDITIONS

Action 535406

CONDITIONS

Operator: SOLARIS WATER MIDSTREAM, LLC 9950 WOODLOCH FOREST DR THE WOODLANDS, TX 77380	OGRID: 371643
	Action Number: 535406
	Action Type: [C-147] Water Recycle Long (C-147L)

CONDITIONS

Created By	Condition	Condition Date
venegas	2RF-149 - EDDY STATE WATER TREATMENT AND REUSE FACILITY ID [FVV2105730365] is approved for one (1) year of operation from the date of the previous registration/permit expiration date of 11/02/2025. The new registration/permit expiration date is 11/02/2026. If [371643] SOLARIS WATER MIDSTREAM, LLC wishes to extend the registration/permit past 11/02/2026, a registration/permit extension request must be submitted to OCD no later than 10/02/2026.	12/17/2025