

State Of New Mexico
Energy, Minerals and Natural Resources Department

27-Sep-24

CHEVRON U S A INC

6301 Deauville Blvd
Midland, TX 79706

Pre Enforcement Notification

Dear Operator:

The following inspection indicates that the well, equipment, location or operational status of the well failed to meet standards of the New Mexico Oil Conservation Division as described in the detail section below. To comply with standards imposed by Rules and Regulations of the Division, corrective action must be taken immediately and the situation brought into compliance. The detail section indicates preliminary findings and/or probable nature of the violation. This determination is based on an inspection of your well or facility by an inspector employed by the Oil Conservation Division on the date indicated.

Please notify the Compliance Officer copied on this letter, in writing, of the date corrective actions are scheduled to be made so that arrangements can be made to reinspect the well and/or facility.

INSPECTION DETAIL SECTION

[30-015-26766] PMS 8 FEDERAL #006

OGRID: 4323

F-08-18S-31E 1930 FNL 2032 FWL

Inspection Date	Type Inspection	Inspector	Inspection No.
9/26/2024	Routine Inspection	[TZM] Timothy Martin	iTZM2427031961
Violation	Title		Corrective Action Due
cTZM2427145882	19.15.10.8 Safety Procedures for Drilling and Production Fire Hazard		12/25/2024
	(Weeds and vegetation near ignition and electrical sources . Potential fire hazard in tank battery, and heater area)		

In the event that a satisfactory response is not received to this letter of direction by the "Corrective Action Due By:" date shown above, further enforcement will occur. Such enforcement may include this office applying to the Division for an order summoning you to a hearing before a Division Examiner in Santa Fe to show cause why you should not be ordered to permanently plug and abandon this well.

Note: Information in Detail Section comes directly from field inspector data entries - not all blanks will contain data.

Oil Conservation Division * 506 W. Texas Ave. * Artesia, NM 88210
Phone: 575-748-1283 * Fax: 575-748-9720 * www.emnrd.nm.gov