

District I
1625 N. French Dr., Hobbs, NM 88240
District II
811 S. First St., Artesia, NM 88210
District III
1000 Rio Brazos Road, Aztec, NM 87410
District IV
1220 S. St. Francis Dr., Santa Fe, NM 87505

State of New Mexico
Energy Minerals and Natural Resources
Oil Conservation Division
1220 South St. Francis Dr.
Santa Fe, NM 87505

MAY 22 2018

Form C-141
Revised April 3, 2017

Submit 1 Copy to appropriate District Office in accordance with 19.15.29 NMAC.
DISTRICT II-ARTESIA O.C.D.

FAB1814336306
NAB1814336863

Release Notification and Corrective Action

OPERATOR

Initial Report Final Report

Name of Company DCP Midstream <i>310785</i>	Contact: Nicholas L. Case
Address: 5301 Sierra Vista Drive Carlsbad NM 88220	Telephone No. 575-802-5225
Facility Name Dagger Draw Booster	Facility Type Gas Gathering compression/ Booster

Surface Owner	Mineral Owner	API No.
---------------	---------------	---------

LOCATION OF RELEASE

Unit Letter	Section 36	Township 19S	Range 24E	Feet from the	North/South Line	Feet from the	East/West Line	County: Eddy
-------------	---------------	-----------------	--------------	---------------	------------------	---------------	----------------	--------------

32.6128508 *104.5334025*
Latitude 32 36'46.263"N Longitude 104 32'00.249"W, 3610' NAD83?

NATURE OF RELEASE

Type of Release; Enardo Tank vapor fire due to thunderstorm	Volume of Release; Unknown	Volume Recovered none
Source of Release	Date and Hour of Occurrence	Date and Hour of Discovery: 8:05 am
Was Immediate Notice Given? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Not Required	If YES, To Whom? Mike Bratcher Via voice mail (575-748-1283 ext 108)	
By Whom? Nicholas L. Case	Date and Hour 05/22/2018 09:04	
Was a Watercourse Reached? N/A <input type="checkbox"/> Yes <input type="checkbox"/> No	If YES, Volume Impacting the Watercourse. N/A	

If a Watercourse was Impacted, Describe Fully.*

Describe Cause of Problem and Remedial Action Taken.*

Lightning storm ignited the enardo valve on the slop tank causing a small flame. The fire dept was called out to extinguish it. the tank was unaffected but the enardo valve will be replaced. No roads were shut down and emissions from the event cannot be accurately calculated. First responders indicated that they had been dispatched to 20+ such fires last night/ this morning.

Describe Area Affected and Cleanup Action Taken.*

I hereby certify that the information given above is true and complete to the best of my knowledge and understand that pursuant to NMOCD rules and regulations all operators are required to report and/or file certain release notifications and perform corrective actions for releases which may endanger public health or the environment. The acceptance of a C-141 report by the NMOCD marked as "Final Report" does not relieve the operator of liability should their operations have failed to adequately investigate and remediate contamination that pose a threat to ground water, surface water, human health or the environment. In addition, NMOCD acceptance of a C-141 report does not relieve the operator of responsibility for compliance with any other federal, state, or local laws and/or regulations.

Signature: <i>Nicholas L. Case</i>	OIL CONSERVATION DIVISION	
	Approved by Environmental Specialist: Signed By <i>Mike Bratcher</i>	
Printed Name: Nicholas L. Case	Approval Date: <i>5/22/18</i>	Expiration Date: <i>N/A</i>
E-mail Address: nlcase@dcpmidstream.com	Conditions of Approval: <i>FINAL</i>	
Date: 05/22/2018 Phone: 575 802 5225	Attached <input type="checkbox"/> <i>200-4767</i>	

* Attach Additional Sheets If Necessary

Bratcher, Mike, EMNRD

From: Case, Nicholas L <casen@dcpmidstream.com>
Sent: Tuesday, May 22, 2018 10:48 AM
To: Bratcher, Mike, EMNRD
Cc: Case, Nicholas L; Valencia, Israel; Pudim, David A
Subject: initial/ Final C-141 for the small fire at Dagger Draw Booster
Attachments: init final C-1414-3-17 Dagger Draw Fire 05222018.doc

Mr. Bratcher: here is the initial/ Final C-141 for the small fire at Dagger Draw Booster that we discussed on the phone earlier today.

Please e-mail or call me if you have any questions or need any additional information.

Thanks

Nick

Nicholas L. Case
Environmental Specialist

DCP Midstream Operating Company LP
5301 Sierra Vista Drive
Carlsbad NM 88220
Cell: 575-802-5225
e-mail: NLCase@dcpmidstream.com

