



2010 Afton Place
Farmington, NM 87401
Phone: (505) 278-8720
Fax: (505) 326-6112

March 15, 2019

PCS 1523130486
3RF-3

Brandon Powell
New Mexico Oil Conservation Division
1000 Rio Brazos Road
Aztec, New Mexico 87410

RE: Condition of Approval for Extension
Section 30 Recycling Containment and Facility #3RF-3
January 28 - February 24

4/3/19
CS

NMOCD

MAR 18 2019

DISTRICT III

Dear Mr. Powell,

Pursuant to Order R-20253, LOGOS Operating, LLC received approval to operate the Section 30 Recycling Containment and Facility (#3RF-3) located in Section 30, Township 31N, Range 5W, Rio Arriba County, New Mexico through December 31, 2019. Approval of the extension was granted by Deputy Director Gabriel Wade on December 3, 2018. Conditions of Approval (COA) of the C-103 are listed below. This report is being submitted to satisfy the monthly report requirement.

1.0 Conditions of Approval

Approval of the extension was granted with the following COA:

- 1) Take necessary actions to keep fresh water accumulation within the containment to a minimum and prevent damage from freezing.
- 2) Inspect and take photographs of the Facility weekly.
- 3) In the event of leaks or damage to the Facility, the operator must do the following.
 - a. Notify OCD District III within 48 hours of knowledge of leaks or damage.
 - b. Submit a Corrective Action Plan (CAP) to repair leaks or damage within seven days of notification above.
 - c. Upon OCD's approval of the CAP, complete repairs per the OCD-approved schedule.
- 4) By the 15th of the month, submit monthly reports to OCD District III of inspection results with photographs and progress on CAP's if any.
- 5) Verify liner integrity before returning the containment to service.

2.0 Weekly Inspections

LOGOS continues to monitor the condition of the Section 30 Recycling Containment. Attached is a summary of weekly inspections conducted at the containment from January 28 - February 24. Also attached is a photograph log documenting site conditions during January 28 - February 24.




**Section 30 Recycling Containment and Facility
February 2019 Monthly Report**

3.0 Recent Event Summary

- No new leaks have been discovered and previous repairs have held.
- Leak detection volume has increased during the month of January, may have been due to excessive precipitation.
- LOGOS personnel are continuing to search and inspect the liner for any potential areas of concern along the base of the containment and is gathering information for next steps forward for the containment.
- Per email received on 8/6/18 from Aztec OCD office the measured volume that was removed from the leak detection during each pumping event is attached.

This report was submitted on 03/18/2019, the next report will be submitted to the Aztec office by April 15, 2019. For additional information or questions regarding current site conditions, please contact me at 505-787-2027.

Sincerely,



Larissa Farrell
Environmental/Regulatory Technician

Attachments

Weekly Inspection Log Summary

Photograph Log

Measurement Report

Section 30 Recycling Facility and Containment Inspection Summary

WEEKLY INSPECTION:

DATE:

	1/28/19--2/3/19	2/4/19--2/10/19	2/11/19--2/17/19	2/18/19--2/24/19
	YES NO	YES NO	YES NO	YES NO
1. ARE FREEBOARD LEVELS AT 3' OR GREATER?	YES	YES	YES	YES
2. IS THERE ANY OIL ACCUMULATION ON THE CONTAINMENT?	NO	NO	NO	NO
3. ARE THERE VISIBLE TEARS IN LINER?	NO	NO	NO	NO
4. DOES THE NET NEED MAINTENANCE?	NO	NO	NO	NO
5. IS THE FENCING IN GOOD CONDITION?	YES	YES	YES	YES
6. HOUSEKEEPING ISSUES?	NO	NO	NO	NO
7. POND MEASUREMENT (HEIGHT)	0	0	0	0
8. IS THERE WATER PRESENT IN THE LEAK DETECTION TUBE?	NO	NO	NO	NO
9. DEAD WILDLIFE/BIRDS INSIDE CONTAINMENT?	NO	NO	NO	NO
COMMENTS: (include water quality, odor, color, etc.)	water is the same quality and color	water is the same quality and color	water is the same -	water is same quality and color
ADDITIONAL OBSERVATIONS:	pond is frozen. And there is extra water from weather	pond is still frozed and weather has added extra water	pond is freezing over	pond is froze over and had some extra water added to pond from weather

LOGOS Operating, LLC
Section 30 Recycling Containment and Facility
February 2018 Monthly Report

February 12, 2019
Picture #1



February 12, 2019
Picture #2



LOGOS Operating, LLC
Section 30 Recycling Containment and Facility
February 2018 Monthly Report

February 12, 2019
Picture #3



February 13, 2019
Picture #4



LOGOS Operating, LLC
Section 30 Recycling Containment and Facility
February 2018 Monthly Report

February 14, 2019
Picture #5



February 14, 2019
Picture #6




LOGOS Operating, LLC
Section 30 Recycling Containment and Facility
February 2018 Monthly Report

February 18, 2019
Picture #7



February 19, 2019
Picture #8



LOGOS Operating, LLC
Section 30 Recycling Containment and Facility
February 2019 Measurement Report

Date	Measured Inches	Volume in Gallons	Comment
1/28/2019	332	83	
1/29/2019	100	25	
1/30/2019	90	22.5	
1/31/2019			no test bad pump motor
2/1/2019			no test--
2/2/2019			no test--rain
2/4/2019			no test rain
2/5/2019			no test
2/6/2019			no test--snow
2/7/2019			no test
2/8/2019			no test--bad pump
2/9/2019			no test
2/10/2019			no test
2/11/2019			no test --snow
2/12/2019			no test
2/13/2019			no test
2/14/2019			no test
2/15/2019			no test
2/16/2019			no test
2/17/2019			no test--snow
2/18/2018			no test--snow
2/19/2019			no test-new pump --cant get it back under liner frozen pond--snow
2/20/2019			no test
2/21/2019			no test--snow
2/22/2019			no test
2/23/2019			no test--
2/24/2019			no test--pond still frozen