

District I
1625 N. French Dr., Hobbs, NM 88240
District II
1301 W. Grand Avenue, Artesia, NM 88210
District III
1000 Rio Brazos Road, Aztec, NM 87410
District IV
1220 S. St. Francis Dr., Santa Fe, NM 87505

State of New Mexico
Energy Minerals and Natural Resources
Oil Conservation Division
1220 South St. Francis Dr.
Santa Fe, NM 87505

Form C-141
Revised October 10, 2003

Submit 2 Copies to appropriate
District Office in accordance
with Rule 116 on back
side of form

Release Notification and Corrective Action

OPERATOR

Initial Report Final Report

Name of Company ConocoPhillips Company	Contact Mickey Garner
Address 3300 North A St. Bldg 6, Midland, TX 79705-5406	Telephone No. 505.391.3158
Facility Name EVGSAU 3308-007	Facility Type Oil and Gas
Surface Owner State of New Mexico	Mineral Owner State of New Mexico
	Lease No 30-025-32219

LOCATION OF RELEASE

Unit Letter	Section	Township	Range	Feet from the	North/South Line	Feet from the	East/West Line	County
B	33	17S	35E					Lea

Latitude **N 32.79691** Longitude **W 103.46833**

NATURE OF RELEASE

Type of Release Grass Fire	Volume of Release N/Abbl (oil, water)	Volume Recovered (oil, water)
Source of Release N/A	Date and Hour of Occurrence 7-31-2007 13:30	Date and Hour of Discovery 7-31-2007 13:30
Was Immediate Notice Given? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Not Required	If YES, To Whom? Pat Richards	
By Whom? Mickey Garner	Date and Hour 7-31-2007 14:30	
Was a Watercourse Reached? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	If YES, Volume Impacting the Watercourse. N/A	



If a Watercourse was Impacted, Describe Fully.*
N/A

Describe Cause of Problem and Remedial Action Taken.*
A small grass fire occurred when a jumper to a transformer failed and dropped hot wiring to the ground which resulted in a small grass fire. The affected area consisted of a 50' x 100' patch of ranch land.

Describe Area Affected and Cleanup Action Taken.*
Two COPC employees determined they could extinguish the fire by utilizing portable fire extinguishers and commenced to extinguish the fire. The employees stood by for 15 minutes to ensure that the fire would not re-ignite.

It was determined that the power lines and poles belonged to Lea County Electric, meter station #26518.

I hereby certify that the information given above is true and complete to the best of my knowledge and understand that pursuant to NMOCD rules and regulations all operators are required to report and/or file certain release notifications and perform corrective actions for releases which may endanger public health or the environment. The acceptance of a C-141 report by the NMOCD marked as "Final Report" does not relieve the operator of liability should their operations have failed to adequately investigate and remediate contamination that pose a threat to ground water, surface water, human health or the environment. In addition, NMOCD acceptance of a C-141 report does not relieve the operator of responsibility for compliance with any other federal, state, or local laws and/or regulations.

Signature: 	OIL CONSERVATION DIVISION	
Printed Name: Mickey Garner	Approved by District Supervisor: 	
Title: HSER Lead	Approval Date: 8.3.07	Expiration Date: —
E-mail Address: Mickey.D.Garner@conocophillips.com	Conditions of Approval: —	Attached <input type="checkbox"/>
Date: 8-1-2007	Phone: 505.391.3158	

RP# 1517