

District I
1625 N. French Dr , Hobbs, NM 88240
District II
1301 W. Grand Avenue, Artesia, NM 88210
District III
1000 Rio Brazos Road, Aztec, NM 87410
District IV
1220 S. St Francis Dr., Santa Fe, NM 87505

State of New Mexico
Energy Minerals and Natural Resources

Oil Conservation Division
1220 South St. Francis Dr.
Santa Fe, NM 87505

Revised January 1, 2000

Submit 1 Copy to appropriate
District Office

Release Notification and Corrective Action

OPERATOR

Initial Report Final Report

Name of Company DCP Midstream, LP	Contact Johnnie Bradford	
Address 10 Desta Drive, Suite 400 W, Midland, TX., 79705	Telephone# & E-mail 432.620.4166 jbradford@dcpmidstream.com	
Facility Name Eunice Gas Plant	Facility Type Single Wall Sump	
Surface Owner	Mineral Owner	Well API No.

LOCATION OF RELEASE

Unit Letter	Section 5	Township 21	Range 36	Feet from the	North/South Line S	Feet from the	East/West Line E	County Lea
-------------	--------------	----------------	-------------	---------------	-----------------------	---------------	---------------------	---------------

Latitude 32.5144 Longitude -103.2819

NATURE OF RELEASE

Type of Release Water and Oil	Volume of Release Unknown	Volume Recovered 0
Source of Release Leaking single wall sump in the process area.	Date & Hour of Occurrence Unknown	Date & Hour of Discovery 12/20/2007 approximately 15:00
Was Immediate Notice Given OCD? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Not Required	If YES, To Whom @ OCD? N/A	
By Whom? N/A	Date and Hour N/A	
Was a Watercourse Reached? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	If YES, Volume Impacting the Watercourse	

RECEIVED

FEB - 4 2008

HOBBS OCD

If a Watercourse was Impacted, Describe Fully.*
N/A

Describe Cause of Problem and Remedial Action Taken. (If water spilled, give Chloride content)*
During the course of performing annual single wall sump inspections as per GW-016 Approval Condition #9 at the Eunice Gas Plant, the #3 Sump failed the inspection criteria (static leak checking). Corrective actions include: 1. Isolating the sump from service. 2. Removing the existing sump by hydro-excavation. 3. Soil segregation and sampling for BTEX, TPH and Chlorides. 4. Sampling of excavated area for additional contamination and removal as necessary. 5. Following the determination that the excavated area is clean, reinstallation of a double walled fiber glass sump. Additionally, because the sump is isolated, continued contamination is unlikely from this source. DCPM intends to procure additional capital to allow the removal and replacement of all single walled sumps in the plant to double walled fiberglass prior to mitigating the #3 Sump.

Describe Area Affected, Dimensions, and Cleanup Action Taken.*
Area is underground around buried sump, which is located on the South West corner of the process area. Current dimensions are unknown pending excavation. Clean up actions are described in the previous section.

I hereby certify that the information given above is true and complete to the best of my knowledge and understand that pursuant to NMOCD rules and regulations all operators are required to report and/or file certain release notifications and perform corrective actions for releases which may endanger public health or the environment. The acceptance of a C-141 report by the NMOCD marked as "Final Report" does not relieve the operator of liability should their operations have failed to adequately investigate and remediate contamination that pose a threat to ground water, surface water, human health or the environment. In addition, NMOCD acceptance of a C-141 report does not relieve the operator of responsibility for compliance with any other federal, state, or local laws and/or regulations.

Signature: <i>Johnnie Bradford</i>	OIL CONSERVATION DIVISION	
Printed Name: Johnnie Bradford	Approved by District Supervisor <i>J. Johnson</i> ENVIRONMENTAL ENGINEER	
Title: Sr. Environmental Specialist	Approval Date: 2.5.08	Expiration Date: 7.5.08
E-mail Address: jbradford@dcpmidstream.com	Conditions of Approval:	RP#
Date: 01/04/2008 Phone: 432.620.4166	NOTIFICATION TO HOBBS OCD PRIOR TO START OF PROJECT & ALL SAMPLING EVENTS	

RP# 1777

* Attach Additional Sheets If Necessary