

**GW - \_\_\_\_\_ 028 \_\_\_\_\_**

**ABOVE GROUND  
TANK SCHEDULE**

**DATE:**

**01/14/09**

## Chavez, Carl J, EMNRD

---

**From:** Chavez, Carl J, EMNRD  
**Sent:** Thursday, December 01, 2011 7:15 AM  
**To:** 'Moore, Darrell'; Krueger, Pamela; Tsinnajinnie, Leona, NMENV; Cobrain, Dave, NMENV  
**Cc:** Dade, Randy, EMNRD; Lackey, Johnny; Spence, Richard (Trampas); VonGonten, Glenn, EMNRD  
**Subject:** RE: TK-401 Leak  
**Attachments:** API 653.pdf; listing\_of\_standards\_and\_practices.pdf; AST Repair.doc

Darrell:

The propose method of tank repair does not appear to be consistent with API-653 and/or other applicable professional AST guidelines for tank repairs based on the type and volume of refinery tank. In addition, the repairs shall comply with the requirements stipulated in the OCD discharge permit (GW-028) for retrofitting or upgrading the tank to acceptable standards.

Please find attached some references to acceptable practices for tank repairs and provide the agencies with reference to the proper guidelines that the tank will be repair to. Once the repairs are completed, provide the schematic with references of the reconstructed tank for the OCD's tank records.

Thank you.

Carl J. Chavez, CHMM  
New Mexico Energy, Minerals & Natural Resources Dept.  
Oil Conservation Division, Environmental Bureau  
1220 South St. Francis Dr., Santa Fe, New Mexico 87505  
Office: (505) 476-3490  
Fax: (505) 476-3462  
E-mail: CarlJ.Chavez@state.nm.us

Website: <http://www.emnrd.state.nm.us/ocd/>

"Why not Prevent Pollution; Minimize Waste; Reduce the Cost of Operations; & Move Forward with the Rest of the Nation?" To see how, go to "Pollution Prevention & Waste Minimization" at: <http://www.emnrd.state.nm.us/ocd/environmental.htm#environmental>)

---

**From:** Moore, Darrell [mailto:Darrell.Moore@hollyfrontier.com]  
**Sent:** Tuesday, November 29, 2011 10:41 AM  
**To:** Chavez, Carl J, EMNRD; Krueger, Pamela; Tsinnajinnie, Leona, NMENV; Cobrain, Dave, NMENV  
**Cc:** Dade, Randy, EMNRD; Lackey, Johnny; Spence, Richard (Trampas)  
**Subject:** RE: TK-401 Leak

Carl et al,

Typically, there are no engineering drawings done for tank repairs. Obviously, when a new tank is built, there will be engineered drawings to build the tank .....but not for repairs. The lower floor will be repaired using cork and silicon to seal the holes. Four (4) inches of gravel will then be added on top of the lower floor. A brand new steel floor will then be welded into place on top of the gravel. Weep holes (tattle tales) will be added between the two floors for leak detection.

After the new floor has been welded into place, the tank will be hydrotested with fresh groundwater to ensure mechanical integrity. The tank will then be placed back into service.

Materials and crews have been ordered to start this work Monday, December 5, 2011. If there are any questions about this approach, please call me at 575-746-5281 or at my email address.

---

**From:** Chavez, Carl J, EMNRD [mailto:CarlJ.Chavez@state.nm.us]  
**Sent:** Tuesday, November 22, 2011 4:30 PM  
**To:** Krueger, Pamela; Moore, Darrell; Tsinnajinnie, Leona, NMENV; Cobrain, Dave, NMENV  
**Cc:** Dade, Randy, EMNRD  
**Subject:** RE: TK-401 Leak

Pam and Darrell:

I think NMED can respond to the AOC; active remediation based on the chemicals of concern; and/or monitoring downgradient from the tank in question.

OCD requests and engineering drawing to determine how the tank will actually be repaired, since it seems like patch work is the plan based on the LEL and safety concerns. OCD thinks there needs to be competent lower plate, LDS, with another well designed plate above the LDS with an MIT that verifies no leakage to the LDS in order to restore the tank to working order.

Based on the above, the operator can propose an alternative to the above to the agencies.

I'll be back in next Tuesday, November 29, 2011 at 6:30 a.m. NMED should respond tomorrow before the holiday, and if not, maybe by November 28, 2011.

Thank you.

Carl J. Chavez, CHMM  
New Mexico Energy, Minerals & Natural Resources Dept.  
Oil Conservation Division, Environmental Bureau  
1220 South St. Francis Dr., Santa Fe, New Mexico 87505  
Office: (505) 476-3490  
Fax: (505) 476-3462  
E-mail: CarlJ.Chavez@state.nm.us

Website: <http://www.emnrd.state.nm.us/ocd/>

"Why not Prevent Pollution; Minimize Waste; Reduce the Cost of Operations; & Move Forward with the Rest of the Nation?" To see how, go to "Pollution Prevention & Waste Minimization" at:  
<http://www.emnrd.state.nm.us/ocd/environmental.htm#environmental>)

---

**From:** Krueger, Pamela [mailto:pam.krueger@arcadis-us.com]  
**Sent:** Tuesday, November 22, 2011 2:52 PM  
**To:** Moore, Darrell; Chavez, Carl J, EMNRD; Tsinnajinnie, Leona, NMENV  
**Cc:** Dade, Randy, EMNRD  
**Subject:** RE: TK-401 Leak

Tank 401 is already included in the Permit under AOC3 – Southeast Tank Farm. That AOC is included in AOC Group 1. MW-28 is on the downgradient side of the Southeast Tank Farm, almost due east of Tank 401. This well is sampled semiannually and the analyte list includes GRO, DRO, Volatiles, metals and cyanide.

**Pamela R. Krueger** | Senior Project Manager | [pam.krueger@arcadis-us.com](mailto:pam.krueger@arcadis-us.com)  
ARCADIS U.S., Inc. | 2929 Briarpark Dr. Suite 300 | Houston, TX 77042  
T. 713.953.4816 | M. 713.249.8548 | F. 713.977.4620  
[www.arcadis-us.com](http://www.arcadis-us.com)  
ARCADIS, Imagine the result

---

**From:** Moore, Darrell [mailto:Darrell.Moore@hollyfrontier.com]  
**Sent:** Tuesday, November 22, 2011 3:32 PM  
**To:** Chavez, Carl J, EMNRD; Tsinnajinnie, Leona, NMENV  
**Cc:** Dade, Randy, EMNRD; Krueger, Pamela  
**Subject:** RE: TK-401 Leak

Et al

We have gotten into this tank and are having problems with LEL levels. The LEL levels are making it unsafe to do any cutting of the floor so that we could perform the path forward delineated below. Obviously, there is some amount of contamination below the tank. Since we cant cut the floor safely, even using water, we would like to propose a modified path forward.

- 1) We will plug all holes in the current floor of the tank. This should isolate whatever contamination is under the tank and allow us to get the LEL's down to a safe level.
- 2) We will then cover the floor with 4" of pea gravel and install a new steel floor in the tank.
- 3) The below path forward mentions MW-99 as being a monitor well to watch. That monitor well is actually WEST of TK 401 and will probably not be relevant to this issue. That was my mistake. However, MW-28 is about 300 ft due east of TK-401 and we can monitor that well for any trends in VOC's. MW-66 is also east of TK-401, but just south of due east.

Since we cant safely approach this any other way, this may be a candidate to be included in our post-closure permit as an Area of Concern (AOC).

---

**From:** Chavez, Carl J, EMNRD [mailto:CarlJ.Chavez@state.nm.us]  
**Sent:** Thursday, November 10, 2011 7:48 AM  
**To:** Tsinnajinnie, Leona, NMENV  
**Cc:** Moore, Darrell; Dade, Randy, EMNRD  
**Subject:** FW: TK-401 Leak

Leona:

I spoke with Darrell Moore this morning about the leak and a path forward as requested in his e-mail on 11/8.

The path forward is:

- 1) Remove the section where the double pinhole leak is located (NW Quadrant of Tank within 3 ft. of cement ring wall (note: no liner exists beneath the tank) and hand auger down to 10 ft. and assess cuttings and PID readings for gross contamination assessment. A bottom hole sample collected using EPA QA/QC and DQO protocols will be analyzed for TPH and VOCs.
- 2) The closest MW (MW-99) is located about 300 yds E-NE of Tank will be evaluated for increasing trends of VOCs.
- 3) The Prax-Aire monitoring was implemented about a year ago and there were no indications of a leak at that time according to Darrell. Prax-Aire was called out recently again and detected a leak, but it was the stained soils from the tattle-tale leak leak detection system in the concrete ringwall beneath the tank that indicated that there was a leak.
- 4) The operator will notify the NMED and OCD before the augering is to be performed. Based on this work, the agencies will need to determine whether active remediation and another MW positioned down gradient is warranted. Darrell indicated that this area was not in a SWMU.

Please chime in if you have comments and/or recommendations at this time. Thank you.

Carl J. Chavez, CHMM  
New Mexico Energy, Minerals & Natural Resources Dept.  
Oil Conservation Division, Environmental Bureau  
1220 South St. Francis Dr., Santa Fe, New Mexico 87505  
Office: (505) 476-3490  
Fax: (505) 476-3462  
E-mail: CarlJ.Chavez@state.nm.us

Website: <http://www.emnrd.state.nm.us/ocd/>

"Why not Prevent Pollution; Minimize Waste; Reduce the Cost of Operations; & Move Forward with the Rest of the Nation?" To see how, go to "Pollution Prevention & Waste Minimization" at: <http://www.emnrd.state.nm.us/ocd/environmental.htm#environmental>)

---

**From:** Chavez, Carl J, EMNRD

**Sent:** Tuesday, November 08, 2011 7:24 AM

**To:** Tsinnajinnie, Leona, NMENV

**Subject:** FW: TK-401 Leak

Leona:

I'm wondering if this is the tank with the liner connected to the inner ring-wall of the tank concrete base? Also, I though Navajo had a liquid level alarm to detect product loss or some method to gauge the tanks for possible loss?

I'm reading up on naphthas now to see about contaminant hydrogeology and monitoring..... I'll get back with you soon to discuss.

Thanks.

Carl J. Chavez, CHMM

New Mexico Energy, Minerals & Natural Resources Dept.

Oil Conservation Division, Environmental Bureau

1220 South St. Francis Dr., Santa Fe, New Mexico 87505

Office: (505) 476-3490

Fax: (505) 476-3462

E-mail: [CarlJ.Chavez@state.nm.us](mailto:CarlJ.Chavez@state.nm.us)

Website: <http://www.emnrd.state.nm.us/ocd/>

"Why not Prevent Pollution; Minimize Waste; Reduce the Cost of Operations; & Move Forward with the Rest of the Nation?" To see how, go to "Pollution Prevention & Waste Minimization" at: <http://www.emnrd.state.nm.us/ocd/environmental.htm#environmental>)

---

**From:** Moore, Darrell [<mailto:Darrell.Moore@hollyfrontier.com>]

**Sent:** Tuesday, November 08, 2011 7:00 AM

**To:** Chavez, Carl J, EMNRD; Tsinnajinnie, Leona, NMENV

**Subject:** TK-401 Leak

Carl and Leona

Ive attached the C-141 and a few photos of a leak we had in a gasoline tank (Tk-401). This C-141 and the pictures were sent to OCD and NMED on October 7, 2011. We have emptied the tank and found a small hole in the floor in the northwest quadrant and that will be repaired. We have cleaned up the part of the spill that can be reached. Obviously we cant clean up the spill that is under the tank. So Im looking for guidance from OCD and NMED about a path going forward. Do we put this area on the AOC list in our post-closure permit and deal with it that way?

**Darrell Moore**

Environmental Manager for Water and Wastec

**The Holly Frontier Companies**

**Navajo Refining Company, LLC**

**501 E Main**

**PO Box 159**

**Artesia NM 88211-0159**

Phone: 575-746-5281

Cell: 575-703-5058

CONFIDENTIALITY NOTICE: This e-mail, and any attachments, may contain information that is privileged and confidential. If you received this message in error, please advise the sender immediately by reply e-mail and do not retain any paper or electronic copies of this message or any attachments. Unless expressly stated, nothing contained in this message should be construed as a digital or electronic signature or a commitment to a binding agreement

---

CONFIDENTIALITY NOTICE: This e-mail, and any attachments, may contain information that is privileged, proprietary and/or confidential. If you received this message in error, please advise the sender immediately by reply e-mail and do not retain any paper or electronic copies of this message or any attachments. Unless expressly stated, nothing contained in this message should be construed as a digital or electronic signature or a commitment to a binding agreement.

---

NOTICE: This e-mail and any files transmitted with it are the property of ARCADIS U.S., Inc. and its affiliates. All rights, including without limitation copyright, are reserved. The proprietary information contained in this e-mail message, and any files transmitted with it, is intended for the use of the recipient(s) named above. If the reader of this e-mail is not the intended recipient, you are hereby notified that you have received this e-mail in error and that any review, distribution or copying of this e-mail or any files transmitted with it is strictly prohibited. If you have received this e-mail in error, please notify the sender immediately and delete the original message and any files transmitted. The unauthorized use of this e-mail or any files transmitted with it is prohibited and disclaimed by ARCADIS U.S., Inc. and its affiliates. Nothing herein is intended to constitute the offering or performance of services where otherwise restricted by law.

## List of Frequently Utilized Storage Tank Standards and Practices

Below is a list of frequently used storage tank standards and practices from organizations that are referenced in 25 PA Code, Chapter 245. There may be other applicable standards. The current (or most recent) edition/revision of a publication should be used.

<b>American Petroleum Institute</b>	
Number (ID)	Title &/or Description
<b>Construction Standards:</b>	
API Spec 12D	Specifications for Field Welded Tanks for Storage of Production Liquids
API Spec 12F	Shop Welded Tanks for Storage of Production Liquids
API Spec 12P	Specifications for Fiberglass Reinforced Plastic Tanks
API Std 620	Design and Construction of Large, Welded, Low Pressure Storage Tanks
API Std 650	Welded Steel Tanks for Oil Storage (Replaced several API 12 series Spec's)
API Std 2000	Venting Atmospheric and Low-pressure Storage Tanks
API Std 2610	Design, Construction, Operation, Maintenance, and Inspection of Terminal & Tank Facilities
<b>Inspection Standards:</b> (Includes Construction Alteration, and Reconstruction Standards)	
API Std 510	Pressure Vessel Inspection Code (Maintenance Inspection, Rating, Repair and Alteration)
API Std 570	Inspection, Repair, Alteration, and Rerating of In-Service Piping Systems
API Std 653	Tank Inspection, Repair, Alteration, and Reconstruction
API Std 2015	Requirements for Safe Entry & Cleaning of Petroleum Storage Tanks
<b>Recommended Practices:</b>	
API RP 12H	Installation of New Bottoms in Old Storage Tanks
API RP 12R	Setting, Maintenance, Inspection, Operation, and Repair of Tanks in Production Service
API RP 574	Inspection Practices for Piping System Components
API RP 575	Inspection of Atmospheric and Low Pressure Storage Tanks
API RP 580	Risk Based Inspection
API RP 651	Cathodic Protection of Aboveground Petroleum Storage Tanks
API RP 652	Lining of Aboveground Petroleum Storage Tank Bottoms
API RP 1107	Pipeline Maintenance Welding Practices
API RP 1110	Pressure Testing of Liquid Petroleum Pipelines
API RP 1604	Closure of Underground Petroleum Storage Tanks
API RP 1615	Installation of Underground Petroleum Storage Systems
API RP 1626	Storing and Handling Ethanol and Gasoline-Ethanol Blends at Distribution Terminals and Service Stations
API RP 1627	Storing and Handling of Gasoline-Methanol/Cosolvent Blends at Distribution Terminals and Service Stations
API RP 1631	Interior Lining and Periodic Inspection of Underground Storage Tanks
API RP 1632	Cathodic Protection of Underground Petroleum Storage Tanks and Piping Systems
API RP 1637	Using the API Color-Symbol System to Mark Equipment and Vehicles for Product Identification at Gasoline Dispensing Facilities and Distribution Terminals
API RP 2003	Protection Against Ignitions Arising Out of Static, Lightning and Stray Currents
API RP 2016	Guidelines for Entering and Cleaning Petroleum Storage Tanks

<b>American Petroleum Institute</b>	
Number (ID)	Title &/or Description
API RP 2027	Ignition Hazards Involved in Abrasive Blasting of Atmospheric Storage Tanks in Hydrocarbon Service
API RP 2350	Overfill Protection for Storage Tanks in Petroleum Facilities
<b>Other Publications:</b>	
API – 334	A Guide to Leak Detection for Aboveground Storage Tanks
API Pub 2009	Safe Welding, Cutting and Hot Work Practices in the Petroleum and Petrochemical Industries
API Pub 2200	Repairing Crude Oil, Liquefied Petroleum Gas, and Product Pipelines
API – 2207	Preparing Tank Bottoms for Hot Work
API Pub 2217A	Guidelines for Work in Inert Confined Spaces in the Petroleum Industry

<b>Petroleum Equipment Institute</b>	
Number (ID)	Title &/or Description
<b>Recommended Practices:</b>	
PEI RP 100	Recommended Practices for Installation of Underground Liquid Storage Systems
PEI RP 200	Recommended Practices for Installation of Aboveground Storage Systems for Motor Vehicle Fueling

<b>National Leak Prevention Association</b>	
Number (ID)	Title &/or Description
<b>Recommended Practices:</b>	
NLPA Std 631	Entry, Cleaning, Interior Inspection, Repair and Lining of Underground Storage Tanks

<b>NACE International – The Corrosion Society</b>	
Number (ID)	Title &/or Description
<b>Inspection Standards:</b>	
NACE TM 01-01	Measurement Techniques Related to Criteria for Cathodic Protection on Underground or Submerged Metallic Tank Systems
NACE TM 04-97	Measurement Techniques Related to Criteria for Cathodic Protection on Underground or Submerged Metallic Piping Systems
<b>Recommended Practices:</b>	
NACE 1/SSPC-SP5	Steel Structures Painting Council: "White Metal Blast Cleaning"
NACE 2/SSPC-SP10	Steel Structures Painting Council: "Near White Metal Blast Cleaning"
NACE 3/SSPC-SP6	Steel Structures Painting Council: "Commercial Blast Cleaning"
NACE 4/SSPC-SP7	Steel Structures Painting Council: "Brush Off Cleaning"
NACE 10/SSPC-PA6	Steel Structures Painting Council: "Fiberglass-Reinforced Plastic (FRP) Linings Applied to Bottoms of Carbon Steel Aboveground Storage Tanks"
NACE RP 0169	Control of External Corrosion on Underground or Submerged Metallic Piping Systems

<b>NACE International – The Corrosion Society</b>	
Number (ID)	Title &/or Description
NACE RP 0172	Surface Preparation of Steel and Other Hard Materials by Water Blasting Prior to Coating or Recoating
NACE SP 0177	Mitigation of Alternating Current and Lightning Effects on Metallic Structures and Corrosion Control Systems
NACE RP 0178	Design, Fabrication, and Surface Finish of Metal Tanks and Vessels to be Lined for Chemical Immersion Service
NACE RP 0184	Repair of Lining Systems
NACE RP 0187	Design Considerations for Corrosion Control of Reinforcing Steel in Concrete
NACE SP 0188	Discontinuity (Holiday) Testing of New Protective Coatings on Conductive Substrates
NACE RP 0193	External Cathodic Protection of On-Grade Carbon Steel Storage Tank Bottoms
NACE RP 0275	Application of Organic Coatings to the External Surface of Steel Pipe for Underground Service
NACE RP 0285	Corrosion Control of Underground Storage Tank Systems by Cathodic Protection

<b>National Fire Protection Association</b>	
see also 37 PA Code Chapters 11 and 13, Flammable & Combustible Liquids Handbook	
Number (ID)	Title &/or Description
<b>Construction Standards:</b>	
NFPA 70 (NEC)	National Electric Code®
NFPA 30	Flammable and Combustible Liquids Code
NFPA 30A	Motor Fuel Dispensing Facilities and Repair Garages
NFPA 303	Marinas and Boatyards
<b>Recommended Practices:</b>	
NFPA 77	Static Electricity
NFPA 326	Safeguarding Tanks and Containers for Entry, Cleaning or Repair

<b>Underwriters Laboratories</b>	
Number (ID)	Title &/or Description
<b>Construction Standards:</b>	
UL Std 58	Standards for Steel Underground Tanks for Flammable and Combustible Liquids
UL Std 142	Standard for Steel Aboveground Tanks for Flammable and Combustible Liquids
UL Std 567	Standard for Emergency Breakaway Fittings, Swivel Connectors and Pipe-Connection Fittings for Petroleum Products and LP-Gas
UL Std 842	Standard for Valves for Flammable Fluids
UL Std 860	Standard for Pipe Unions for Flammable and Combustible Fluids and Fire Protection Service
UL Std 971	Standard for Nonmetallic Underground Piping for Flammable Liquids
UL Std 1316	Glass-Fiber-Reinforced Plastic Underground Storage Tanks for Petroleum Products, Alcohol and Alcohol-Gasoline Mixtures
UL Std 1746	Standard for External Corrosion Protection Systems for Steel Underground Storage Tanks
UL Std 2085	Standard for Protected Aboveground Tanks for Flammable and Combustible Liquids
UL Std 2245	Standard for Below-grade Vaults for Flammable Liquid Storage Tanks

<b>American National Standards Institute</b>	
Number (ID)	Title &/or Description
<b>Construction Standards:</b>	
ASME B31.3	American Society of Mechanical Engineers: "Process Piping"
ASME B31.4	American Society of Mechanical Engineers: "Liquid Transportation Systems for Hydrocarbons, Liquid Petroleum Gas, Anhydrous Ammonia and Alcohols"
<b>Recommended Practices:</b>	
ASSE Z117.1	American Society of Safety Engineers: "Safety Requirements for Confined Spaces"

<b>American Society for Testing and Materials</b>	
Number (ID)	Title &/or Description
<b>Construction Standards:</b>	
ASTM A182/A182M	Standard Specification for Forged or Rolled Alloy Stainless Steel Pipe Flanges, Forged Fittings and Valves and Parts for High-Temperature Service
ASTM D2996	Standard Specification for Filament-Wound Fiberglass (Glass-Fiber-Reinforced Thermosetting-Resin) Pipe
ASTM D4097	Standard Specification for Contact-Molded Glass-Fiber-Reinforced Thermoset Resin Corrosion Resistant Tanks
ASTM D5685	Standard Specification for Fiberglass (Glass-Fiber-Reinforced Thermosetting-Resin) Pressure Pipe Fittings
<b>Recommended Practices:</b>	
ASTM E797	Standard Practice for Measuring Thickness by Manual Ultrasonic Pulse-Echo Contact Method
ASTM D2794	Standard Test Method for Resistance of Organic Coatings on the Effects of Rapid Deformation (Impact)

<b>Steel Tank Institute</b>	
Number (ID)	Title &/or Description
<b>Construction Standards:</b>	
STI P3	Specification and Manual for External Corrosion Protection of Underground Steel Storage Tanks
STI F841	Standard for Dual Wall Underground Steel Storage Tanks
STI F894	Act-100® Specification For External Corrosion Protection of FRP Composite Steel USTs (See also Association of Composite Tanks)
STI F921®	F921® Standard for Aboveground Tanks with Integral Secondary Containment
STI F922	Specification for Permatank®
STI F941	Standards for Fireguard® Thermally Insulated Aboveground Storage Tanks
STI R951	Specification for Tanks Using Low Levels of Pressure in the Tanks Interstice
STI F961	ACT-100U Specification for External Corrosion Protection of Composite Steel Underground Storage Tanks
<b>Inspection Standards:</b>	
STI SP001	Standard for Inspection of In-Service Shop Fabricated Aboveground Tanks for Storage of Combustible and Flammable Liquids
<b>Recommended Practices:</b>	
STI SP031	Standard for Repair of In-Service Shop Fabricated Aboveground Tanks for Storage of Combustible & Flammable Liquids

<b>Steel Tank Institute</b>	
Number (ID)	Title &/or Description
STI R821	sti-P3 Installation Instructions
STI R891	RP for Hold Down Strap Isolation
STI R892	RP for Corrosion Protection of Underground Piping Networks Associated with Liquid Storage and Dispensing Systems
STI R912	Installation Instructions for Shop Fabricated Aboveground Storage Tanks for Flammable, Combustible Liquids
STI R913	Act-100® Installation Instructions
STI R923	Permatank® Installation Instructions
STI R931	F921® Installation Instructions
STI R942	Fireguard® Installation & Testing Instructions for Thermally Insulated, Lightweight, Double Wall Fireguard Aboveground Storage Tanks
STI R971	ACT-100-U® Installation Instructions
STI R972	RP for the Addition of Supplemental Anodes to sti-P3® USTs

<b>Steel Structures Painting Council</b> see also NACE International	
Number (ID)	Title &/or Description
<b>Recommended Practices:</b>	
	SSPC Painting Manual volume I
	SSPC Painting Manual volume II

<b>Association of Composite Tanks</b>	
Number (ID)	Title &/or Description
<b>Construction Standards:</b>	
ACT 100	Specification for the Fabrication of FRP Clad Underground Storage Tanks

<b>Fiberglass Petroleum Tank and Pipe Institute</b>	
Number (ID)	Title &/or Description
<b>Recommended Practices:</b>	
FFTP 1	Fiberglass Piping Systems Installation Check List for Underground Petroleum Pipe
FTPI RP T-95-02	Remanufacturing of Fiberglass Reinforced Plastic (FRP) Underground Storage Tanks

<b>American Concrete Institute</b>	
Number (ID)	Title &/or Description
<b>Recommended Practices:</b>	
ACI 350	Environmental Engineering Concrete Structures



**BODY OF KNOWLEDGE  
API-653 ABOVEGROUND STORAGE TANK  
INSPECTOR  
CERTIFICATION EXAMINATION**

November 2007 (Replaces November 2006)

API Authorized Aboveground Storage Tank Inspectors must have a broad knowledge base relating to tank inspection and repair of aboveground storage tanks. The API Aboveground Storage Tank Inspector Certification examination is designed to identify individuals who have satisfied the minimum qualifications specified in API Standard 653, *Tank Inspection, Repair, Alteration, and Reconstruction*.

The examination consists of two parts. The closed book part tests the candidate on knowledge and tasks requiring everyday working knowledge of API Standard 653 and the applicable reference documents. The open book portion of the examination requires the use of more detailed information that the inspector is expected to be able to find in the documents, but would not normally be committed to memory.

**REFERENCE PUBLICATIONS:**

**A. API Publications**

**API Recommended Practice 571**, *Damage Mechanisms Affecting Equipment in Refining Industry*  
**API Recommended Practice 577**, *Welding Inspection and Metallurgy*  
**API Recommended Practice 575**, *Inspection of Atmospheric and Low-Pressure Storage Tanks*  
**API Standard 650**, *Welded Steel Tanks for Oil Storage*  
**API Recommended Practice 651**, *Cathodic Protection of Aboveground Petroleum Storage Tanks*  
**API Recommended Practice 652**, *Lining of Aboveground Petroleum Storage Tank Bottoms*  
**API Standard 653**, *Tank Inspection, Repair, Alteration, and Reconstruction*

**B. ASME Publications**

**American Society of Mechanical Engineers (ASME) Boiler & Pressure Vessel Code:**  
**Section V**, Nondestructive Examination  
**Section IX**, Welding and Brazing Qualifications

Note: Refer to the Publications Effectivity Sheet in the application package for a list of which editions, addenda, and supplements of the reference publications are effective for your exam.

# I. CALCULATIONS & TABULAR EVALUATIONS FOR EVALUATING THICKNESS MEASUREMENTS, WELD SIZES, AND TANK INTEGRITY

(NOTE: Paragraph references for all formulas and calculations listed here should be checked for accuracy to the edition, addenda, or supplement for the examination you plan to take per the Publication Effectivity Sheet in the API Examination Application.)

NOTE: Candidates are expected to be able to understand SI units (metric system) and the US customary units (inches, feet, PSI, etc.) and to use both system formulas.

A. Calculation questions will be oriented toward existing tanks, not new tanks. API Authorized AST Inspectors should be able to check and perform calculations included in the following categories:

## I. CORROSION RATES AND INSPECTION INTERVALS (API-575, Paragraph 7.6)

The Inspector should be able to take inspection data and determine the internal and external inspection intervals. These calculations could be in either the "open book" or "closed book" portion of the exam. The Inspector must be able to calculate:

- a. Metal Loss (including corrosion averaging - API-653, Section 4)
- b. Corrosion Rates
- c. Remaining Life
- d. Remaining Corrosion Allowance (API-653, Section 6)
- e. Inspection Interval (API-653, Section 6)

$$\text{Remaining life (years)} = \frac{t_{\text{actual}} - t_{\text{minimum}}}{\text{corrosion rate}}$$

[inches (millimeters per year)]

Where:

- $t_{\text{actual}}$  = the thickness, in inches (millimeters), recorded at the time of inspection for a given location or component.
- $t_{\text{minimum}}$  = minimum allowable thickness, in inches (millimeters), for a given location or component.

$$\text{Corrosion rate} = \frac{t_{\text{previous}} - t_{\text{actual}}}{\text{years between } t_{\text{actual}} \text{ and } t_{\text{previous}}}$$

- $t_{\text{previous}}$  = the thickness, in inches (millimeters), recorded at the same location as  $t_{\text{actual}}$  measured during a previous inspection.

The formulas for performing the above calculations and rules for setting the inspection intervals may be "closed-book" during the exam. The inspector should also be able to compensate for the corrosion allowance. (Add or subtract based on requirements from the exam problem.)

## 2. JOINT EFFICIENCIES

The inspector must be able to determine the joint efficiency, "E", of a tank weld. Inspector should be able to determine:

- a. Joint Types (API-653 Section 4, Table 4-2)

- b. Type and extent of radiography performed (API 653, Table 4-2, Section 12; API 650, Section 6.1, Figure 6-1)
- c. Joint efficiency by reading API-653, Table 4-2  
Determining joint efficiency may be part of a minimum thickness or maximum fill height problem since joint efficiency, "E", is used in the formulas for determining required thickness. (API-653, 4.3.3.1)

### 3. MAXIMUM FILL HEIGHT (HYDROSTATIC TESTING)

The inspector should be able to determine the maximum liquid height for a tank. To determine the height, the "t<sub>min</sub>" formula in API-653 is rearranged as follows. This formula will be provided in the exam. The inspector is NOT expected to derive this formula by using transposition.

- a. Calculate the minimum allowable thickness per Section 4 of API 653 or the maximum fill height in the localized corroded area per:

$$H = \left( \frac{S \times E \times t_{\min}}{2.6 \times D \times G} \right)$$

- b. Calculate the minimum allowable thickness per Section 4 of API 653 or the maximum fill height for an entire shell course per:

$$H = \left( \frac{S \times E \times t_{\min}}{2.6 \times D \times G} \right) + 1$$

### 4. WELD SIZES FOR SHELL & ROOF OPENINGS

The inspector should be familiar with determining the sizes and spacing of welds for shell openings to the extent of being able to use the information in the following Figures and Tables:

- a) API-650, Figures 3-4A, 3-4B, 3-5, 3-6, 3-9, 3-11, 3-13, 3-14, 3-16, 3-17, 3-18
- b) API-650, Tables 3-6, 3-7, 3-9
- c) API-653, Figures 9-1, 9-2, 9-3A, 9-3B

### 5. HOT TAPPING

- a) The Inspector should be familiar with the Hot Tapping requirements. (API-653, Paragraph 9.14)
- b) The inspector should be able to calculate the minimum spacing between an existing nozzle and a new hot tap nozzle. (API-653 Paragraph 9.14.3)

### 6. SETTLEMENT EVALUATION

The Inspector should be able to calculate the maximum allowed settlement for the following:

- a) Edge Settlement (API-653 Appendix B.2.3, fig. B-5)
- b) Bottom Settlement Near the Tank Shell (API-653, Appendix B.2.4, Figures B-6, B-7, B-9 B-10, B-11, B-12)
- c) Localized Bottom Settlement Remote from the Tank Shell (API-653, B.2.5, Fig. B-8)

### 7. NUMBER OF SETTLEMENT POINTS

- a) The inspector should be able to calculate the number of survey points for determining tank settlement. (API-653 12.5.1.2, Appendix B, Figure B-1, Figure B-2)

## 8. IMPACT TESTING

The inspector should understand the importance of tank materials having adequate toughness. The inspector should be able to determine:

- a) Tank design metal temperature (API-650, 2.2.9.3 & Figure 2-2)
- b) Material Group Number for a plate (API-650, Tables 2-3a and 2-3b)
- c) If impact testing is required (API-650, Figure 2-1)
- d) If impact test values are acceptable (API-650, Table 2-4)

## 9. EXISTING TANK SHELL - MINIMUM THICKNESS

- a) Calculate "S", allowable stress (API-653, 4.3.3.1 & 4.3.4.1)
- b) Determine "E", Joint efficiency (API-653, 4.3.3.1, 4.3.4.1 & Tables 4-2 & 4-3)
- c) Determine "H", liquid height (API-653, 4.3.3.1 & 4.3.4.1)
- d) Calculate- minimum acceptable thickness (API-653, 4.3.3.1 & 4.3.4.1)
- e) Calculate the thickness required for continued service (API-653, 4.3.3.1 & 4.3.4.1)

## 10. RECONSTRUCTED TANK SHELL - MINIMUM THICKNESS

The inspector should be able to determine the minimum thickness of the shell of a reconstructed tank. The inspector should be able to:

- a) Determine " $S_d$ ", allowable stress for design condition (API-650, table 3-2, API-653, 8.4.2)
- b) Determine " $S_t$ ", allowable stress for hydrostatic test condition (API-650, Table 3-2, API-653, 8.4.3)
- c) Calculate " $t_d$ ", design shell thickness (API-650, 3.6.3.2, for tanks of 200 foot diameter and smaller)
- d) Calculate " $t_t$ ", hydrostatic test shell thickness (API-650, 3.6.3.2)

## 11. TANK SHELL - CORRODED AREA

The inspector should be able to determine if a tank shell corroded area is acceptable for continued service. The inspector should be able to:

- a) Select " $t_2$ ", minimum thickness exclusive of pits for a corroded area (API-653, 4.3.2.1.a & Figure 4-1)
- b) Calculate "L", critical length for a corroded area (API-653, 4.3.2.1.b & Figure 4-1)
- c) Determine " $t_1$ ", average thickness for a corroded area (API-653, 4.3.2.1.c, 4.3.2.1.d, Figure 4-1)
- d) Determine " $t_{min}$ " for the corroded area "H", height and "E", joint efficiency will be based on corroded area (API-653, 4.3.3.1)
- e) Determine if " $t_1$ " and " $t_2$ " are acceptable (API-653, 4.3.3.1.a & .b)

## 12. TANK SHELL - PITTING

The inspector should be able to evaluate a pitted area. The inspector should be able to:

- a) Calculate maximum acceptable pit depth (API-653, 4.3.2.2.a)
- b) Determine the maximum length of pits in any 8" vertical length (API-653, 4.3.2.2.b & Figure 4-2)

### 13. BOTTOM PLATE MINIMUM THICKNESS

The inspector should be able to determine if the bottom thickness is acceptable for continued service. The inspector should be able to:

Calculate "MRT<sub>1</sub>" & "MRT<sub>2</sub>", minimum remaining thickness at the next inspection. (API-653, 4.4.7.1)

Calculate "O", maximum period of operation. These formulas will be provided in the exam.

### 14. REPLACEMENT PLATES

- a) The inspector should be able to determine the minimum dimensions for a replacement plate. (API-653, Figure 9-1)

### 15. LAP WELDED PATCH PLATES

Per API-653, Paragraph 9.3 the inspector should be able to determine:

- a) The minimum thickness
- b) The minimum weld size
- c) The allowable size of the patch plate

- B. Typical code calculations and requirements that candidates will **NOT** be expected to know for purposes of the certification examination.

- 1. Required thickness calculations for wind, earthquake, and small internal pressures;
- 2. Nozzle calculations for external loads;
- 3. Flange calculations;
- 4. Brazing requirements;
- 5. Calculating venting requirements;
- 6. Ladder, stairway, and other structural type calculations;
- 7. Calculations for bottoms supported by grillage;
- 8. Variable point method calculations

## II. WELDING ON ATMOSPHERIC ABOVEGROUND STORAGE TANKS

### ASME Section IX, Welding and Brazing Qualifications

(NOTE: Candidates should be familiar with the basic requirements for welding qualifications for procedures and welding personnel contained in ASME Section IX. Brazing is NOT covered on the examination. )

A. The inspector should have the knowledge and skills required to review a Procedure Qualification Record and a Welding Procedure Specification or to answer questions requiring the same level of knowledge and skill. Questions covering the specific rules of Section IX will be limited in complexity and scope to the SMAW and SAW welding processes.

- 1) Questions will be based on:
  - a) No more than one process
  - b) Filler metals limited to one
  - c) Essential, non-essential, variables only will be covered
  - d) Number, type, and results of mechanical tests
  - e) Base metals limited to P1
  - f) Additional essential variables required by API-650 or API-653
  
- 2) The following are specifically excluded:
  - a) Dissimilar base metal joints
  - b) Supplemental powdered filler metals and consumable inserts
  - c) Special weld processes such as corrosion-resistant weld metal overlay, hard-facing overlay, and dissimilar metal welds with buttering
  - d) Charpy impact requirements and supplementary essential variables
  - e) Any PQR and WPS included on the examination will not include heat treatment requirements.

B. The inspector should know that the WPS must reference the applicable PQR and that the PQR must be signed and dated.

C. **API-650 and API-653:** General welding requirements:

- 1) **API Standard 650, *Welded Steel Tanks for Oil Storage*:** The inspector should be familiar with and understand the general rules for welding in API-650, Section 7 and other rules for welding in API-650 such as those for:
  - a) typical joints and definitions
  - b) weld sizes
  - c) restrictions on joints
  - d) maximum allowable reinforcement
  - e) inspection requirements
  
- 2) **API Standard 653, *Tank Inspection, Repair, Alteration, and Reconstruction*:** The inspector should be familiar with and understand the general rules for welding in API-653, Section 11.

### III. NONDESTRUCTIVE EXAMINATION

#### ASME Section V, Nondestructive Examination

NOTE: The examination will cover only the main body of each referenced Article, except as noted:

A. Article 1, General Requirements:

The inspector should be familiar with and understand:

- 1) The Scope of Section V,
- 2) Rules for use of Section V as a referenced Code,
- 3) Responsibilities of the Owner / User, and of subcontractors,
- 4) Calibration,
- 5) Definitions of "inspection" and examination",
- 6) Record keeping requirements.

B. Article 2, Radiographic Examination:

The inspector should be familiar with and understand:

- 1) The Scope of Article 2 and general requirements,
- 2) The rules for radiography as typically applied on butt welded AST horizontal and vertical seams such as, but not limited to:
  - required marking
  - type, selection, number, and placement of IQIs,
  - allowable density
  - control of backscatter radiation
  - location markers
- 3) Records

C. Article 6, Liquid Penetrant Examination, Including Mandatory Appendix II:

The inspector should be familiar with and understand:

- 1) The Scope of Article 6,
- 2) The general rules for applying and using the liquid penetrant method such as but not limited to:
  - a) procedures
  - b) contaminants
  - c) techniques
  - d) examination
  - e) interpretation
  - f) documentation
  - g) record keeping

D. Article 7, Magnetic Particle Examination (Yoke and Prod techniques only, excluding paragraphs T-765 and T-766):

The inspector should be familiar with and understand the general rules for applying and using the magnetic particle method such as but not limited to:

- 1) The Scope of Article 7,
- 2) General requirements such as but not limited to requirements for:
  - a) procedures
  - b) techniques (Yoke and Prod only)
  - c) calibration
  - d) examination

- . e) interpretation
- 3) Documentation and record keeping

E. Article 23, Ultrasonic Standards, **Section SE-797 only** – Standard practice for measuring thickness by manual ultrasonic pulse-echo contact method:

The inspector should be familiar with and understand;

- 1) The Scope of Article 23, Section SE-797,
- 2) The general rules for applying and using the Ultrasonic method
- 3) The specific procedures for Ultrasonic thickness measurement as contained in paragraph 7.

F. **API-650 and API-653:** General nondestructive examination requirements:

- 1) **API Standard 650, *Welded Steel Tanks for Oil Storage*:** The inspector should be familiar with and understand the general rules for NDE in API-650, Section 6.
- 2) **API Standard 653, *Tank Inspection, Repair, Alteration, and Reconstruction*:** The inspector should be familiar with and understand the general rules for NDE in API-653, Section 12

#### IV. PRACTICAL KNOWLEDGE - GENERAL

A. The following topics may be covered:

- 1) Organization and Certification Requirements.
- 2) Types and Definitions of Inspections.
- 3) Types Corrosion and Deterioration.
- 4) Materials and Fabrication Problems.
- 5) Welding.
- 6) Nondestructive Examination (NDE) Methods
- 7) Corrosion and Minimum Thickness Evaluation.
- 8) Estimated Remaining Life.
- 9) Inspection Interval Determination and Issues Affecting Intervals.
- 10) Inspecting Relief Devices.
- 11) Inspection Safety Practices.
- 12) Inspection Records and Reports.
- 13) Repairs / Alterations.
- 14) Disassembly and Reconstruction.
- 15) Hydro Testing,
- 16) Pneumatic Testing

More information relevant to each of these categories is contained in section "V. PRACTICAL KNOWLEDGE - SPECIFIC" where each reference publication applicable for study for the examination has been listed with the relevant topics that may be covered on the examination.

B. Typical code requirements that candidates will **NOT** be expected to know for purposes of this certification examination.

- 1) Required thickness calculations for wind, earthquake, and small internal pressures
- 2) Nozzle calculations for external loads;
- 3) Flange calculations;
- 4) Brazing requirements;
- 5) Calculating venting requirements;
- 6) Ladder, stairway, and other structural type calculations;
- 7) NDE requirements for acoustic emission, eddy current, and motion radiography per ASME Section V, Article 9
- 8) Technical interpretations of API & ASME Codes and Standards
- 9) Welding process requirements other than shielded metal arc welding (SMAW) and submerged arc welding (SAW)
- 10) API-650, Appendix S
- 11) API-650 Appendix E
- 12) API-650, Appendix R
- 13) API-650, Appendix V
- 14) API-650, Appendix D
- 15) API-650, Appendix P
- 16) API-650, Appendix C
- 17) API-650, Appendix K

## V. PRACTICAL KNOWLEDGE - SPECIFIC

- A. Each reference publication relative to study for the examination is listed below. A list of topics, which may be covered, is listed for each publication. Some topics may be listed under more than one publication. For example; ASME Section IX is the basic document for welding requirements as referenced by API-650 and API-653. The referencing API documents contain additional welding requirements and exceptions or additions to those contained in ASME Section IX. Therefore, welding requirements may be listed under all three documents and all three documents may be listed under the general heading of "Welding on Tanks".

### **API RP 571, Damage Mechanisms Affecting Fixed equipment in the Refining Industry**

ATTN: Inspectors are not required to memorize the definitions of terms included in Section 3 (Definitions of Terms and Abbreviations), but are expected to be familiar with the common terms and abbreviations and be able to find definitions, if needed in the solution of a test question.

Test questions will be based on the following mechanisms only:

- 4.2.7 - Brittle Fracture
- 4.2.16 - Mechanical Fatigue
- 4.3.2 - Atmospheric Corrosion
- 4.3.3 - Corrosion under insulation (CUI)
- 4.3.8 - Microbiologically Induced Corrosion (MIC)
- 4.3.9 - Soil Corrosion
- 4.3.10 - Caustic Corrosion
- 4.5.1 - Chloride Stress Corrosion Cracking (Cl-SCC)
- 4.5.3 - Caustic Stress Corrosion Cracking (Caustic Embrittlement)
- 5.1.11 - Sulfuric Acid Corrosion

### **API Recommended Practice 575, Inspection of Atmospheric and Low-Pressure Storage Tanks**

NOTE: API RP-575 is a Recommended Practice and contains many general statements that are not strict requirements. Some questions on the examination related to RP-575 may contain phrases such as "it is best to" or "an inspector would normally" when information or statements from RP-575 are covered. In these cases it is important to be familiar with the content of RP-575 and to be able to pick the *best* answer of those given. All of RP-575 is applicable to the examination unless specifically excluded.

A. The inspector should have a practical understanding and be familiar with the information contained in RP-575 (excluding Appendix C) as related to:

- 1) types of tanks covered
- 2) procedures to perform internal and external inspection
- 3) the types of external and internal inspections
- 4) procedures to determine suitability for continued service
- 5) evaluation change-of-service effects on suitability for continued service
- 6) evaluation and general condition of:
  - a) distortions, flaws, windgirders, stiffeners, welds, and nozzles
  - b) tank bottoms
  - c) tank foundations
  - d) causes of corrosion, leaks, cracks, and mechanical deterioration
  - e) auxiliary equipment.
  - f) anchor bolts, pipe connections, ground connections
  - g) insulation.

- h) shells and roofs

### **API RP 577, Welding Inspection and Metallurgy**

1. Definitions
2. Welding Inspection
3. Welding Processes
4. Welding procedure
5. Welding Materials
6. Welder qualifications
7. Non-destructive examination
8. Metallurgy
9. Refinery and Petrochemical Plant Welding Issues
10. Terminology and symbols
11. Actions to Address improperly made production welds
12. Welding procedure review
13. Guide to common filler metal selection
14. Example report of RT results

**API Standard 653, Tank Inspection, Repair, Alteration, and Reconstruction**  
*and the related portions of API Standard 650, Welded Steel Tanks for Oil Storage*  
(NOTE: all of API-653 is applicable to the examination unless specifically excluded.)

#### A. Tank Inspection, NDE, and Testing

- 1) The inspector should have a practical understanding and be familiar with the information contained in API-653 related to general inspection practices such as:
  - a) types of tanks covered
  - b) applicable inspection tasks for internal and external inspection (e.g., API Standard 653, Appendix C, Checklist for Tank Inspection).
  - c) safe working practices
  - d) thickness and dimensional measurements and tolerances
  - e) requirements of external and internal inspections
  - f) frequencies and intervals for external and internal inspection
  - g) alternatives to the required internal inspection intervals
  - h) NDE procedures and NDE personnel qualification requirements
  - i) types of roofs and seals and types of deterioration
  - j) reasons for inspection and causes of deterioration of storage tanks
  - k) procedures to check or test storage tanks for leaks
  - l) tools and equipment for tank inspection
  - m) failure assessment and deterioration of auxiliary equipment
  - n) suitability for continued service.
  - o) change-of-service effects on suitability for continued service
  - p) evaluation of tank bottom conditions
  - q) evaluate tank foundation conditions
  - r) risk of failure due to brittle fracture
  - s) evaluate the causes of corrosion, leaks, cracks, and mechanical deterioration.
  - t) evaluate the condition of anchor bolts, pipe connections, ground connections, and insulation

- 2) The inspector should have an understanding and be able to perform calculations related to: (See also previous section on "CALCULATIONS FOR EVALUATING THICKNESS MEASUREMENTS AND TANK INTEGRITY")
  - a) actual and minimum required thickness for shell plates
  - b) maximum allowable fill height
  - c) required thickness for hydrotesting and for elevated temperatures
  - d) evaluation of corroded areas and pits on shell plates
  - e) t min, corrosion rate, inspection interval and remaining corrosion allowance
  - f) distortions, flaws, welds, and nozzles.
  - g) minimum thickness for tank bottoms and annular plate rings and shell rings
  - h) evaluate the effects of tank bottom settlement and acceptable limits
  - i) evaluate the condition of tank shells and roofs.
  - j) weld size at roof-to-shell and bottom-to-shell junctions per design requirements
  
- 3) The inspector should have an understanding of the requirements for performing repairs and alterations such as:
  - a) definitions of repairs and alterations
  - b) repairs to foundations, shell plates, welds, tank bottoms, nozzles & penetrations, roofs, seals,
  - c) knowledge of the repair/alteration material and toughness requirements
  - d) use of unidentified materials for repairs/alterations
  - e) hot tap requirements and procedures
  - f) inspection and NDE requirements for repairs and alterations
  - g) hydrostatic and leak testing requirements
  - h) lap welded patch plates (API-653, 9-3)
  - i) new bottoms supported by grillage API-650, Appendix I, Excluding calculations)
  
- 4) The inspector should have an understanding of the requirements for recording the inspection data and records related to inspection, repairs, and alterations such as:
  - a) nameplate requirements
  - b) record-keeping requirements
  - c) reports for inspection, repair and alterations

**API Recommended Practice 651, *Cathodic Protection of Aboveground Petroleum Storage Tanks***

NOTE: Only Sections 1, 2, 3, 4, 5, 6, 8, and 11 will be covered on the examination.

A. The inspector should have a practical understanding and be familiar with the information contained in RP-651 related to:

- 1) Corrosion of Aboveground Steel Storage Tanks
- 2) Determination of Need for Cathodic Protection
- 3) Methods of Cathodic Protection for Corrosion Control
- 4) Operation and Maintenance of Cathodic Protection Systems

B. Information contained in RP-651 which the inspector will not be examined on:

- 1) design of cathodic protection systems
- 2) sources, detection, and control of interference currents

**API Recommended Practice 652, *Lining of Aboveground Petroleum Storage Tank Bottoms***

A. The inspector should have a practical understanding and be familiar with the information contained in RP-652 related to:

- 1) types of tank bottom linings and advantage and disadvantages of each
- 2) considerations for recommending tank bottom linings
- 3) causes of tank bottom lining failures
- 4) types of tank bottom lining materials
- 5) surface preparation requirements for the installation of tank bottom linings
- 6) issues affecting the application of a tank bottom lining

## Storage Tank Basic Facts

Storage tanks are an essential element in the production, refining, transportation, and marketing of petroleum products. API maintains several documents that address the design, fabrication, operation, inspection, and maintenance of aboveground (AST's) and underground (UST's) storage tanks.

API storage tank standards are developed by committees of experienced tank designers, fabricators, owners, and operators that bring a wealth of accumulated knowledge from their respective companies. Although API standards cover many aspects of AST and UST design and operation, they are not all-inclusive. There are several organizations that publish standards on tank design, fabrication, installation, inspection, and repair that may be more appropriate in some instances than API standards. Please refer to the following organizations for additional requirements and specifications:

- American Society of Mechanical Engineers (ASME) - [www.asme.org](http://www.asme.org)
- American Society for Testing and Materials (ASTM) - [www.astm.org](http://www.astm.org)
- American Water Works Association (AWWA) - [www.awwa.org](http://www.awwa.org)
- Building Officials and Code Administrators International (BOCA) - [www.bocai.org](http://www.bocai.org)
- NACE International (Corrosion Engineers) - [www.nace.org](http://www.nace.org)
- National Fire Protection Association (NFPA) - [www.nfpa.org](http://www.nfpa.org)
- Petroleum Equipment Institute (PEI) - [www.pei.org](http://www.pei.org)
- Steel Tank Institute (STI) - [www.steeltank.com](http://www.steeltank.com)
- Underwriters Laboratories (UL) - [ulstandardsinfontet.ul.com](http://ulstandardsinfontet.ul.com)
- International Fire Code Institute (Uniform Fire Code) - [www.ifci.com](http://www.ifci.com)

## OTHER RESOURCES

[Basis of Seismic Design Provisions for Welded Steel Oil Storage Tanks \(1.3 MB\)](#)

By R. S. Wozniak and W. W. Mitchell, Presented at 43rd API Midyear Refining, May 7, 1978

(To download: Right-click on link and select "Save Target As...")

[USGS Earthquake Hazards Program](#)

The [Independent Liquid Terminals Association](#) - Provides a listing of equipment and services available to the Bulk Liquid Terminals Industry. It's express purpose is to provide terminal and tank farm owners with a quick and easy reference for locating valuable and needed services parts & equipment.

U.S. Environmental Protection Agency TANKS emission estimation software and information.

## STORAGE TANK FAQ'S

**Q:** Where are storage tanks used in the petroleum industry?

**A:** Storage tanks are found in most sectors of the petroleum industry. These include Exploration & Production, Refining, Marketing, and Pipelines.

**Q:** What are the different types of storage tanks?

**A:** Storage tanks can be divided into two basic types: aboveground (AST) and underground (UST). AST's are used in production, refining, marketing, and pipeline operations. UST's are typically used in the marketing of gasoline at retail service stations.

**Q:** What are the most recent editions of API 620, 650, and 653?

**A:** API 620: 10th Edition, February 2002; API 650: 10th Edition, March 1998, including Addenda #1 (2000) and #2 (2001); API 653: 3rd Edition December 2001. More information on past editions can be found at Past Editions of API Tank Design Standards 12C and 650.

**Q:** What are the API standards for construction of new UST's?

**A:** API does not publish standards for construction of UST's. See Underwriters Laboratories UL58, 1316, or 1746, and the Steel Tank Institute's F841-91.

**Q:** What are the API standards for construction of new AST's?

**A:** Spec. 12B, Bolted Tanks for Storage of Production Liquids; Spec. 12D, Field Welded Tanks for Storage of Production Liquids; Spec. 12F, Shop Welded Tanks for Storage of Production Liquids; Spec. 12P, Fiberglass Reinforced Plastic Tanks; API 620, Design and Construction of Large, Welded, Low-Pressure Storage Tanks; API 650, Welded Steel Tanks for Oil Storage.

**Q:** What is the difference between tanks constructed to the API 12 series specifications for production operations and API 650 tanks?

A: Production tanks are usually much smaller than API 650 tanks and are often subject to different operating conditions.

**Q: What size tanks are covered by API refining, marketing, and pipeline standards?**

A: Generally, the minimum size is 1100 gallons (4164 liters). API design standards for AST's in refining, marketing, and pipeline facilities do not specify a maximum size.

**Q: What are the API standards for the inspection and repair of AST's currently in-service?**

A: Spec. 12R1, Setting, Maintenance, Inspection, Operation, and Repair of Tanks in Production Service; API 653, Tanks Inspection, Repair, Alteration, and Reconstruction. You also should consider the Steel Tank Institute's SPO01-00 standard for shop fabricated tanks.

**Q: Does API certify tank manufacturers?**

A: No.

**Q: Does API issue a certificate to verify that a tank has been built to API 620 or 650?**

A: No. The manufacturer is responsible for certifying that the tank has been constructed in accordance with API 650 (see API 650, Section 8.3)

**Q: How do I get my tank certified by API to Standard 620 or 650?**

A: API does not certify tanks built to API 620 and 650. You may see older 650 tanks with an API stamp or monogram, however, the Monogram Program was removed from API 650 with the release of the sixth edition in 1977. The Monogram Program does include tanks built to API Specifications 12B, 12D, and 12F for exploration and production operations..

**Q: Can API provide assistance or consultation on tank design or inspection?**

A: No. API does not act as a consultant on specific engineering problems or on the general application of its standards. API will provide an

interpretation of the requirements in the standard and will address suggested changes based on new data or technology. Please refer to API 620, Appendix J; API 650, Appendix D; or API 653, Appendix E for further information in interpretations.

**Q: Does API provide nameplates for API 650 tanks?**

A: No. The tank manufacturer typically provides the nameplate for a new tank (see API 650, Section 8.1).

**Q: Does API certify companies to do tank repair?**

A: No. API only certifies inspectors to API 653.

**Q: Where can I find an API 653 certified inspector?**

A: A list of companies that employ certified inspectors can be found on the [API Inspector Certification](#) website.

**Q: Does API publish procedures on hydrostatic testing?**


A: Although API 650 and 653 have requirements on when a hydrostatic test must be performed, they do not have detailed procedures on how a hydrostatic test is performed. There is information available in API 650, Appendix S, Section S.4.10 specific to stainless steel tanks. API 620, Section 7.18.4 (Section 5.18.4 in the ninth edition) does have a procedure for low-pressure storage tanks.

**Q: Where can I find a list of technical interpretations?**


A: API Publication 850 is a compilation of interpretations for API standards 620, 650, and 653 from 1987 through 1997. More recent inquiries can be found on the API website.



# WASTE WATER TREATMENT BLOCK FLOW DIAGRAMS




## 1. EXISTING SYSTEM



## 2. MODIFIED SYSTEM

DCJ  
D6-17-96 REV.0



## Chavez, Carl J, EMNRD

---

**From:** Moore, Darrell [Darrell.Moore@hollycorp.com]  
**Sent:** Wednesday, June 29, 2011 2:11 PM  
**To:** Chavez, Carl J, EMNRD; Cobrain, Dave, NMENV  
**Cc:** Monzeglio, Hope, NMENV  
**Subject:** RE: NRS Detailed Area Piping Plan Drawings

Carl

The area we are talking about is the wastewater area. The tanks in that area are waste water tanks so they are not on the tank schedule.

The designation "D" for drum is not really a tank. Its also not a 55 gal drum. Its refinery slang for a steel, welded, process pressure vessel. All the vessels with the "D" designation are on concrete.

---

**From:** Chavez, Carl J, EMNRD [mailto:CarlJ.Chavez@state.nm.us]  
**Sent:** Thursday, June 23, 2011 1:58 PM  
**To:** Moore, Darrell; Cobrain, Dave, NMENV  
**Cc:** Monzeglio, Hope, NMENV  
**Subject:** RE: NRS Detailed Area Piping Plan Drawings

Darrell:

I was also using the tank schedule that Navajo submitted to look for the tank numbers I listed and did not see them on the spreadsheet.

Could you please double check the above grade tank tank inspection schedule spreadsheet to make sure it includes all tanks. Also, and drums that you are using as above ground storage containers, i.e., designation "D" from your past correspondences. The drums could be added into a separate column area on the spreadsheet. Please provide the update by the date the OCD requested that the new tanks be added to the spreadsheet and submitted to the OCD. Thank you.

Carl J. Chavez, CHMM  
New Mexico Energy, Minerals & Natural Resources Dept.  
Oil Conservation Division, Environmental Bureau  
1220 South St. Francis Dr., Santa Fe, New Mexico 87505  
Office: (505) 476-3490  
Fax: (505) 476-3462  
E-mail: CarlJ.Chavez@state.nm.us  
Website: <http://www.emnrd.state.nm.us/ocd/index.htm>  
"Why not Prevent Pollution; Minimize Waste; Reduce the Cost of Operations; & Move Forward with the Rest of the Nation?" To see how, go to "Pollution Prevention & Waste Minimization" at:  
<http://www.emnrd.state.nm.us/ocd/environmental.htm#environmental>)

File: OCD Online "Tank Schedule"

---

**From:** Moore, Darrell [mailto:Darrell.Moore@hollycorp.com]  
**Sent:** Thursday, June 23, 2011 1:25 PM  
**To:** Chavez, Carl J, EMNRD; Cobrain, Dave, NMENV  
**Cc:** Monzeglio, Hope, NMENV  
**Subject:** RE: NRS Detailed Area Piping Plan Drawings

Carl

The only new tanks are TK 829 and TK 830 (plot plan attached) which you approved on May 3, 2011. All the other tanks are already constructed and have been constructed for years. The "Frac Tank" is just a temporary tank that was there when the consultant drew up the plot plan.

The 300 gallon polymer mix tank is part of Veolia's (Formerly ScalTech) process and is on a concrete pad. It too has been there for years.

---

**From:** Chavez, Carl J, EMNRD [mailto:CarlJ.Chavez@state.nm.us]  
**Sent:** Thursday, June 16, 2011 11:19 AM  
**To:** Moore, Darrell; Cobrain, Dave, NMENV  
**Cc:** Monzeglio, Hope, NMENV  
**Subject:** RE: NRS Detailed Area Piping Plan Drawings

Darrell:

The OCD is in receipt of the engineering pipeline drawings for the waste water system. The OCD approved the tank upgrades with conditions on May 3, 2011.

Based on the attached drawings, the new tanks appear to be: Tk-0829, Tk-836, Tk-49 (solvent extraction tank), Frac Tank (Dwg: 80-1-201-D-04), Tk-803, Tk-804, Tk-1, Tk-2, Tk-3, Tk-4, Tk-807,.....

Dwg: 80-1-201-D-02 depicts a 300 GALLON POLYMER MIX TANK, which must also meet the design and construction requirements of the permit.

OCD requests that Navajo provide the listing of all new tanks (which include Frac Tanks?) installed at the facility so the OCD can inspect the locations for compliance with the permit.

Thank you.

File: GW-028: "Inspections" and "Permit Modification" Thumbnails

Carl J. Chavez, CHMM  
New Mexico Energy, Minerals & Natural Resources Dept.  
Oil Conservation Division, Environmental Bureau  
1220 South St. Francis Dr., Santa Fe, New Mexico 87505  
Office: (505) 476-3490  
Fax: (505) 476-3462  
E-mail: CarlJ.Chavez@state.nm.us

Website: <http://www.emnrd.state.nm.us/ocd/index.htm>

"Why not Prevent Pollution; Minimize Waste; Reduce the Cost of Operations; & Move Forward with the Rest of the Nation?" To see how, go to "Pollution Prevention & Waste Minimization" at:

<http://www.emnrd.state.nm.us/ocd/environmental.htm#environmental>)

---

**From:** Moore, Darrell [mailto:Darrell.Moore@hollycorp.com]  
**Sent:** Wednesday, June 15, 2011 9:39 AM  
**To:** Chavez, Carl J, EMNRD; Cobrain, Dave, NMENV  
**Cc:** Monzeglio, Hope, NMENV  
**Subject:** FW: NRS Detailed Area Piping Plan Drawings

Carl, Dave and Hope

Attached, please find detailed piping and other drawings for our upgrade of our Waste Water System. We had sent you the drawings for the tanks for this system a few weeks ago.

---

**From:** Siwek, Janusz  
**Sent:** Thursday, June 09, 2011 9:49 PM

**To:** Moore, Darrell  
**Cc:** McKee, Michael; Meeks, Jimmy; Evans, Jason  
**Subject:** FW: NRS Detailed Area Piping Plan Drawings

---

**From:** Holmes, Don P. [holmesdp@cdm.com]  
**Sent:** Thursday, June 09, 2011 5:18 PM  
**To:** Siwek, Janusz; Cline, Jim; Davis, Gary  
**Cc:** Christiansen, John A.  
**Subject:** NRS Detailed Area Piping Plan Drawings

Please find attached the 16 drawings noted above. These drawings are not complete, but do define where all the equipment is located and how about 85% of the piping is located. These should be useful on your OCD permit request.

Lagenia, Please send an office transmittal to document this and post these drawing on the e-Room. Do not attach these drawings again to the official Transmittal.

Don P. Holmes, P.E.  
Sr. Project Manager  
**CDM, Inc.**  
3050 Post Oak Blvd., Site 300  
Houston, Texas 77056  
direct (713) 423-7318  
Cell (713) 208-6847

---

**CONFIDENTIALITY NOTICE:** This e-mail, and any attachments, may contain information that is privileged, proprietary and/or confidential. If you received this message in error, please advise the sender immediately by reply e-mail and do not retain any paper or electronic copies of this message or any attachments. Unless expressly stated, nothing contained in this message should be construed as a digital or electronic signature or a commitment to a binding agreement.

## Chavez, Carl J, EMNRD

---

**From:** Chavez, Carl J, EMNRD  
**Sent:** Thursday, June 23, 2011 1:58 PM  
**To:** 'Moore, Darrell'; Cobrain, Dave, NMENV  
**Cc:** Monzeglio, Hope, NMENV  
**Subject:** RE: NRS Detailed Area Piping Plan Drawings

Darrell:

I was also using the tank schedule that Navajo submitted to look for the tank numbers I listed and did not see them on the spreadsheet.

Could you please double check the above grade tank tank inspection schedule spreadsheet to make sure it includes all tanks. Also, and drums that you are using as above ground storage containers, i.e., designation "D" from your past correspondences. The drums could be added into a separate column area on the spreadsheet. Please provide the update by the date the OCD requested that the new tanks be added to the spreadsheet and submitted to the OCD. Thank you.

Carl J. Chavez, CHMM  
New Mexico Energy, Minerals & Natural Resources Dept.  
Oil Conservation Division, Environmental Bureau  
1220 South St. Francis Dr., Santa Fe, New Mexico 87505  
Office: (505) 476-3490  
Fax: (505) 476-3462  
E-mail: CarlJ.Chavez@state.nm.us

Website: <http://www.emnrd.state.nm.us/ocd/index.htm>

"Why not Prevent Pollution; Minimize Waste; Reduce the Cost of Operations; & Move Forward with the Rest of the Nation?" To see how, go to "Pollution Prevention & Waste Minimization" at:

<http://www.emnrd.state.nm.us/ocd/environmental.htm#environmental>)

File: OCD Online "Tank Schedule"

---

**From:** Moore, Darrell [mailto:Darrell.Moore@hollycorp.com]  
**Sent:** Thursday, June 23, 2011 1:25 PM  
**To:** Chavez, Carl J, EMNRD; Cobrain, Dave, NMENV  
**Cc:** Monzeglio, Hope, NMENV  
**Subject:** RE: NRS Detailed Area Piping Plan Drawings

Carl

The only new tanks are TK 829 and TK 830 (plot plan attached) which you approved on May 3, 2011. All the other tanks are already constructed and have been constructed for years. The "Frac Tank" is just a temporary tank that was there when the consultant drew up the plot plan.

The 300 gallon polymer mix tank is part of Veolia's (Formerly ScalTech) process and is on a concrete pad. It too has been there for years.

---

**From:** Chavez, Carl J, EMNRD [mailto:CarlJ.Chavez@state.nm.us]  
**Sent:** Thursday, June 16, 2011 11:19 AM  
**To:** Moore, Darrell; Cobrain, Dave, NMENV  
**Cc:** Monzeglio, Hope, NMENV  
**Subject:** RE: NRS Detailed Area Piping Plan Drawings

Darrell:

The OCD is in receipt of the engineering pipeline drawings for the waste water system. The OCD approved the tank upgrades with conditions on May 3, 2011.

Based on the attached drawings, the new tanks appear to be: Tk-0829, Tk-836, Tk-49 (solvent extraction tank), Frac Tank (Dwg: 80-1-201-D-04), Tk-803, Tk-804, Tk-1, Tk-2, Tk-3, Tk-4, Tk-807,.....

Dwg: 80-1-201-D-02 depicts a 300 GALLON POLYMER MIX TANK, which must also meet the design and construction requirements of the permit.

OCD requests that Navajo provide the listing of all new tanks (which include Frac Tanks?) installed at the facility so the OCD can inspect the locations for compliance with the permit.

Thank you.

File: GW-028: "Inspections" and "Permit Modification" Thumbnails

Carl J. Chavez, CHMM  
New Mexico Energy, Minerals & Natural Resources Dept.  
Oil Conservation Division, Environmental Bureau  
1220 South St. Francis Dr., Santa Fe, New Mexico 87505  
Office: (505) 476-3490  
Fax: (505) 476-3462  
E-mail: CarlJ.Chavez@state.nm.us

Website: <http://www.emnrd.state.nm.us/ocd/index.htm>

"Why not Prevent Pollution; Minimize Waste; Reduce the Cost of Operations; & Move Forward with the Rest of the Nation?" To see how, go to "Pollution Prevention & Waste Minimization" at:  
<http://www.emnrd.state.nm.us/ocd/environmental.htm#environmental>

---

**From:** Moore, Darrell [mailto:Darrell.Moore@hollycorp.com]  
**Sent:** Wednesday, June 15, 2011 9:39 AM  
**To:** Chavez, Carl J, EMNRD; Cobrain, Dave, NMENV  
**Cc:** Monzeglio, Hope, NMENV  
**Subject:** FW: NRS Detailed Area Piping Plan Drawings

Carl, Dave and Hope

Attached, please find detailed piping and other drawings for our upgrade of our Waste Water System. We had sent you the drawings for the tanks for this system a few weeks ago.

---

**From:** Siwek, Janusz  
**Sent:** Thursday, June 09, 2011 9:49 PM  
**To:** Moore, Darrell  
**Cc:** McKee, Michael; Meeks, Jimmy; Evans, Jason  
**Subject:** FW: NRS Detailed Area Piping Plan Drawings

---

**From:** Holmes, Don P. [holmesdp@cdm.com]  
**Sent:** Thursday, June 09, 2011 5:18 PM  
**To:** Siwek, Janusz; Cline, Jim; Davis, Gary  
**Cc:** Christiansen, John A.  
**Subject:** NRS Detailed Area Piping Plan Drawings

Please find attached the 16 drawings noted above. These drawings are not complete, but do define where all the equipment is located and how about 85% of the piping is located. These should be useful on your OCD permit request.

Lagenia, Please send an office transmittal to document this and post these drawing on the e-Room. Do not attach these drawings again to the official Transmittal.

Don P. Holmes, P.E.  
Sr. Project Manager  
**CDM, Inc.**  
3050 Post Oak Blvd., Site 300  
Houston, Texas 77056  
direct (713) 423-7318  
Cell (713) 208-6847

---

**CONFIDENTIALITY NOTICE:** This e-mail, and any attachments, may contain information that is privileged, proprietary and/or confidential. If you received this message in error, please advise the sender immediately by reply e-mail and do not retain any paper or electronic copies of this message or any attachments. Unless expressly stated, nothing contained in this message should be construed as a digital or electronic signature or a commitment to a binding agreement.

**Chavez, Carl J, EMNRD**

---

**From:** Chavez, Carl J, EMNRD  
**Sent:** Thursday, June 16, 2011 11:19 AM  
**To:** 'Moore, Darrell'; Cobrain, Dave, NMENV  
**Cc:** Monzeglio, Hope, NMENV  
**Subject:** RE: NRS Detailed Area Piping Plan Drawings

Darrell:

The OCD is in receipt of the engineering pipeline drawings for the waste water system. The OCD approved the tank upgrades with conditions on May 3, 2011.

Based on the attached drawings, the new tanks appear to be: Tk-0829, Tk-836, Tk-49 (solvent extraction tank), Frac Tank (Dwg: 80-1-201-D-04), Tk-803, Tk-804, Tk-1, Tk-2, Tk-3, Tk-4, Tk-807,.....

Dwg: 80-1-201-D-02 depicts a 300 GALLON POLYMER MIX TANK, which must also meet the design and construction requirements of the permit.

OCD requests that Navajo provide the listing of all new tanks (which include Frac Tanks?) installed at the facility so the OCD can inspect the locations for compliance with the permit.

Thank you.

File: GW-028: "Inspections" and "Permit Modification" Thumbnails

Carl J. Chavez, CHMM  
New Mexico Energy, Minerals & Natural Resources Dept.  
Oil Conservation Division, Environmental Bureau  
1220 South St. Francis Dr., Santa Fe, New Mexico 87505  
Office: (505) 476-3490  
Fax: (505) 476-3462  
E-mail: CarlJ.Chavez@state.nm.us

Website: <http://www.emnrd.state.nm.us/ocd/index.htm>

"Why not Prevent Pollution; Minimize Waste; Reduce the Cost of Operations; & Move Forward with the Rest of the Nation?" To see how, go to "Pollution Prevention & Waste Minimization" at:

<http://www.emnrd.state.nm.us/ocd/environmental.htm#environmental>)

---

**From:** Moore, Darrell [<mailto:Darrell.Moore@hollycorp.com>]  
**Sent:** Wednesday, June 15, 2011 9:39 AM  
**To:** Chavez, Carl J, EMNRD; Cobrain, Dave, NMENV  
**Cc:** Monzeglio, Hope, NMENV  
**Subject:** FW: NRS Detailed Area Piping Plan Drawings

Carl, Dave and Hope

Attached, please find detailed piping and other drawings for our upgrade of our Waste Water System. We had sent you the drawings for the tanks for this system a few weeks ago.

---

**From:** Siwek, Janusz  
**Sent:** Thursday, June 09, 2011 9:49 PM  
**To:** Moore, Darrell  
**Cc:** McKee, Michael; Meeks, Jimmy; Evans, Jason  
**Subject:** FW: NRS Detailed Area Piping Plan Drawings

---

**From:** Holmes, Don P. [holmesdp@cdm.com]  
**Sent:** Thursday, June 09, 2011 5:18 PM  
**To:** Siwek, Janusz; Cline, Jim; Davis, Gary  
**Cc:** Christiansen, John A.  
**Subject:** NRS Detailed Area Piping Plan Drawings

Please find attached the 16 drawings noted above. These drawings are not complete, but do define where all the equipment is located and how about 85% of the piping is located. These should be useful on your OCD permit request.

Lagenia, Please send an office transmittal to document this and post these drawing on the e-Room. Do not attach these drawings again to the official Transmittal.

Don P. Holmes, P.E.  
Sr. Project Manager  
**CDM, Inc.**  
3050 Post Oak Blvd., Site 300  
Houston, Texas 77056  
direct (713) 423-7318  
Cell (713) 208-6847

---

**CONFIDENTIALITY NOTICE:** This e-mail, and any attachments, may contain information that is privileged, proprietary and/or confidential. If you received this message in error, please advise the sender immediately by reply e-mail and do not retain any paper or electronic copies of this message or any attachments. Unless expressly stated, nothing contained in this message should be construed as a digital or electronic signature or a commitment to a binding agreement.



## Chavez, Carl J, EMNRD

---

**From:** Chavez, Carl J, EMNRD  
**Sent:** Friday, June 10, 2011 10:42 AM  
**To:** Monzeglio, Hope, NMENV; Moore, Darrell  
**Cc:** Cobrain, Dave, NMENV; Tsinnajinnie, Leona, NMENV; Lackey, Johnny  
**Subject:** RE: NCL Tank 815

Yeah, the OCD DP requires fluids not to be allowed to pool for 72 hours before evacuation I believe....

NMED confirmed that it is precipitation and city water that is pooling and would not be tainted with any contaminants from that area and/or addressed by evaporation and phyto remediation anyway.....

So, if the refinery addresses this permit issue, OCD is ok.

Carl J. Chavez, CHMM  
New Mexico Energy, Minerals & Natural Resources Dept.  
Oil Conservation Division, Environmental Bureau  
1220 South St. Francis Dr., Santa Fe, New Mexico 87505  
Office: (505) 476-3490  
Fax: (505) 476-3462  
E-mail: CarlJ.Chavez@state.nm.us

Website: <http://www.emnrd.state.nm.us/ocd/index.htm>

"Why not Prevent Pollution; Minimize Waste; Reduce the Cost of Operations; & Move Forward with the Rest of the Nation?" To see how, go to "Pollution Prevention & Waste Minimization" at:  
<http://www.emnrd.state.nm.us/ocd/environmental.htm#environmental>)

---

**From:** Monzeglio, Hope, NMENV  
**Sent:** Friday, June 10, 2011 10:35 AM  
**To:** Moore, Darrell  
**Cc:** Cobrain, Dave, NMENV; Tsinnajinnie, Leona, NMENV; Lackey, Johnny; Chavez, Carl J, EMNRD  
**Subject:** RE: NCL

Darrell

NMED does not object with managing the water as described below. NMED also spoke with OCD who also does not foresee any issue with this.

Hope

---

**From:** Moore, Darrell [<mailto:Darrell.Moore@hollycorp.com>]  
**Sent:** Monday, June 06, 2011 4:02 PM  
**To:** Monzeglio, Hope, NMENV  
**Cc:** Cobrain, Dave, NMENV; Tsinnajinnie, Leona, NMENV; Lackey, Johnny  
**Subject:** RE: NCL

Hope

Attached, please find an aerial photo of the NCL. I have added a general drawing of what we would like to add to the East berm of the landfarm. As you know, water pools up on the east side of the landfarm. We would add two pipes (with valves) thru the dike that would allow us to drain the water into the dike area of Tk 815 where it could evaporate. If the water got to be too much we would send our vacuum truck and suck it up and put it thru our Waste Water treatment system.

It's a pretty simple fix and we think it would work very well.

---

**From:** Monzeglio, Hope, NMENV [<mailto:hope.monzeglio@state.nm.us>]  
**Sent:** Monday, June 06, 2011 9:09 AM  
**To:** Moore, Darrell  
**Cc:** Cobrain, Dave, NMENV; Tsinnajinnie, Leona, NMENV; Lackey, Johnny  
**Subject:** NCL

Darrell

See attached emails. Please update me on the status of the NCL survey plat and details to address the vegetation by **Friday June 10, 2011**. Navajo must seek NMED approval before changes can be made to the vegetative cover on the NCL.

Let me know if you have any questions.

Hope

Hope Monzeglio Petrie  
Environmental Specialist  
New Mexico Environment Department  
Hazardous Waste Bureau  
2905 Rodeo Park Drive East, BLDG 1  
Santa Fe NM 87505  
Phone: (505) 476-6045; Main No.: (505)-476-6000  
Fax: (505)-476-6060  
[hope.monzeglio@state.nm.us](mailto:hope.monzeglio@state.nm.us)

**Websites:**

**[New Mexico Environment Department](#)**  
**[Hazardous Waste Bureau](#)**

---

**CONFIDENTIALITY NOTICE:** This e-mail, and any attachments, may contain information that is privileged, proprietary and/or confidential. If you received this message in error, please advise the sender immediately by reply e-mail and do not retain any paper or electronic copies of this message or any attachments. Unless expressly stated, nothing contained in this message should be construed as a digital or electronic signature or a commitment to a binding agreement.

## Chavez, Carl J, EMNRD

---

**From:** Chavez, Carl J, EMNRD  
**Sent:** Tuesday, May 03, 2011 1:57 PM  
**To:** 'Moore, Darrell'; Monzeglio, Hope, NMENV  
**Cc:** Lackey, Johnny; Siwek, Janusz; Davis, Gary; Dade, Randy, EMNRD  
**Subject:** RE: Navajo Refining Company, Artesia Refinery (GW-028) Tank Drawings for Waste Water Tank Upgrades

Darrell et al.:

Good afternoon.

Approved with the conditions specified in the OCD Discharge Permit provided below. Navajo Refining Company shall provide an updated spreadsheet with tank specifications, info., etc., and tank diagram of tanks with identification numbers for the tank integrity program within 3 months of tank construction.

Please provide at least 72 hours advance notice of tank construction schedule so the agencies may witness the construction of the liner system, concrete ring, leak detection system, etc. You may recall the tank ring that developed cracks because the tank was not centered in the middle of the concrete ring; consequently, I'm sure the construction will ensure that the tank circumference is centered on the tank ring for the construction. Also, the OCD observes that liner specifications were not provided in the engineering diagrams. The discharge permit requires LLDPE; however, if HDPE is used, in order to overcome its stress crack nature, the mil thickness must be increased to a minimum of 60-mil. The OCD expects the liner to be properly tied into the tank ring structure beneath the tank and the liner seams to be properly tested to ensure a good seal exists during and after construction.

Per Section 9 of the Discharge Permit:

### **9. Above Ground Tanks:**

All new and existing above ground tanks containing chemicals must be placed or retrofitted over an impermeable pad (40-mil LLDPE reinforced liner with leak detection system) or liner system within a bermed secondary containment area approved by the OCD. The bermed areas shall be constructed to contain a volume of at least one and one-third (1+1/3) greater than the total volume of the largest tank and/or all interconnected tanks within a bermed containment area. Alternative secondary containment designs must be approved by the OCD.

The owner/operator shall submit a spreadsheet or table identifying all tanks with a work schedule to address this provision (Tank ID #, type of tank, new/used, volume, chemical stored, tank age, last integrity test date, planned retrofit date and/or construction date, etc.) to the OCD for approval. The owner operator shall prioritize existing tanks for retrofit based on the toxicity and solubility (contaminant transport potential) of chemicals (BTEX, JP4, etc.) and site-specific threats to public health, safety, fresh water, and the environment. A work schedule with a phased approach extending beyond the standard 5-Year permit period may be approved by the OCD if the table is submitted within 3 months of permit issuance. The table(s) shall be considered approved if the OCD does not respond within 30 days of receipt of the table and work schedule.

Please contact me if you have questions. Thank you.

Carl J. Chavez, CHMM  
New Mexico Energy, Minerals & Natural Resources Dept.  
Oil Conservation Division, Environmental Bureau  
1220 South St. Francis Dr., Santa Fe, New Mexico 87505  
Office: (505) 476-3490  
Fax: (505) 476-3462  
E-mail: CarlJ.Chavez@state.nm.us  
Website: <http://www.emnrd.state.nm.us/oed/index.htm>

"Why not Prevent Pollution; Minimize Waste; Reduce the Cost of Operations; & Move Forward with the Rest of the Nation?" To see how, go to "Pollution Prevention & Waste Minimization" at: <http://www.emnrd.state.nm.us/oed/environmental.htm#environmental>

**From:** Moore, Darrell [mailto:Darrell.Moore@hollycorp.com]  
**Sent:** Tuesday, May 03, 2011 11:02 AM  
**To:** Chavez, Carl J, EMNRD; Monzeglio, Hope, NMENV  
**Cc:** Lackey, Johnny; Siwek, Janusz; Davis, Gary  
**Subject:** Tank Drawings for Waste Water Upgrade

Carl and Hope

Attached are drawings for two tanks that we will be building as part of our Waste Water System Upgrade. This project was discussed at the meeting we held in Santa Fe at OCD's offices in March, 2011. We are asking for approval to build these tanks. They are located just north of current waste water tank 836 and will have a liner under each tank with PVC Tattle Tales thru the ring wall to detect any leaks.

If you have any questions, please contact me at 575-746-5281. We would like to start construction by the end of this week if possible. Your attention to this matter is greatly appreciated.

Darrell Moore  
Environmental Manager for Water and Waste  
Navajo Refining Company, LLC  
Phone Number 575-746-5281  
Cell Number 575-703-5058  
Fax Number 575-746-5451

**CONFIDENTIAL**

This e-mail message and all corresponding e-mail messages, including all attachments, are intended solely for the individual(s) named above. They contain confidential and/or proprietary information. Do not forward, copy, distribute or otherwise relay the messages or their content to any individual without first contacting the sender of this message. If you have received this e-mail message in error, do not read, forward, copy or distribute it or any of its content to anyone. In addition, please notify the sender that you have received this message immediately by return e-mail and delete it.



Please consider the environment before printing this e-mail.

---

**CONFIDENTIALITY NOTICE:** This e-mail, and any attachments, may contain information that is privileged, proprietary and/or confidential. If you received this message in error, please advise the sender immediately by reply e-mail and do not retain any paper or electronic copies of this message or any attachments. Unless expressly stated, nothing contained in this message should be construed as a digital or electronic signature or a commitment to a binding agreement.

## Chavez, Carl J, EMNRD

---

**From:** Moore, Darrell [Darrell.Moore@hollycorp.com]  
**Sent:** Tuesday, May 03, 2011 11:02 AM  
**To:** Chavez, Carl J, EMNRD; Monzeglio, Hope, NMENV  
**Cc:** Lackey, Johnny; Siwek, Janusz; Davis, Gary  
**Subject:** Tank Drawings for Waste Water Upgrade  
**Attachments:** T829 Ringwall FDN.PDF; T-0830 RING WALL FDN.PDF; Plots Tanks Location.pdf

Carl and Hope

Attached are drawings for two tanks that we will be building as part of our Waste Water System Upgrade. This project was discussed at the meeting we held in Santa Fe at OCD's offices in March, 2011. We are asking for approval to build these tanks. They are located just north of current waste water tank 836 and will have a liner under each tank with PVC Tattle Tales thru the ring wall to detect any leaks.

If you have any questions, please contact me at 575-746-5281. We would like to start construction by the end of this week if possible. Your attention to this matter is greatly appreciated.

Darrell Moore  
Environmental Manager for Water and Waste  
Navajo Refining Company, LLC  
Phone Number 575-746-5281  
Cell Number 575-703-5058  
Fax Number 575-746-5451

### CONFIDENTIAL

This e-mail message and all corresponding e-mail messages, including all attachments, are intended solely for the individual(s) named above. They contain confidential and/or proprietary information. Do not forward, copy, distribute or otherwise relay the messages or their content to any individual without first contacting the sender of this message. If you have received this e-mail message in error, do not read, forward, copy or distribute it or any of its content to anyone. In addition, please notify the sender that you have received this message immediately by return e-mail and delete it.



Please consider the environment before printing this e-mail.

---

**CONFIDENTIALITY NOTICE:** This e-mail, and any attachments, may contain information that is privileged, proprietary and/or confidential. If you received this message in error, please advise the sender immediately by reply e-mail and do not retain any paper or electronic copies of this message or any attachments. Unless expressly stated, nothing contained in this message should be construed as a digital or electronic signature or a commitment to a binding agreement.







DRUM STORAGE & RINSE DIAGRAM








DRAWING LIMITS N.13+00'-0" - NO CONTINUATION

DRAWING LIMITS E.10+00'-0" - NO CONTINUATION

DRAWING LIMITS E.5+00'-0" - NO CONTINUATION



DRAWING LIMITS N.23+00'-0" - NO CONTINUATION

T-0829 = N. 18+20'-0" E. 8+51'-0" Bottom of tank EL. 99'-0"  
 T-0830 = N. 19+95'-0" E. 8+51'-0" Bottom of tank EL. 99'-0"

NOTES

REFERENCE DRAWINGS


NO.	REVISIONS	BY	CHK	DATE	APP	NO.	REVISIONS	BY	CHK	DATE	APP

DRAWING TITLE  
 PLOT PLAN

**KAYE ENGINEERING CO.**  
 CONSULTING ENGINEERS  
 1100 CHERRY ST.  
 SUITE 100  
 DENVER, CO 80202

DATE: 04-13-11  
 SCALE: 1"=30'-0"

H:\CADD\207 Ramp Station - WPT\Support\Engineering\Substation\WPT\WPT-UPGRADE\SITE PLAN Rev 2.dwg, 04/20/11 10:33:53 AM, Dallas



T-0829 = N. 18+20'-0", E. 8+51'-0", Bottom of tank EL. 99'-0"  
 T-0830 = N. 19+95'-0", E. 8+51'-0", Bottom of tank EL. 99'-0"

DRAWING LIMITS E.6+80'-0" - NO CONTINUATION

DRAWING LIMITS E.9+80'-0" - NO CONTINUATION

DRAWING LIMITS N.19+00'-0" - NO CONTINUATION



NO.	DATE	BY	CHKD.	DESCRIPTION
1	01/11/11	DMJ	DMJ	ISSUED FOR REVISION
2	01/11/11	DMJ	DMJ	ISSUED FOR REVISION
3	01/11/11	DMJ	DMJ	ISSUED FOR REVISION
4	01/11/11	DMJ	DMJ	ISSUED FOR REVISION
5	01/11/11	DMJ	DMJ	ISSUED FOR REVISION
6	01/11/11	DMJ	DMJ	ISSUED FOR REVISION
7	01/11/11	DMJ	DMJ	ISSUED FOR REVISION
8	01/11/11	DMJ	DMJ	ISSUED FOR REVISION
9	01/11/11	DMJ	DMJ	ISSUED FOR REVISION
10	01/11/11	DMJ	DMJ	ISSUED FOR REVISION

NOTE:  
 1. THE STATION POINT IS THE HEAD OF A CUTTER ANGLE WITH AN URANGE STRING ATTACHED.  
 2. THE BENCH MARK IS LOCATED 2'-2 1/2' EAST OF A MARK ON THE ATLAS COPCO SLAB AND UNDER GRAVEL.  
 3. THE BENCH MARK IS LOCATED 3'-2 1/2' EAST OF A MARK ON AREA PAVING 7'-6 1/2' SOUTH OF CONTAINMENT WALL.  
 4. THE BENCH MARK IS LOCATED 3'-2 1/2' EAST OF A MARK ON AREA PAVING 7'-6 1/2' SOUTH OF CONTAINMENT WALL.

CDM  
 CONSULTING ENGINEERS  
 10000 W. CENTRAL EXPRESSWAY  
 SUITE 200  
 DALLAS, TEXAS 75243  
 PHONE: 972.968.6000  
 FAX: 972.968.6001  
 WWW.CDM.COM

PROJECT NO. 0633-79019  
 SHEET NO.

NAVJO REFINERY  
 ARTESIA NEW MEXICO  
 PHASE 1 WWTP

CDM  
 CONSULTING ENGINEERS  
 10000 W. CENTRAL EXPRESSWAY  
 SUITE 200  
 DALLAS, TEXAS 75243  
 PHONE: 972.968.6000  
 FAX: 972.968.6001  
 WWW.CDM.COM

NO.	DATE	BY	CHKD.	DESCRIPTION
1	01/11/11	DMJ	DMJ	ISSUED FOR REVISION
2	01/11/11	DMJ	DMJ	ISSUED FOR REVISION
3	01/11/11	DMJ	DMJ	ISSUED FOR REVISION
4	01/11/11	DMJ	DMJ	ISSUED FOR REVISION
5	01/11/11	DMJ	DMJ	ISSUED FOR REVISION
6	01/11/11	DMJ	DMJ	ISSUED FOR REVISION
7	01/11/11	DMJ	DMJ	ISSUED FOR REVISION
8	01/11/11	DMJ	DMJ	ISSUED FOR REVISION
9	01/11/11	DMJ	DMJ	ISSUED FOR REVISION
10	01/11/11	DMJ	DMJ	ISSUED FOR REVISION

DATE: MAR 20, 2011 3:05pm PROJECT: ARTESIA REFINERY - WWTP Upgrade/Phase 1  
 USER: D:\dmj\dmj\work\1757-5117.dwg  
 DATE: 02-22-2011 10:52 AM  
 PROJECT NO. 0633-79019  
 SHEET NO. 10 OF 10




DRUM STORAGE & RINSE DIAGRAM

SEE DWG 55-Z-32-D-15

MATCHLINE DWG. 55-Z-31-D-29  
 MATCHLINE DWG. 55-Z-31-D-32  
 MATCHLINE DWG. 55-Z-31-D-33

SEE DWG 55-Z-32-D-12



DRAWING TITLE		BY		CHECKED		DATE		NO.		REVISIONS		DATE		BY		CHECKED		DATE		NO.		REVISIONS		DATE		BY		CHECKED		DATE	
PLOT PLAN		C.A.C.		C.A.C.		11/1/80		1																							
UNDERGROUND SEWER PIPING		C.A.C.		C.A.C.		11/1/80		1																							
WWT/API SEPARATOR AREA		C.A.C.		C.A.C.		11/1/80		1																							

**MILVIO BEVING CO.**  
 ENGINEERS, ARCHITECTS, PLANNERS  
 10000 W. 10TH AVE., SUITE 100  
 ARDEN, NEB 68002

DATE: 11/1/80  
 DRAWN BY: C.A.C.  
 CHECKED BY: C.A.C.  
 PROJECT NUMBER: 55-Z-32-D-1310

NOTES

REFERENCE DRAWINGS



Praxair Services, Inc.

3755 N. Business Center Drive  
Tucson, Arizona 85705  
Toll Free (800) 989-9929  
Tel: (520) 888-9400  
Fax: (520) 293-1306

***Tracer Tight® Leak Test***

10 Above Ground Storage Tanks

Navajo Artesia Refinery  
501 E. Main St.  
Artesia, NM 88210

Praxair Job No. 10152753

Prepared for:  
Navajo Artesia Refinery

Jeff Schmidlen

501 E. Main St.  
Artesia NM 88210  
Tel: (575) 746-5310

Submitted by:

Praxair Services, Inc.  
Alan Harris – Commercial Operations Manager

A handwritten signature in cursive script that reads "Alan Harris".

---

E-Mail: [alan\\_harris@praxair.com](mailto:alan_harris@praxair.com)  
Website: <http://www.praxair.com/services>

Site Location: Navajo Artesia Refinery

Praxair Job No.: 10152753

**Inoculation Information:**

	<b>Inoculation:</b>	<b>Sampling:</b>
<b>Start Date:</b>	August 18, 2009	August 14, 2009
<b>Completion Date:</b>	Sept 21, 2009	Sept 24, 2009
	<b>Job Completion Date:</b>	<b>Sept 25, 2009</b>

Notes:

**Annual Testing Results:**

Facility:	System:	Type:	Diameter:	Product:	Tracer:	Result:	
Navajo Artesia Refinery	Tank 108	AST	67'	Alky (H)	A	Pass	
Navajo Artesia Refinery	Tank 411	AST	90'	Casinghead	A	Pass	
Navajo Artesia Refinery	Tank 415	AST	67'	Alky (L)	A	Pass	
Navajo Artesia Refinery	Tank 450	AST	120'	Naphtha (S)	A	Pass	
Navajo Artesia Refinery	Tank 11	AST	90'	Reformate	A	Pass	
Navajo Artesia Refinery	Tank 12	AST	90'	Reformate	A	Pass	
Navajo Artesia Refinery	Tank 106	AST	67'	Slop Diesel	A	Pass	
Navajo Artesia Refinery	Tank 107	AST	67'	Casinghead	A	Pass	
Navajo Artesia Refinery	Tank 109	AST	67'	Alky (H)	A	Pass	
Navajo Artesia Refinery	Tank 117	AST	50'	Naphtha (H)	A	Pass	



Alan Harris- Commercial Operational Manager  
Date: 09/25/09

Praxair Services, Inc. hereby certifies that the above listed systems(s) have been tested by means of Tracer Tight<sup>®</sup>, which has been evaluated by a third party according to protocols issued and approved by the United States Environmental Protection Agency (EPA) as being able to detect a leak at a rate of 0.05 gallons per hour with a Probability of Detection (PD) of 0.97 and a Probability of False Alarm (PFA) of 0.029. If you have any questions or concerns, please call Praxair Services, Inc. at 800-989-9929 ext.232.



3755 N. Business Center Drive  
Tucson, Arizona 85705  
Toll Free (800) 989-9929  
Tel: (520) 888-9400  
Fax: (520) 293-1306

## ***Tracer Tight® Leak Test***

March 2008 Testing

Three Aboveground Storage Tanks  
**Terminal**  
City, ST

Praxair Job No. 10000000

### **Prepared for:**

Client  
1111 Business Street  
City, ST 11111

Tel: 512-555-1111

Attention: First Last Name

### **Submitted by:**

Praxair Services, Inc.  
Project Manager

---

**E-Mail:** [Todd\\_Waltz @ Praxair.com](mailto:Todd_Waltz@Praxair.com)  
**Website:** <http://www.praxair.com/services>

**UCISCO**

Industrial Gas Services

Pipeline Services

Mechanical Cleaning Services

**Tracer Research**

Leak Detection Services

Environmental Sampling Services

**Corrocon**

Cathodic Protection Services

Environmental Directional Drilling

Site Location: Terminal

Praxair Job No.: 111xxx111

**Inoculation and Sampling Information:**

	<b>Inoculation:</b>	<b>Sampling:</b>
<b>Start Date:</b>	Month 6, 2008	Month 6, 2008
<b>Completion Date:</b>	Month 13, 2008	Month 13, 2008
	<b>Job Completion Date:</b>	<b>Month 13, 2008</b>

**Testing Results:**

<b>Facility:</b>	<b>System:</b>	<b>Type:</b>	<b>Diameter:</b>	<b>Product:</b>	<b>Tracer:</b>	<b>Result:</b>	
BP	Tank 1	AST	50 ft	Diesel	A	Passed	
BP	Tank 3	AST	50 ft	Diesel	A	Passed	
BP	Tank 7	AST	65 ft	Unleaded Gasoline	A	Passed	

**- Project Manager**

**Date: MO/26/2008**

Praxair Services, Inc. hereby certifies that the above listed systems(s) have been tested by means of Tracer Tight<sup>®</sup>, which has been evaluated by a third party according to protocols issued and approved by the United States Environmental Protection Agency (EPA) as being able to detect a leak at a rate of 0.05 gallons per hour with a Probability of Detection (PD) of 0.97 and a Probability of False Alarm (PFA) of 0.029. Tracer concentrations are report in micrograms per liter (ug/L). The Tracer Tight<sup>®</sup> non-volume metric test and does not report in gallons per hour. If you have any questions or concerns, please call Praxair Services, Inc. at 800-989-9929 ext.234.

## Chavez, Carl J, EMNRD

---

**From:** Chavez, Carl J, EMNRD  
**Sent:** Friday, September 03, 2010 7:51 AM  
**To:** 'Moore, Darrell'; 'Lackey, Johnny'  
**Cc:** Dade, Randy, EMNRD; Hill, Larry, EMNRD; VonGonten, Glenn, EMNRD  
**Subject:** Artesia (GW-028) and Lovington (GW-014) Refineries and Praxair Services, Inc. (Praxair) Report(s) Request

Darrell and Johnny:

Good morning. OCD is writing to request all Praxair reports associated with services rendered at the above refineries after the current discharge permits were issued at each facility. Please submit the reports by Tuesday, COB October. 5, 2010.

Also, please make OCD aware of any major discoveries from the Praxair investigations. OCD notices that the February 2010 discovery of a small leak at T-413 from the Praxair method and this may help provide proof that the method is effective.

Please contact me if you have questions. Thank you.

Carl J. Chavez, CHMM  
New Mexico Energy, Minerals & Natural Resources Dept.  
Oil Conservation Division, Environmental Bureau  
1220 South St. Francis Dr., Santa Fe, New Mexico 87505  
Office: (505) 476-3490  
Fax: (505) 476-3462  
E-mail: [CarlJ.Chavez@state.nm.us](mailto:CarlJ.Chavez@state.nm.us)  
Website: <http://www.emnrd.state.nm.us/ocd/index.htm>  
(Pollution Prevention Guidance is under "Publications")



# REFINING COMPANY, LLC

FAX  
(575) 746-5283 DIV. ORDERS  
(575) 746-5481 TRUCKING  
(575) 746-5458 PERSONNEL

2009 JAN 15 PM 1 18

501 EAST MAIN STREET • P. O. BOX 159  
ARTESIA, NEW MEXICO 88211-0159  
TELEPHONE (575) 748-3311

FAX  
(575) 746-5419 ACCOUNTING  
(575) 746-5451 ENV/PURCH/MKTG  
(575) 746-5421 ENGINEERING

January 14, 2009

FedEx Overnight Delivery

Wayne Price  
Environmental Bureau Chief  
Oil Conservation Division  
1220 South St. Francis Drive  
Santa Fe, NM 87505

**Re: Navajo Refining Company, L.L.C., Discharge Permit (GW-028) Proposals**

Dear Mr. Price:

Enclosed pursuant to your August 20, 2008 letter to Darrell Moore regarding the Navajo Refining Company-Artesia Refinery (GW-028) Discharge Permit Approval are the required schedules, drawings and plot plans as follows:

Attachment 1: Drum Storage Site Diagram. (GW-028, Section 7).

Attachment 2: Above Ground Tanks, Leak Detection Retrofit Schedule for OCD approval. (GW-028, Section 9).

Attachment 3: Sanitary Waste Water Proposal for OCD approval. (GW-028, Section 17 iv).

Attachment 4: Underground Process/Wastewater Lines listing. (GW-028, Section 13A).

Attachment 5: Underground tanks sumps, pits. (GW-028, Section 21C).

Please contact me at 575-746-5490 or Darrell Moore at 575-746-5281 if you have any questions.

Sincerely,

Johnny Lackey  
Environmental Manager

Attachments

Cc (w/attachments):

Navajo Refining: JER  
OCD: Carl Chavez, 1220 South St. Francis Dr., Santa Fe, NM 87505

Electronic cc (w/attachments):  
Environmental Files:

DGM  
REF.ART.08-4.E.03  
(Artesia Discharge Permit)

# **Attachment 1**



DRUM STORAGE

RINSE AREA

RINSE AREA

DRUM STORAGE & RINSE DIAGRAM

U S HWY 82

U S HWY 285

EAST 5TH STREET

A5 20601 36

ADAMS DRIVE

HOSELEY AVENUE

CHISUM AVENUE

TEXAS AVENUE

EAST 5TH STREET

FREDMAN AVENUE

FREDMAN AVENUE

U S HWY 82

TEXAS AVENUE

CHISUM AVENUE

MAHNE DRIVE

YUCCA AVENUE

FAIRVIEW AVENUE

DOG EAR AVENUE

CANNON AVENUE

LOGAN AVENUE

U S HWY 285

HOSELEY AVENUE

402

401

112

111

109

108

107

115

412

411

114

113

403

404

405

406

407

408

409

430

431

432

433

434

435

436

437

438

439

440

441

442

443

444

445

446

447

448

450

451

452

453

454

455

456

457

458

459

460

461

462

463

464

465

466

467

468

469

470

471

472

473

474

475

476

477

478

479

480

481

482

483

484

485

486

487

488

489

490

491

492

493

494

495

496

497

498

499

500

501

502

503

504

505

506

507

508

509

510

511

512

513

514

515

516

517

518

519

520

521

522

523

524

525

526

527

528

529

530

531

532

533

534

535

536

537

538

539

540

541

542

543

544

545

546

547

548

549

550

551

552

553

554

555

556

557

558

559

560

561

562

563

564

565

566

567

568

569

570

571

572

573

574

575

576

577

578

579

580

581

582

583

584

585

586

587

588

589

590

591

592

593

594

595

596

597

598

599

600

601

602

603

604

605

606

607

608

609

610

611

612

613

614

615

616

617

618

619

620

621

622

623

624

625

626

627

628

629

630

631

632

633

634

635

636

637

638

639

640

641

642

643

644

645

646

647

648

649

650

651

652

653

654

655

656

657

658

659

660

661

662

663

664

665

666

667

668

669

670

671

672

673

674

675

676

677

678

679

680

681

682

683

684

685

686

687

688

689

690

691

692

693

694

695

696

697

698

699

700

701

702

703

704

705

706

707

708

709

710

711

712

713

714

715

## **Attachment 2**



## **Attachment 3**

## ATTACHMENT 3, January 2009

### Navajo Refining Company

Navajo Refinery in Artesia New Mexico currently has five operating areas separated by geographic area. With the current refinery expansion, a sixth operating area will be added in 2009 to accommodate new process units. Each of the operating areas includes both DCS (i.e. Control Board) and Field Operators. Current and future operating areas are listed below:

1. CCR Area:
2. FCC Area
3. North Plant (NP) Area
4. South Plant (SP) Area
5. Oil Movements Area
6. MHC Area (Pending completion of refinery expansion)

Within the existing operating areas there are eight (8) septic holding tanks in various stages of service. For the holding tanks that are in service, the practice is to empty the tanks via vacuum truck and haul the waste material to a septic waste handling facility. The tanks have been used primarily to service field operating crews while performing duties in and around several buildings provided for environmental shelter. The following are the locations / descriptions of the existing holding tanks and their current status. Please refer to attached aerial photograph drawing:

EXISTING ENVIRONMENTAL SHELTERS WITH HOLDING TANKS			
No.	Location	Current Operator Service	Holding Tank Status
1	Central Control Room	<ul style="list-style-type: none"><li>• FCC, NP and CCR DCS Operators</li><li>• CCR Field Operators</li></ul>	In Service
2	FCC Operator Shelter	<ul style="list-style-type: none"><li>• FCC Field Operators</li></ul>	In Service
3	Pipeline Office Building	<ul style="list-style-type: none"><li>• NP Field Operators</li><li>• Supervisor Offices</li></ul>	In Service
4	North Plant Operator Shelter	<ul style="list-style-type: none"><li>• North Plant Tool and Supply Storage</li></ul>	In Service
5	Blender Control Room	<ul style="list-style-type: none"><li>• Oil Movement DCS Operators</li><li>• Oil Movement Field Operators</li></ul>	In Service
6	TCC Operator Shelter	<ul style="list-style-type: none"><li>• South Plant Tool and Supply Storage</li></ul>	Out of Service
7	South Plant Control Room	<ul style="list-style-type: none"><li>• South Plant DCS Operators</li><li>• South Plant Field Operators</li></ul>	In Service
8	Old South Plant Control Room	<ul style="list-style-type: none"><li>• South Plant Tool and Supply Storage</li></ul>	Out of Service

Navajo is currently in the engineering phase to add new environmental shelters and reconfigure utilization of existing buildings to accommodate refinery expansion and addition of the new MHC operating area. The

overall plan will include installation of 2 new buildings thereby providing environmental shelters for all field operating personnel. Upon completion of the project, use of the septic holding tanks will be discontinued. The following table describes the future services for the new and existing shelters and the future status of the septic holding tanks:

<b>FUTURE ENVIRONMENTAL SHELTER CONFIGURATION</b>			
<b>No.</b>	<b>Location</b>	<b>Future Operator Service</b>	<b>Holding Tank Status</b>
1	Central Control Room	<ul style="list-style-type: none"> <li>• FCC, NP, CCR, and MHC DCS Operators</li> <li>• FCC, CCR Field Operators</li> </ul>	Out of Service
2	FCC Operator Shelter	<ul style="list-style-type: none"> <li>• FCC Tool and Supply Storage</li> </ul>	Out of Service
3	Pipeline Office Building	<ul style="list-style-type: none"> <li>• General Storage</li> </ul>	Out of Service
4	North Plant Operator Shelter	<ul style="list-style-type: none"> <li>• NP Tool and Supply Storage</li> </ul>	Out of Service
5	Blender Control Room	<ul style="list-style-type: none"> <li>• Oil Movement DCS Operators</li> <li>• Oil Movement Field Operators</li> </ul>	Out of Service
6	TCC Operator Shelter	<ul style="list-style-type: none"> <li>• South Plant Tool and Supply Storage</li> </ul>	Out of Service
7	South Plant Control Room	<ul style="list-style-type: none"> <li>• South Plant DCS Operators</li> <li>• South Plant Field Operators</li> </ul>	Out of Service
8	Old South Plant Control Room	<ul style="list-style-type: none"> <li>• South Plant Tool and Supply Storage</li> </ul>	Out of Service
9	New Operator Shelter #1 (OS#1)	<ul style="list-style-type: none"> <li>• MHC Field Operators</li> </ul>	Not Applicable
10	New Operator Shelter #2 (OS#2)	<ul style="list-style-type: none"> <li>• NP Field Operators</li> </ul>	Not Applicable

Relative to the elimination of the septic holding tanks, the project includes provisions to utilize existing septic sewer lines currently routed through the refinery that were recently upgraded and re-commissioned on 11/26/08 in conjunction with the re-routing of the City of Artesia's sewer line. Refer to the attached aerial photograph drawing for general locations of new and existing facilities:

1. Purchase and install two (2) new modern operator shelters to accommodate MHC and NP Field Operators.
2. Install sewer lines from lavatory facilities in the New Operator Shelter #1 running East along Adams Drive and tie into the main line running North/South along East 5<sup>th</sup> Street.
3. Install sewer lines from lavatory facilities in the New Operator Shelter #2 running south along Freeman Avenue and tie into the lateral line running East/West along Moseley Avenue.
4. Renovate the Central Control Room to accommodate MHC DCS operators and FCC field operators in addition to the operators currently using the building for environmental shelter.
5. Install a sewer line from the lavatory facilities in the Central Control Room running South adjacent to TK 400 and tie into the lateral line running East/West along Moseley Avenue.

6. Install sewer line from the lavatory facilities in the Blender Control Room running West past the Maintenance Office Building and tie into the main line running North/South along East 5<sup>th</sup> Street.
7. Install sewer line from the lavatory facilities in the South Plant Control Room running East along Texas Avenue and tie into the main line running North/South along East 5<sup>th</sup> Street.
8. Decommission all abandoned lavatory facilities.
9. Decommission the holding tanks to eliminate future use following NMED Guidelines for removal or in place decommissioning of the below ground sanitary waste water closed tank systems.

Navajo anticipates that the project to install and/or renovate operator shelters and install new sewer lines to eliminate the holding tanks will be complete on or before 09/11/2010 which is 24 months after Artesia's completion of the new sewer line as required in Discharge Permit GW-028 Sec17.iv.

Extensive excavation inside the refinery boundary will be required to install the necessary piping to connect to the city of Artesia's sewer system. If during construction, underground piping or unforeseen obstructions prevent Navajo from completing the above described tie-ins to the city of Artesia's sanitary sewer system; Navajo will tie-in to the refinery oil/water sewer system to treat and/or dispose of all sanitary waste water effluent through the refinery waste water treatment system and permitted UIC Class 1 Injection Wells east of the refinery.

A handwritten signature in black ink, appearing to read "Gore" followed by a flourish, is located in the bottom right corner of the page.


## **Attachment 4**

NAVAJO REFINING COMPANY  
ARTESIA REFINERY  
LISTING OF UNDERGROUND PROCESS/WASTEWATER LINES

Description	Equipment	Unit Code	Priority
UNDERGROUND LINE INTEGRITY TESTING	08-TANKAGE	08	3
UNDERGROUND LINE INTEGRITY TESTING	08-TANKAGE	08	1
UNDERGROUND LINE INTEGRITY TESTING	08-TANKAGE	08	3
UNDERGROUND LINE INTEGRITY TESTING	08-TANKAGE	08	1
UNDERGROUND LINE INTEGRITY TESTING	08-TANKAGE	08	1
UNDERGROUND LINE INTEGRITY TESTING	29-BLENDING	29	1
UNDERGROUND LINE INTEGRITY TESTING	29-BLENDING	29	1
UNDERGROUND LINE INTEGRITY TESTING	29-BLENDING	29	1
UNDERGROUND LINE INTEGRITY TESTING	29-BLENDING	29	1
UNDERGROUND LINE INTEGRITY TESTING	08-TANKAGE	08	1
UNDERGROUND LINE INTEGRITY TESTING	08-TANKAGE	08	1
UNDERGROUND LINE INTEGRITY TESTING	08-TANKAGE	08	3
UNDERGROUND LINE INTEGRITY TESTING	29-BLENDING	29	1

## **Attachment 5**

NO. OF SUMP#S	SUMP ID #	LOCATION	DESCRIPTION	APPROX. DIMENSIONS	LAST TEST DATE	NET TEST DUE	TEST PASS / FAIL	TESTED BY	TEST METHOD	REPAIR METHOD	COMMENT
1	08SUMP01	UNDER H-30	CONCRETE BOX	2-0' x 3-0' x 3-0' D	9/12/05	3/2011	PASS	GLES INC.	HYDROLEVEL CHECK		
2	08SUMP02	UNDER H-19	CONCRETE BOX	2-6' x 2-6' x 3-0' D	9/12/05	9/12/10	PASS	GLES INC.	HYDROLEVEL CHECK		
3	08SUMP03	SKILL COLLECTION BOX AT CBO RR RACK (NORTH)	CONCRETE BOX	7-5' L x 4-0' W x 3-0' D	9/29/2008	9/29/2013	PASS	GLES INC.	HYDROLEVEL CHECK		
4	08SUMP04	SKILL COLLECTION BOX AT CBO RR RACK (SOUTH)	STEEL BOX	7' x 7' x 2'	9/12/2004	9/12/2009	PASS	GLES INC.	HYDROLEVEL CHECK		
5	08SUMP05	CBO BETWEEN TRUCK RACK & RAILROAD (SOUTH)	CONCRETE BOX	8' x 8' x 8'	9/12/2004	9/12/2009	PASS	GLES INC.	HYDROLEVEL CHECK		
6	08SUMP06	CBO BETWEEN TRUCK RACK & RAILROAD (NORTH)	CONCRETE BOX	8' x 8' x 8'	9/12/2004	9/12/2009	PASS	GLES INC.	HYDROLEVEL CHECK		
7	08SUMP07	P-138 EAST OF CBO RACK	CONCRETE BOX	3' x 3' x 3'	9/12/2004	9/12/2009	PASS	GLES INC.	HYDROLEVEL CHECK		
8	08SUMP08	WATER DRAIN NORTH SIDE OF 334 TANK	55 GALLON STEEL DRUM	N/A	9/29/2008	2/14/2010	PASS	GLES INC.	HYDROLEVEL CHECK		
9	08SUMP09	SOUTHWEST CORNER OF 334 TANK	UG STEEL TANK	18' x 8' x 2'	N/A	N/A	PASS	GLES INC.	HYDROLEVEL CHECK		LOCATED IN NE CORNER OF DIKE - OUT OF SERVICE
10	08SUMP10	WATER DRAIN PIT EAST SIDE OF 335 TANK	CONCRETE BOX	5' x 5' x 2'-6"	8/27/2004	8/27/2009	PASS	GLES INC.	HYDROLEVEL CHECK		
11	08SUMP11	WATER DRAIN PIT EAST SIDE OF 335 TANK	CONCRETE BOX	5' x 5' x 2'-6"	N/A	N/A	PASS	GLES INC.	HYDROLEVEL CHECK		
12	08SUMP12	SURRY SLINGER SLUDGE PIT	STEEL BOX	9' x 7' x 5'	N/A	N/A	PASS	GLES INC.	HYDROLEVEL CHECK		
13	08SUMP13	SURRY SLINGER SLUDGE PIT	STEEL BOX	9' x 7' x 5'	N/A	N/A	PASS	GLES INC.	HYDROLEVEL CHECK		
14	08SUMP14	SURRY SLINGER SLUDGE PIT	STEEL BOX	9' x 7' x 5'	N/A	N/A	PASS	GLES INC.	HYDROLEVEL CHECK		
15	08SUMP15	WATER DRAIN PIT AT EAST SIDE OF 315 TANK	CONCRETE BOX	8'-0" x 4'-0" x 3'-0" D	1/20/2008	1/20/2011	PASS	GLES INC.	HYDROLEVEL CHECK		
16	08SUMP16	WATER DRAIN PIT AT EAST SIDE OF 315 TANK	CONCRETE BOX	8'-0" x 4'-0" x 3'-0" D	8/27/2008	8/27/2009	PASS	GLES INC.	HYDROLEVEL CHECK		
17	08SUMP17	SPURRY BOX LIFTING STATION SW CORNER OF DIKE @ 301 T	CONCRETE BOX	3' x 3' x 4'	10/11/2004	10/11/2009	PASS	GLES INC.	HYDROLEVEL CHECK		
18	08SUMP18	WEST SIDE OF 430 TANK	CONCRETE BOX	3' x 3' x 4'	9/29/2008	9/29/2009	PASS	GLES INC.	HYDROLEVEL CHECK		
19	08SUMP19	WEST SIDE OF 430 TANK	CONCRETE BOX	3' x 3' x 4'	12/13/2004	12/13/2009	PASS	GLES INC.	HYDROLEVEL CHECK		
20	08SUMP20	WEST SIDE OF 430 TANK	CONCRETE BOX	8' x 8' x DEEP	9/12/2004	9/12/2009	PASS	GLES INC.	HYDROLEVEL CHECK		
21	08SUMP21	SE CORNER #2 RADIAL INDIANA TRANSFER PUMPS	CONCRETE BOX	3' x 3' x 3'	9/12/2008	9/12/2013	PASS	GLES INC.	HYDROLEVEL CHECK		
22	08SUMP22	WEST OF #3 SLINGER	CONCRETE BOX	3' x 3' x 3'	9/12/2008	9/12/2013	PASS	GLES INC.	HYDROLEVEL CHECK		
23	08SUMP23	ASPHALT TANK, SOUTH OF 433 TANK	CONCRETE BOX	4' x 3' x 3'	9/29/2008	9/29/2009	PASS	GLES INC.	HYDROLEVEL CHECK		
24	08SUMP24	WATER DRAIN PIT AT 433 TANK	CONCRETE BOX	20' x 40' x 3'	N/A	N/A	PASS	GLES INC.	HYDROLEVEL CHECK		OUT OF SERVICE, REMOVED BY ENG PROJECTS JAN 2008
25	08SUMP25	WATER DRAIN PIT AT 433 TANK	CONCRETE BOX	20' x 40' x 3'	N/A	N/A	PASS	GLES INC.	HYDROLEVEL CHECK		OUT OF SERVICE
26	08SUMP26	WEST OF 438 TANK	UG STEEL TANK	N/A	10/12/2004	10/12/2009	PASS	GLES INC.	HYDROLEVEL CHECK		
27	08SUMP27	SOUTH OF 438 TANK	UG STEEL TANK	N/A	8/29/2008	8/29/2013	PASS	GLES INC.	HYDROLEVEL CHECK		
28	08SUMP28	SPILL RETENTION SUMP#S @ GASOLINE LOADING RACK	CONCRETE BOX	2' x 2'-6" x 2'	9/12/2008	9/12/2013	PASS	GLES INC.	HYDROLEVEL CHECK		
29	08SUMP29	SPILL RETENTION SUMP#S @ GASOLINE LOADING RACK	CONCRETE BOX	2' x 2'-6" x 2'	9/12/2008	9/12/2013	PASS	GLES INC.	HYDROLEVEL CHECK		
30	08SUMP30	NORTH SIDE OF 110 TANK	UG STEEL TANK	N/A	10/13/2004	10/13/2009	PASS	GLES INC.	HYDROLEVEL CHECK		
31	08SUMP31	LIFT STATION @ FILTER MANIFOLD S. OF UG LOADING RACK	UG STEEL TANK	8' DIAMETER x 4' DEEP	11/15/2008	11/15/2009	PASS	GLES INC.	HYDROLEVEL CHECK		
32	08SUMP32	SUMP BETWEEN 431 TANK AND 432 TANK	CONCRETE BOX	5' x 8' x 6'	6/10/2004	6/10/2009	PASS	GLES INC.	HYDROLEVEL CHECK		
33	08SUMP33	SOUTHWEST OF 834 TANK	CONCRETE BOX	5' x 8' x 6'	7/10/2008	7/10/2009	PASS	GLES INC.	HYDROLEVEL CHECK		
34	08SUMP34	EAST OF 115 TANK BY HEP PUMPS	UG STEEL TANK	N/A	N/A	N/A	PASS	GLES INC.	HYDROLEVEL CHECK		
35	08SUMP35	E. PASO PUMP STATION	METAL BOX	5' x 3' x 3'	12/9/2008	12/9/2013	FAIL	GLES INC.	HYDROLEVEL CHECK		REPAIR WITH CONCRETE PATCH
36	08SUMP36	E. PASO PUMP STATION	METAL BOX	5' x 3' x 3'	12/9/2008	12/9/2013	PASS	GLES INC.	HYDROLEVEL CHECK		
37	08SUMP37	E. PASO PUMP STATION	METAL BOX	5' x 3' x 3'	12/9/2008	12/9/2013	PASS	GLES INC.	HYDROLEVEL CHECK		
38	08SUMP38	FOUR CORNERS STATION "HEP"	METAL BOX	6' x 4'	12/9/2008	12/9/2013	PASS	GLES INC.	HYDROLEVEL CHECK		
39	08SUMP39	FOUR CORNERS STATION "HEP"	METAL BOX	6' x 4'	12/9/2008	12/9/2013	PASS	GLES INC.	HYDROLEVEL CHECK		
40	08SUMP40	FOUR CORNERS STATION "HEP"	METAL BOX	6' x 4'	12/9/2008	12/9/2013	PASS	GLES INC.	HYDROLEVEL CHECK		
41	08SUMP41	FLUORIDE PERCHLORATE	CONCRETE BOX	4'-0" x 4'-0" x 3'-0"	10/15/2007	10/15/2012	FAIL	GLES INC.	HYDROLEVEL CHECK		REPAIRED WITH CONCRETE PATCH
42	08SUMP42	FLUORIDE PERCHLORATE	CONCRETE BOX	4'-0" x 4'-0" x 3'-0"	10/15/2007	10/15/2012	PASS	GLES INC.	HYDROLEVEL CHECK		
43	08SUMP43	SURRY BARREL @ NORTH PLANT SOUTH OF 7-245	1/2-55 GALLON STEEL DRUM	N/A	N/A	N/A	PASS	GLES INC.	HYDROLEVEL CHECK		LOCATED IN NORTH PLANT NW OF OLD COMPOST STATION
44	08SUMP44	SURRY BARREL @ NORTH PLANT SOUTH OF 7-245	CONCRETE BOX	4'-0" x 4'-0" x 3'-0"	N/A	N/A	PASS	GLES INC.	HYDROLEVEL CHECK		
45	08SUMP45	FLUE GAS SCRUBBER - FICU	CONCRETE BOX	4'-0" x 4'-0" x 3'-0"	10/15/2007	10/15/2012	FAIL	GLES INC.	HYDROLEVEL CHECK		REPAIRED WITH CONCRETE PATCH
46	08SUMP46	FLUE GAS SCRUBBER - FICU	CONCRETE BOX	4'-0" x 4'-0" x 3'-0"	10/15/2007	10/15/2012	PASS	GLES INC.	HYDROLEVEL CHECK		
47	08SUMP47	FLUE GAS SCRUBBER - FICU	CONCRETE BOX	4'-0" x 4'-0" x 3'-0"	10/15/2007	10/15/2012	PASS	GLES INC.	HYDROLEVEL CHECK		
48	08SUMP48	UNDER D-207 VACUUM UNIT	CONCRETE BOX	2-6' x 2-6' x 2-6" D	10/29/2007	10/29/2012	PASS	GLES INC.	HYDROLEVEL CHECK		
49	08SUMP49	EAST OF 7-AMU ON BRADLEY BLVD	CONCRETE BOX	1-5' x 1-5' x 1-5' D	10/29/2007	10/29/2012	PASS	GLES INC.	HYDROLEVEL CHECK		
50	08SUMP50	WEST END OF SP. ALVY C.T. 1 (2 NORTH)	CONCRETE BOX	6'-0" x 6'-0" x 6'-0" D	N/A	N/A	PASS	GLES INC.	HYDROLEVEL CHECK		OUT OF SERVICE
51	08SUMP51	WEST END OF SP. ALVY C.T. 1 (2 SOUTH)	CONCRETE BOX	10'-0" x 8'-0" x 6'-0" D	N/A	N/A	PASS	GLES INC.	HYDROLEVEL CHECK		OUT OF SERVICE
52	08SUMP52	H-31 PUMP OUT SUMP NEW CORNER OF CUBED AREA AT H-31	CONCRETE BOX	2'-8" x 2'-8" x 2'-0" D	10/29/2007	10/29/2012	PASS	GLES INC.	HYDROLEVEL CHECK		
53	08SUMP53	NORTH TOOL ROOM	CONCRETE BOX	2' x 2' x 2'	5/20/2004	5/20/2009	PASS	GLES INC.	HYDROLEVEL CHECK		
54	08SUMP54	SE CORNER OF TRUCKING YARD	CONCRETE BOX	3' x 3' x 2'-6"	9/10/2004	9/10/2009	PASS	GLES INC.	HYDROLEVEL CHECK		
55	08SUMP55	DIESEL STORAGE TANK AT MILCOCK WEL GENERATOR	FIBERGLASS	10' x 3' x 1'-9"	9/12/2008	9/12/2013	PASS	GLES INC.	HYDROLEVEL CHECK		
56	08SUMP56	SP BUNDLE SLAB CATCH BASIN	CONCRETE BOX W/ Baffle	50' x 3' x 3'-6"	7/14/2004	7/14/2009	PASS	GLES INC.	HYDROLEVEL CHECK		NOT A SUMP - TIED TO SEWER LINE (SEE SEWER DWGS)
57	08SUMP57	DIESEL STORAGE TANK SOUTH OF #2 WAREHOUSE	FIBERGLASS	15'-6" x 8'-6" x 1'-9"	9/29/2008	9/29/2013	PASS	GLES INC.	HYDROLEVEL CHECK		
58	08SUMP58	HYDRAULIC FLUID CONTAINMENT SOUTH OF #2 WAREHOUSE	FIBERGLASS	7'-6" x 6'-6" x 1'-9"	9/29/2008	9/29/2013	PASS	GLES INC.	HYDROLEVEL CHECK		
59	08SUMP59	UNLEADED GASOLINE STORAGE IN SOUTH OF WELDING SHOP	FIBERGLASS	12' x 8' x 2'	9/12/2004	9/12/2009	PASS	GLES INC.	HYDROLEVEL CHECK		
60	08SUMP60	SP BUNDLE SLAB CATCH BASIN	CONCRETE BOX W/ Baffle	50' x 3' x 3'-6"	7/13/2004	7/13/2009	PASS	GLES INC.	HYDROLEVEL CHECK		NOT A SUMP - TIED TO SEWER LINE (SEE SEWER DWGS)
61	08SUMP61	CHEMICAL PAD WEST END OF #2 YARD	CONCRETE BOX	3' x 3' x 3'	6/9/2004	6/9/2009	PASS	GLES INC.	HYDROLEVEL CHECK		
62	08SUMP62	EAST OF MECHANIC SHOP	CONCRETE BOX	4' x 2' x 2'-3"	9/12/2004	9/12/2009	PASS	GLES INC.	HYDROLEVEL CHECK		
63	08SUMP63	EAST OF MECHANIC SHOP	CONCRETE BOX	3' x 3' x 3'	9/12/2004	9/12/2009	PASS	GLES INC.	HYDROLEVEL CHECK		
64	08SUMP64	SW CORNER OF ELECTRICAL SHOP	UG STEEL TANK	N/A	9/29/2008	9/29/2013	PASS	GLES INC.	HYDROLEVEL CHECK		
65	08SUMP65	NORTH OF INSTRUMENT SHOP	CONCRETE BOX	5' x 5' x 5'	9/12/2008	9/12/2013	PASS	GLES INC.	HYDROLEVEL CHECK		
66	08SUMP66	SAMPLE SUMP NORTH OF LAB	CONCRETE BOX	4' x 4' x 4' (48920)	9/12/2008	9/12/2013	PASS	GLES INC.	HYDROLEVEL CHECK		
67	08SUMP67	CHEMICAL STORAGE AREA NORTH OF WAREHOUSE EAST	CONCRETE BOX	N/A	NEW 10/07	2012	PASS	GLES INC.	HYDROLEVEL CHECK		NEW ADDITION REQUIRES ADD TO DRAWING
68	08SUMP68	CHEMICAL STORAGE AREA NORTH OF WAREHOUSE WEST	CONCRETE BOX	N/A	NEW 10/07	2012	PASS	GLES INC.	HYDROLEVEL CHECK		THIS SUMP WILL BECOME ASB WHEN NEW 12 UNIT IS BUILT
69	08SUMP69	CHEMICAL STORAGE AREA NORTH OF WAREHOUSE WEST	CONCRETE BOX	N/A	NEW 10/07	2012	PASS	GLES INC.	HYDROLEVEL CHECK		
70	08SUMP70	NORTH SIDE OF HYDROGEN UNIT	CONCRETE BOX	3'-0" x 3'-0" x 4'-3" D	8/12/2005	8/12/2010	PASS	GLES INC.	HYDROLEVEL CHECK		



**NAVATO REFINING CO.**  
 ENGINEERING DEPARTMENT  
 P.O. DRAWER 159  
 ARTESIA, NEW MEXICO

DATE: 1/11/08  
 DRAWN BY: SLW  
 CHECKED BY: SLW  
 APPR. BY: DGJ  
 SCALE: NONE  
 DRAWING NUMBER: 55-Z-32-D-00  
 REV.:

DRAWING TITLE  
**KEY PLOT PLAN  
 UNDERGROUND SEWER PIPING**

NO.	REVISIONS	BY	CHK.	DATE	APPR.	APPR.	NO.
0	ISSUED FOR REFERENCE	SLW	SLW				DGJ


NO.	REVISIONS	BY	CHK.	DATE	APPR.	APPR.	NO.

NO.	REVISIONS	BY	CHK.	DATE	APPR.	APPR.	NO.

REFERENCE DRAWINGS

NOTES





SEE DWG 55-Z-32-D-01

SEE DWG 55-Z-32-D-05

SEE DWG 55-Z-32-D-03

**MAYAJO REFINING CO.**  
 ENGINEERING DEPARTMENT  
 P.O. DRAWER 159  
 ARTESIA, NEW MEXICO

DATE: 1/11/08  
 DRAWING NUMBER: 55-Z-32-D-021.0  
 SCALE: NONE  
 DRAWN BY: SLW  
 CHECKED BY: SLW  
 APPROVED BY: DGI

**DRAWING TITLE**  
 PLOT PLAN  
 UNDERGROUND SEWER PIPING  
 VACUUM UNIT AREA, PCB SKID  
 TREATER AREA, SOUTH MAIN  
 LINE, SOUTH TRUNK LINE, AREA  
 EAST OF 419 TANK-S.P.

NO.	REVISIONS	BY	CHK.	DATE	APPR.	NO.	BY	CHK.	DATE	APPR.
0	ISSUED FOR REFERENCE					0				

NO.	REVISIONS	BY	CHK.	DATE	APPR.	NO.	BY	CHK.	DATE	APPR.

NO.	REVISIONS	BY	CHK.	DATE	APPR.	NO.	BY	CHK.	DATE	APPR.

NO.	REVISIONS	BY	CHK.	DATE	APPR.	NO.	BY	CHK.	DATE	APPR.


NOTES











P-0105  
P-0762  
P-0761  
P-0341  
P-XXXX

P-0277  
P-0276  
P-0275  
P-0274  
P-0273


P-0277  
P-0277



SEE DWG 55-Z-32-D-08

		<b>NAVJO REFINING CO.</b> ENGINEERING DEPARTMENT ARTESIA, NEW MEXICO		DATE 1/11/08	DRAWN BY SLW	CHECKED BY DCJ	SCALE NONE	DRAWING NUMBER 55-Z-32-D-07.0	REV. 0
<b>DRAWING TITLE</b> PLOT PLAN UNDERGROUND SEWER PIPING BLENDER TANK FARM, NORTH PLANT-SOUTH TANK FARM									
<b>REVISIONS</b>									
NO.	BY	CHK.	DATE	APPR.	APPR.	NO.	ISSUED FOR REFERENCE		
<b>REFERENCE DRAWINGS</b>									
<b>NOTES</b>									

SEE DWG 55-Z-32-D-07



NAVAJO REFINING CO.  
ENGINEERING DEPARTMENT  
ARTESIA, NEW MEXICO

DESIGNED BY	SCALE	NO. OF SHEETS	NO. OF SHEETS
DATE	DATE	DATE	DATE
1/11/08	DCJ	DCJ	DCJ
DRAWING NUMBER		55-Z-32-D-08.0	

DRAWING TITLE  
PLOT PLAN  
UNDERGROUND SEWER PIPING  
BLENDER TANK FARM



NO.	REVISIONS	BY	CHK.	DATE	APPROVAL	NO.	REVISIONS	BY	CHK.	DATE	APPROVAL
0	ISSUED FOR REFERENCE					0	ISSUED FOR REFERENCE				

REFERENCE DRAWINGS

NOTES



SEE DWG 55-Z-32-D-14



1/4" = 1'-0"

1/8" = 1'-0"

1/16" = 1'-0"

1/32" = 1'-0"

1/64" = 1'-0"

1/128" = 1'-0"

1/256" = 1'-0"

1/512" = 1'-0"

1/1024" = 1'-0"

1/2048" = 1'-0"

1/4096" = 1'-0"

1/8192" = 1'-0"

1/16384" = 1'-0"

1/32768" = 1'-0"

1/65536" = 1'-0"

1/131072" = 1'-0"

1/262144" = 1'-0"

1/524288" = 1'-0"

1/1048576" = 1'-0"

1/2097152" = 1'-0"

1/4194304" = 1'-0"

1/8388608" = 1'-0"

1/16777216" = 1'-0"

1/33554432" = 1'-0"

1/67108864" = 1'-0"

1/134217728" = 1'-0"

1/268435456" = 1'-0"

1/536870912" = 1'-0"

1/1073741824" = 1'-0"

1/2147483648" = 1'-0"

1/4294967296" = 1'-0"

1/8589934592" = 1'-0"

1/17179869184" = 1'-0"

1/34359738368" = 1'-0"

1/68719476736" = 1'-0"

1/137438953472" = 1'-0"

1/274877906944" = 1'-0"

1/549755813888" = 1'-0"

1/1099511627776" = 1'-0"

1/2199023255552" = 1'-0"

1/4398046511104" = 1'-0"

1/8796093022208" = 1'-0"

1/17592186444416" = 1'-0"

1/35184372888832" = 1'-0"

1/70368745777664" = 1'-0"

1/14073749155328" = 1'-0"

1/28147498310656" = 1'-0"

1/56294996621312" = 1'-0"

1/112589993242624" = 1'-0"

1/225179986485248" = 1'-0"

1/450359972970496" = 1'-0"

1/900719945940992" = 1'-0"

1/1801439891881984" = 1'-0"

1/3602879783763968" = 1'-0"

1/7205759567527936" = 1'-0"

1/14411519135055872" = 1'-0"

1/28823038270111744" = 1'-0"

1/57646076540223488" = 1'-0"

1/115292153080446976" = 1'-0"

1/230584306160893952" = 1'-0"

1/461168612321787904" = 1'-0"

1/922337224643575808" = 1'-0"

1/1844674449287151616" = 1'-0"

1/3689348898574303232" = 1'-0"

1/7378697797148606464" = 1'-0"

1/14757395584297212928" = 1'-0"

1/29514791168594425856" = 1'-0"

1/59029582337188851712" = 1'-0"

1/118059164674377703424" = 1'-0"

1/236118329348755406848" = 1'-0"

1/472236658697510813696" = 1'-0"

1/944473317395021627392" = 1'-0"

1/1888946634900043254784" = 1'-0"

1/3777893269800086509568" = 1'-0"

1/7555786539600173019136" = 1'-0"

1/15111573079200346378272" = 1'-0"

1/30223146158400692756544" = 1'-0"

1/60446292316801385513088" = 1'-0"

1/120892584633602771026176" = 1'-0"

1/241785169267205542052352" = 1'-0"

1/483570338534411084104704" = 1'-0"

1/967140677068822168209408" = 1'-0"

1/1934281354137643364118816" = 1'-0"

1/3868562708275286728237632" = 1'-0"

1/7737125416550573456447264" = 1'-0"

1/15474250833101146912894528" = 1'-0"

1/30948501666202293825789568" = 1'-0"

1/61897003332404587651579136" = 1'-0"

1/123794006664809175303154272" = 1'-0"

1/247588013329618350606308544" = 1'-0"

1/4951760266592367012126171088" = 1'-0"

1/9903520533184734024252342176" = 1'-0"

1/198070410663686804485046835328" = 1'-0"

1/396140821327373608970093670656" = 1'-0"

1/792281642654747217940187341312" = 1'-0"

1/1584563285309494435880374622624" = 1'-0"

1/3169126570618988871760749245248" = 1'-0"

1/6338253141237977743521498490496" = 1'-0"

1/12676506282475955487042996800992" = 1'-0"

1/25353012564951910974085993601984" = 1'-0"

1/50706025129903821948171987203968" = 1'-0"

1/10141205025980764396434374407936" = 1'-0"

1/20282410051961528792868748815872" = 1'-0"

1/40564820103923057585737497631744" = 1'-0"

1/81129640207846115171464992623488" = 1'-0"

1/162259284556922230342918982446976" = 1'-0"

1/324518569113844460685837764893952" = 1'-0"

1/649037138227688921371677529787904" = 1'-0"

1/1298074276555377842743355115557584" = 1'-0"

1/259614855311075568548671022111115168" = 1'-0"

1/519229710622151137097342444222230336" = 1'-0"

1/1038459421444302274194684884444446072" = 1'-0"

1/2076918842888604548389369768888892144" = 1'-0"

1/41538376857772090967787953777777888288" = 1'-0"

1/830767537155441819355759875555557775776" = 1'-0"

1/1661535074308883637111111111111111115552" = 1'-0"

1/332307014861776727422222222222222223104" = 1'-0"

1/664614029723553454844444444444444446208" = 1'-0"

1/1329228059447106908888888888888888812416" = 1'-0"

1/265845611893821377777777777777777724832" = 1'-0"

1/53169122378764275555555555555555549664" = 1'-0"

1/106338244777528541111111111111111199328" = 1'-0"

1/21267648955505708222222222222222239664" = 1'-0"

1/4253529791101141644444444444444479328" = 1'-0"

1/8507059582202283288888888888888948656" = 1'-0"

1/1701411916440576577777777777777897312" = 1'-0"

1/3402823832881153155555555555555794624" = 1'-0"

1/6805647665762306311111111111111589248" = 1'-0"

1/1361129533532461262222222222222378496" = 1'-0"

1/2722259067064922524444444444444756992" = 1'-0"

1/5444518134129845048888888888889513984" = 1'-0"

1/10889036268259690097777777777780271968" = 1'-0"

1/21778072536519380195555555555560543936" = 1'-0"

1/435561450730387603911111111111210888888" = 1'-0"

1/871122901460775207822222222222421777776" = 1'-0"

1/17422458232115140564444444444484355552" = 1'-0"

1/34844916464230281128888888888968711104" = 1'-0"

1/69689832928460562257777777777817342208" = 1'-0"

1/13937966585692112455555555555628684416" = 1'-0"

1/278759331713842249111111111112513728832" = 1'-0"

1/55751866342768449822222222225027457664" = 1'-0"

1/111503732685536899644444444410054915328" = 1'-0"

1/22300746537107379928888888882010982656" = 1'-0"

1/4460149307421475985777777774021965312" = 1'-0"

1/8920298614842951971555555558043930624" = 1'-0"

1/17840597237689039431111111160878612448" = 1'-0"

1/3568119447537807886222222240177224896" = 1'-0"

1/713623889507561577244444480354449792" = 1'-0"

1/142724777901523115448888960708899584" = 1'-0"

1/285449555803046230897777801417799168" = 1'-0"

1/570899111606092461795555602835593328" = 1'-0"

1/11417982232121848235911112056711666656" = 1'-0"

1/22835964464237696471822224113423333112" = 1'-0"

1/4567192892847539294364448226846666224" = 1'-0"

1/913438578569507858872889653369333248" = 1'-0"

1/1826877157139117177745781066738666496" = 1'-0"

1/365375431427823355491517333477333296" = 1'-0"

1/730750862855646710982230666944666592" = 1'-0"

1/1461501725711313417644613338892921184" = 1'-0"

1/292300345142262683528928666778584368" = 1'-0"

1/5846006902845253671577773535571771712" = 1'-0"

1/1169201380569050734315555707114343424" = 1'-0"

1/233840276113810146823111114142686848" = 1'-0"

1/467680552227620293646222282853737376" = 1'-0"

1/935361104455240587292444565707474752" = 1'-0"

1/187072220910481174584888111414148944" = 1'-0"

1/374144441820962349169777222828288888" = 1'-0"

1/74828888364192469833955445665666666" = 1'-0"

1/1496577767283849196679111111111111111" = 1'-0"

1/2993155534567698393348222222222222222" = 1'-0"

1/5986311069135396786696444444444444444" = 1'-0"

1/11972622138270793733392888888888888888" = 1'-0"

1/23945244276541587466785777777777777777" = 1'-0"

1/478904885530831751335771555555555555555" = 1'-0"

1/957809771061663502671511111111111111111" = 1'-0"

1/191561942212332605342302222222222222222" = 1'-0"

1/383123884424665210684604444444444444444" = 1'-0"

1/766247768849330421369240888888888888888" = 1'-0"

1/1532495536986608422738848177777777777777" = 1'-0"

1/3064991073973216845477715555555555555555" = 1'-0"


1/6129982147946433690955431111111111111111" = 1'-0"

1/12259964298912867381911066222222222222222" = 1'-0"


SEE DWG 55-Z-32-D-10

H-242

PSB-116



FUTURE  
UNIT 04  
HYDROGEN PLANT



PLT. NORTH  
ROT. 4.01934° CW

**NAVAJO REFINING CO.**  
ENGINEERING DEPARTMENT  
P.O. DRAWER 159  
ARTESIA, NEW MEXICO

DATE: 1/11/08  
DRAWN BY: SLW  
CHECKED BY: DCJ  
APPROVED BY: DCJ  
SCALE: NONE  
DRAWING NUMBER: 55-Z-32-D-11  
REV. 0

DRAWING TITLE  
**PLOT PLAN  
UNDERGROUND SEWER PIPING  
HYDROGEN UNIT AREA**

NO.	REVISIONS	BY	CHK	DATE	APPR.
0	ISSUED FOR REFERENCE	SLW	DCJ	1/11/08	DCJ

NO.	REVISIONS	BY	CHK	DATE	APPR.

NO.	REVISIONS	BY	CHK	DATE	APPR.

REFERENCE DRAWINGS


NOTES









SEE DWG 55-Z-32-D-16




SEE DWG 55-Z-32-D-14




MATCHLINE DWG. 55-Z-31-D-29  
M 13'-8" 0"




MATCHLINE DWG. 55-Z-31-D-29  
M 13'-8" 0"




MATCHLINE DWG. 55-Z-31-D-29  
M 13'-8" 0"




MATCHLINE DWG. 55-Z-31-D-29  
M 13'-8" 0"



MATCHLINE DWG. 55-Z-31-D-29  
M 13'-8" 0"





SEE DWG 55-Z-32-D-17

SEE DWG 55-Z-32-D-14

SEE DWG 55-Z-32-D-15



PLI. NORTH  
ROT. 4.01934° CW

**NAVAJO REFINING CO.**  
ENGINEERING DEPARTMENT  
ARTESIA, NEW MEXICO

DESIGNED BY	SLW	SCALE	NONE
CHECKED BY	SLW	DATE	1/11/08
APPROVED BY	DCJ	DRAWING NUMBER	55-Z-32-D-16.0
REV.			

**DRAWING TITLE**  
PLOT PLAN  
UNDERGROUND SEWER PIPING  
NORTH PLANT DEAERATOR AREA,  
FCCU AREA, NORTH MAIN LINE

NO.	REVISIONS	BY	CHK.	DATE	APPR.	APPR.
0	ISSUED FOR REFERENCE					

NO.	REVISIONS	BY	CHK.	DATE	APPR.	APPR.

NO.	REVISIONS	BY	CHK.	DATE	APPR.	APPR.

NO.	REVISIONS	BY	CHK.	DATE	APPR.	APPR.

**NOTES**

REFERENCE DRAWINGS

SEE DWG 55-Z-32-D-18

FREEMAN STREET

FREEMAN STREET

SMOKE SHACK

ELECTRICAL BUILDING

ELECTRICAL BUILDING

ELECTRICAL SUB-STATION

Y-8 COOLING TOWER

P-830  
P-831  
P-829  
P-826

Y-4 COOLING TOWER

SAFETY SHOWER/EW

CAUSTIC MIX

PIPE RACK

PIPE RACK

FIBER OPTIC CABLE

SEWER

CONTROL ROOM

FLARE DRUM

FUEL GAS DRUM

C.O.

NMB-09

NPS-8218

NPS-8217

NPS-8216

NPS-8215

NPS-8214

NPS-8213

NPS-8212

NPS-8211

NPS-8210

NPS-8209

NPS-8208

NPS-8207

NPS-8206

NPS-8205

NPS-8204

NPS-8203

NPS-8202

NPS-8201

NPS-8200

NPS-8199

NPS-8198

NPS-8197

NPS-8196

NPS-8195

NPS-8194

NPS-8193

NPS-8192

NPS-8191

NPS-8190

NPS-8189

NPS-8188

NPS-8187

NPS-8186

NPS-8185

NPS-8184

NPS-8183

NPS-8182

NPS-8181

NPS-8180

NPS-8179

NPS-8178

NPS-8177

NPS-8176

NPS-8175

NPS-8174

NPS-8173

NPS-8172

NPS-8171

NPS-8170

NPS-8169

NPS-8168

NPS-8167

NPS-8166

NPS-8165

NPS-8164

NPS-8163

NPS-8162

NPS-8161

NPS-8160

NPS-8159

NPS-8158

NPS-8157

NPS-8156

NPS-8155

NPS-8154

NPS-8153

NPS-8152

NPS-8151

NPS-8150

NPS-8149

NPS-8148

NPS-8147

NPS-8146

NPS-8145

NPS-8144

NPS-8143

NPS-8142

NPS-8141

NPS-8140

NPS-8139

NPS-8138

NPS-8137

NPS-8136

NPS-8135

NPS-8134

NPS-8133

NPS-8132

NPS-8131

NPS-8130

NPS-8129

NPS-8128

NPS-8127

NPS-8126

NPS-8125

NPS-8124

NPS-8123

NPS-8122

NPS-8121

NPS-8120

NPS-8119

NPS-8118

NPS-8117

NPS-8116

NPS-8115

NPS-8114

NPS-8113

NPS-8112

NPS-8111

NPS-8110

NPS-8109

NPS-8108

NPS-8107

NPS-8106

NPS-8105

NPS-8104

NPS-8103

NPS-8102

NPS-8101

NPS-8100

NPS-8099

NPS-8098

NPS-8097

NPS-8096

NPS-8095

NPS-8094

NPS-8093

NPS-8092

NPS-8091

NPS-8090

NPS-8089

NPS-8088

NPS-8087

NPS-8086

NPS-8085

NPS-8084

NPS-8083

NPS-8082

NPS-8081

NPS-8080

NPS-8079

NPS-8078

NPS-8077

NPS-8076

NPS-8075

NPS-8074

NPS-8073

NPS-8072

NPS-8071

NPS-8070

NPS-8069

NPS-8068

NPS-8067

NPS-8066

NPS-8065

NPS-8064

NPS-8063

NPS-8062

NPS-8061

NPS-8060

NPS-8059

NPS-8058

NPS-8057

NPS-8056

NPS-8055

NPS-8054

NPS-8053

NPS-8052

NPS-8051

NPS-8050

NPS-8049

NPS-8048

NPS-8047

NPS-8046

NPS-8045

NPS-8044

NPS-8043

NPS-8042

NPS-8041

NPS-8040

NPS-8039

NPS-8038

NPS-8037

NPS-8036

NPS-8035

NPS-8034

NPS-8033

NPS-8032

NPS-8031

NPS-8030

NPS-8029

NPS-8028

NPS-8027

NPS-8026

NPS-8025

NPS-8024

NPS-8023

NPS-8022

NPS-8021

NPS-8020

NPS-8019

NPS-8018

NPS-8017

NPS-8016

NPS-8015

NPS-8014

NPS-8013

NPS-8012

NPS-8011

NPS-8010

NPS-8009

NPS-8008

NPS-8007

NPS-8006

NPS-8005

NPS-8004

NPS-8003

NPS-8002

NPS-8001

NPS-8000

NPS-7999

NPS-7998

NPS-7997

NPS-7996

NPS-7995

NPS-7994

NPS-7993

NPS-7992

NPS-7991

NPS-7990

NPS-7989

NPS-7988

NPS-7987

NPS-7986

NPS-7985

NPS-7984

NPS-7983

NPS-7982

NPS-7981

NPS-7980

NPS-7979

NPS-7978

NPS-7977

NPS-7976

NPS-7975

NPS-7974

NPS-7973

NPS-7972

NPS-7971

NPS-7970

NPS-7969

NPS-7968

NPS-7967

NPS-7966

NPS-7965

NPS-7964

NPS-7963

NPS-7962

NPS-7961

NPS-7960

NPS-7959

NPS-7958

NPS-7957

NPS-7956

NPS-7955

NPS-7954

NPS-7953

NPS-7952

NPS-7951

NPS-7950

NPS-7949

NPS-7948

NPS-7947

NPS-7946

NPS-7945

NPS-7944

NPS-7943


NPS-7942

NPS-7941

NPS-7940

NPS-7939

NPS-7938



NAVAJO REFINING CO.  
ENGINEERING DEPARTMENT  
P.O. DRAWER 159  
ARTESIA, NEW MEXICO

SCALE NONE

DATE 1/11/08

DRAWN BY SLW

CHECKED BY DGJ

APPROVED BY DGJ

DRAWING NUMBER 55-Z-32-D-18

REV. 0

DRAWING TITLE  
PLOT PLAN  
UNDERGROUND SEWER PIPING  
NORTH TRUNK LINE, NORTH MAIN  
LINE, N.P. OLD LAB, NAPHTHA  
UNIT, D-8 AREA, AMINE SKIDS,  
NORTH AMINE UNIT (NEW),  
NORTH AMINE UNIT

NO.	REVISIONS	BY	CHK.	DATE	APPR.	APPR.
0	ISSUED FOR REFERENCE	SLW	SLW	1/11/08	DGJ	DGJ

NO.	REVISIONS	BY	CHK.	DATE	APPR.	APPR.
0	ISSUED FOR REFERENCE	SLW	SLW	1/11/08	DGJ	DGJ

SEE DWG 55-Z-32-D-17

REFERENCE DRAWINGS

NOTES

EET

