

GW-185

H2S Plan

DATE:

03.07.11



New Mexico Energy, Minerals and Natural Resources Department

Susana Martinez
Governor

Brett F. Woods, Ph.D.
Acting Cabinet Secretary

Daniel Sanchez
Acting Division Director
Oil Conservation Division



March 3, 2011

Ms. Jennifer Knowlton, PE
Agave Energy Company
105 South Fourth Street
Artesia, NM 88210

**RE: H2S CONTINGENCY PLAN - AGAVE DAGGER DRAW PROCESSING PLANT
AND THE METROPOLIS DISPOSAL #1 WELL
GW-153**

Ms. Knowlton:

The Oil Conservation Division (OCD) has completed its review of Agave Energy Company's *H2S Contingency Plan - Agave Dagger Draw Processing Plant and The Metropolis Disposal #1 Well* submitted as a draft on April 5, 2010 and submitted as a final document on December 20, 2010. Agave is required to submit this Hydrogen Sulfide Contingency Plan, pursuant to 19.15.11.9A NMAC, because operations at Agave's Dagger Draw Gas Plant and its acid gas injection well (Metropolis Disposal Well) could result in the release of a potentially hazardous volume of hydrogen sulfide which might impact a public road. Agave's contingency plan specifies how it will alert and protect the public in accordance with the Subsections B through I of 19.15.11.9 NMAC.

On February 16, 2011, OCD met with Agave and Geolex to discuss technical issues. On February 17, 2011, Agave brought its Acid Gas Injection (AGI) application for authorization to inject to a hearing before an OCD hearing examiner (Case 14601). Agave requested permission to inject acid gas into its Metropolis Disposal #001 Well (API No. 30-015-31905). The well is located in Section 36, Township 18 South, Range 25 East, NMPM, in Eddy County, New Mexico.


Following the technical meeting of February 16, 2011, Agave submitted a revised H2S Contingency Plan via email to OCD on February 23 and February 25, 2011. On March 1, 2011, OCD provided Agave with a final review and on March 2, 2011, Agave made the requested final revisions.



Ms. Knowlton
Page 2 of 2

OCD hereby approves Agave's H2S Contingency Plan dated March 1, 2011. OCD thanks Agave and Geolex for their cooperation during this review process. Please contact Mr. Leonard Lowe at (505) 476-3492 if you have any questions.

Sincerely,

A handwritten signature in black ink that reads "Glenn von Gonten". The signature is written in a cursive style with a large, prominent 'G' at the beginning.

Glenn von Gonten
Acting Environmental Bureau Chief

Cc: Richard Ezeanyim, OCD
Leonard Lowe, OCD
Carl Chavez, OCD
Randy Dade, OCD
Julie Guitierrez, Geolex

March 3, 2011

Glenn von Gonten
Environmental Bureau Senior Hydrologist
State of New Mexico
Oil Conservation Division
1220 South St. Francis Drive
Santa Fe, New Mexico 87505

Dear Mr. von Gonten,

Per our conversations, enclosed is a disk that contains electronic copies of the Agave Dagger Draw Gas Processing Plant Hydrogen Sulfide Contingency Plan. Also enclosed is a bound hard copy of the same report.

Thanks for your assistance with this. As always, let me know if you have any questions.

Sincerely,



Julie W. Gutierrez

xc: Jennifer Knowlton, Agave (3 hard copies enclosed)

RECEIVED OGD
2011 MAR -11 P 12:23

Lowe, Leonard, EMNRD

From: VonGonten, Glenn, EMNRD
Sent: Thursday, March 03, 2011 4:27 PM
To: Lowe, Leonard, EMNRD
Subject: FW:

From: Julie W. Gutierrez [<mailto:jwg@geolex.com>]
Sent: Thursday, March 03, 2011 4:02 PM
To: VonGonten, Glenn, EMNRD
Subject: RE:

Thanks very much, Glenn. We are delighted.

Best regards,

Julie

Julie W. Gutiérrez
Geolex, Inc[®]
500 Marquette Avenue, NW Suite 1350
Albuquerque, NM 87102
505-842-8000 Ext. 101
505-842-7380 Fax

PRIVILEGED & CONFIDENTIAL

This message and attachment(s) contain confidential information belonging to the sender which is intended for the sole use of the individual(s) or entity named above. If you receive this message in error, you are hereby notified that any disclosure, copying, distribution, resending, forwarding or taking of any action in reliance on the contents of this email and/or any attachment(s) is strictly prohibited. If you have received this message in error, please notify the sender via return email and permanently delete this message and any attachment(s) from any computer(s).

From: VonGonten, Glenn, EMNRD [<mailto:Glenn.VonGonten@state.nm.us>]
Sent: Thursday, March 03, 2011 3:42 PM
To: Jennifer Knowlton; Julie W. Gutierrez; Lowe, Leonard, EMNRD
Subject:


Jennifer,

Here is OCD's approval for the Dagger Draw GP/Metropolis Well H2S Contingency Plan of March 1, 2011. The hard copy will go out tomorrow in the mail.

Glenn

H₂S Contingency Plan

Agave Dagger Draw Processing Plant
and the
Metropolis Disposal #1 Well



Agave Energy Company

105 South 4th Street
Artesia, NM 88210
(575-748-4555)

March 1, 2011

TABLE OF CONTENTS

	Page
I. Introduction	
[API RP-55 7.1].....	1
II. Scope	
[API RP-55 7.2].....	1
III. Plan Availability	
[API RP-55 7.3].....	1
IV. Emergency Procedures	1
[NMAC 19.15.11.9.B(2)(a)][API RP-55 7.4 a.]	
A. Responsibilities and Duties of Personnel During an Emergency	
B. Immediate Action Plan	
C. Telephone Numbers and Communication Methods	
D. Location of Residents, Roads, and Medical Facilities	
E. Evacuation Routes, Muster Areas, and Road Block Locations	
F. Monitoring Equipment, Alarm Systems, Safety Equipment, and Supplies	
V. Characteristics of Hydrogen Sulfide (H₂S), Sulfur Dioxide (SO₂), and Carbon Dioxide (CO₂) [NMAC 19.15.11.9.B(2)(b)][API RP-55 7.4 b.].....	12
A. Characteristics of Hydrogen Sulfide (H ₂ S)	
B. Sulfur Dioxide (SO ₂)	
C. Carbon Dioxide (CO ₂)	
D. Radii of Exposure (ROE)	
VI. Facility Description, Maps, and Drawings	
[AC [19.15.11.9.B(2)(c)][API RP-55 7.4 c.].....	17
A. Dagger Draw Processing Plant	
B. Metropolis Disposal #1 Well	
C. Map of Plant and Well	
VII. Training and Drills	
[NMAC 19.15.11.9.B(2)(d)][API RP-55 7.4 d.].....	19
A. Responsibilities and Duties of Essential Personnel	
B. On-site or Classroom Drills	
C. Notification and Training of Residents on Protective Measures in Emergency Situations	
D. Training and Attendance Documentation	
E. Briefing of Public Officials on Evacuation and Shelter in Place Plans	
VIII. Coordination with State Emergency Plans	
[NMAC 19.15.11.9.B(2)(e)].....	20
A. Oil Conservation Division	
B. New Mexico State Police	
IX. Plan Activation	
[NMAC 19.15.11.9.C][API RP-55 7.4 d.].....	20
A. Activation Levels	
B. Events that Could Lead to a Release	

X. Submission of H₂S Contingency Plans
[NMAC 19.15.11.9.D]..... 21
A. Submission
B. Retention
C. Inventory

MAPS AND FIGURES

- Map 1 Agave Dagger Draw Plant Facilities Locations
- Map 2 General Diagram of Agave Dagger Draw Gas Plant and Location of Pipeline Connecting Plant with Metropolis Disposal #1 Well

Figure 1 Photos of Pipeline

APPENDICES

Appendix A – Facility Maps and Drawings

- Map A-1: Facility Map
- Map A-2: Alarms and Monitors, Dagger Draw Active Equipment
- Map A-3: Safety and Fire Equipment, Dagger Draw Active Equipment
- Map A-4: Evacuation Router, Dagger Draw Active Equipment
- Map A-5: Proposed Perimeter Alarms
- Map A-6: Metropolis Disposal #1 Well

Appendix B – Response Flow Diagram

Appendix C – ROE Calculations

- Map C-1: Facility, Pipeline and Well Site ROE


Appendix D – Muster Areas and Evacuation Routes

- Map D-1: Evacuation Routes to Muster Areas

Appendix E – Distribution List

OPERATOR QUICK REFERENCE GUIDE

Dagger Draw Processing Plant Level 1 Response FOR PLANT OR WELLHEAD ALARMS



Location of Facilities

Agave Dagger Draw Processing Plant (See Map 1)

Go south of Artesia, NM on Hwy 285 approximately 9 miles to County Road 38 (Kincaid Ranch Road). Turn right (west) on Kincaid Ranch Road and go approximately 2.8 miles to Pipeline Road. Turn right (north) and go 0.2 miles to the Dagger Draw Gas Plant Office. Physical address is 278 Pipeline Road, Artesia, NM 88210.

Section 25-Township 18S-Range 25E

Metropolis Disposal #1 Well (See Map 1)

Go south of Artesia, NM on Hwy 285 approximately 9 miles to County Road 38 (Kincaid Ranch Road). Turn right (west) on Kincaid Ranch Road and go 2.6 miles (just past the Agave Field Office). Turn left (south) on dirt lease road and go approximately 0.6 miles then turn left (east) and go 0.2 miles to the Metropolis Disposal #1 Well. **Section 36-Township 18S-Range 25E**

Emergency Trailer – Atoka Facility Location (See Map 1)

From Artesia, drive south on Highway 285 to County Road 39. Turn east and drive approximately 2 miles. The facility is on the south side of the road in NW/NE Sec 14 18S 26 E. See F. 6. (Page 9) for a detailed list of Emergency Trailer contents. The trailer can serve as a mobile resource center or Incident Command Center.

I. Introduction

[API RP-55 7.1]

The Agave Dagger Draw Processing Plant is a natural gas processing plant which handles and/or generates hydrogen sulfide (H₂S) and/or sulfur dioxide (SO₂). This H₂S contingency plan was created to outline procedures that are to be followed in the event of an H₂S release that occurs at the plant, the acid gas well, or on the acid gas pipeline. The response plan is the same regardless of where the release takes place. This plan complies with the **New Mexico Oil Conservation Division (OCD) Rule 11**. The plan and operation of the Dagger Draw Plant also conform to standards set forth in **API RP-55 "Recommended Practices for Oil and Gas Producing and Gas Processing Plant Operations Involving Hydrogen Sulfide"** as well as **API RP-49 "Recommended Practice for Drilling and Well Servicing Operations Involving Hydrogen Sulfide."** The Dagger Draw Plant does not have any storage tanks in which hydrogen sulfide or other gas or gas products are stored, and thus, API regulations and OCD regulations (specifically 19.15.11.12.E NMAC) relative to those types of storage are not applicable for this plant. While there are no known residences or businesses within the 100 ppm radius of exposure (ROE) other than the Agave Dagger Draw Processing Plant, Agave has committed to provide notice to nearby property owners outside of the ROE as detailed in Section C. 4. (Page 6) and Appendix E in the case of an unintended release.

II. Scope

[API RP-55 7.2]

This contingency plan is specific to the Agave Dagger Draw Gas Processing Plant and acid gas injection system. This plan contains procedures to provide an organized response to an unplanned release from the plant, well site and pipeline connecting them and outlines procedures that would be followed to alert and protect any members of the public, residents in surrounding areas and/or contractors working on or around the plant in the event of an unplanned release. All operations shall be performed with safety as the primary goal. Any part of the operation that might compromise the safety of personnel will cease until the operation can be re-evaluated and the proper engineering controls implemented.

III. Plan Availability

[API RP-55 7.3]

This contingency plan shall be available to all personnel responsible for implementing any portion of the plan. Copies of the plan will be distributed to the following agencies: New Mexico Oil Conservation Division (OCD), New Mexico Department of Public Safety, Local Emergency Planning Committee (LEPC), Artesia Fire Department, Atoka Fire Department, Artesia Police Department, and Eddy County Sheriff's Department. The Plan will be available at the following Agave Energy Company locations: Dagger Draw Processing Plant, the Artesia Field Office, Emergency Response Trailer at Atoka (Map 1) and the Agave Main Office in Artesia.

IV. Emergency Procedures

[NMAC 19.15.11.9.B(2)(a)] [API RP-55 7.4 a] [29 CFR 1910.1200]

A. Responsibilities and Duties of Personnel during an Emergency

1. Plant Manager or designee will serve as the Incident Commander (IC); is responsible for training operators assigned to the plant, contractors and visitors on the implementation of this plan; and will maintain communication with Agave management and residents within the radius of exposure (ROE).

2. Plant Supervisor or designee will serve as the Incident Commander (IC) in the absence of the Plant Manager; is responsible for training and supervising plant operators on the implementation of this plan, will maintain accountability of all contractors and visitors; and will maintain communication with the plant manager and Agave management.

3. Plant Operators will perform operations in accordance with this safety plan; assist in the accountability and evacuation of visitors and contractors to designated muster areas; and keep the plant supervisor and manager informed on the repair progress.

4. Essential Agave Personnel will be familiar with the procedures in this plan and assist plant operators in assisting with the implementation of this plan in a safe manner.

5. Visitors and contractors on site will be familiar with safety alarms and signals at the Dagger Draw Gas Processing Plant and the acid gas injection system; and adhere to instructions of Plant Operators and other Agave personnel in evacuation of the facilities.

B. Immediate Action Plan

1. The following outlines the Immediate Action Plan that is illustrated by the response flow diagram in Appendix B. This is to be used when responding to an H₂S release. Response levels are the same for a release at the plant or the acid gas well. Additional or long term response actions will be determined on a case-by-case basis, if needed, once the Incident Command Center (ICC) and System (ICS) are established following the immediate response.

Level	Alarms	Actions
I	Intermittent audible alarm sounded and/or flashing yellow lights activated for H ₂ S at 10 ppm or greater.	<p>1. The audible signal for a Plant emergency and evacuation is an intermittent alarm and yellow lights (repeating off/on) activated when levels of H₂S of 10 ppm or greater are detected. In addition, a flashing yellow light or beacon will be activated at 10 ppm or greater of H₂S. The audible alarm and flashing yellow lights are redundant systems which function independently of one another so that should one system fail, the other would remain active. These systems incorporate back-up battery capabilities as recommended in API RP 55 which insure their operation in the event of a power failure. A computer in the control room and in the Plant Supervisor office establishes which H₂S monitor has activated the alarm and/or flashing yellow beacon, be it a plant monitor or well monitor. At the initial sound of the intermittent alarm or the flashing yellow beacon, assigned operators will put on a 30 minute self-contained breathing apparatus (SCBA). (There are a maximum of four operators at the plant at any one time, and at least seven SCBA devices are located where they are accessible to the operators.) All other personnel in the Plant complex or well site shall immediately evacuate the Plant or well site to the closest Emergency Assembly Area (see Appendix D, Map D-1). If H₂S concentrations are 10 ppm or greater, then personnel will evacuate to a designated Muster Area determined by the Incident Commander (IC) (see Appendix D, Map D-1). The operators, upon suit up with the self-contained breathing apparatus (SCBA), will first help any persons in distress evacuate to the Emergency Assembly Area. If deemed necessary by the Plant Manager or Plant Supervisor, local emergency response service providers will be contacted by Plant personnel designated by the Plant Manager or Supervisor.</p> <p>2. All entities within the 100 ppm radius of impact (ROE) will be notified (by telephone) of a release if the <u>perimeter alarms</u> are activated at 10 ppm H₂S or greater. Notification will be done by personnel designated by the Plant Manager or his designee. The nature of the release and status of containment will be conveyed. Businesses will be advised to report the incident to employees working near the Plant and to alert any third party contractors or service companies working in the Plant vicinity or imminently scheduled to work in the vicinity of the release. All should be instructed to leave the area and not to enter/re-enter area until further notice. It should be noted that at the time of submission of this plan there are no known occupants, businesses or residences within the 100 ppm ROE; however, Agave personnel will make a visual inspection of the ROE area to insure that no individuals are seen inside the ROE, and if any are observed, they will be advised to immediately evacuate to the designated Muster Area, described above.</p> <p>3. Wearing the self-contained breathing apparatus (SCBA), the operator(s) will attempt to fix the cause of the release. The H₂S levels at the Emergency Assembly Area will be monitored with a hand held or personal monitor and with the fixed monitor.</p> <p>4. The Incident Commander (IC) will set up secondary re-entry team(s) with 30 minute self-contained breathing apparatus (SCBA) to re-enter and resolve the situation. Re-entry will occur in 15 minute shifts at the direction of the Incident Commander (IC) until the problem is resolved or the emergency shut down (ESD) is activated. If H₂S levels in the Emergency Assembly Areas exceed 10 ppm H₂S, evacuate to alternate Emergency Assembly Area and continue to monitor Emergency Assembly Area with personal or handheld H₂S monitors. If evacuation to Muster Area occurs, road blocks will be established near the Muster Areas on Kincaid and Pipeline Road. If release is resolved and monitored levels in the Plant are less than 10 ppm H₂S, personnel may re-enter the Plant. The Oil Conservation Division (OCD) shall be notified within four hours of any release that activates the Plan. If the release is not resolved and H₂S levels continue to increase, Level II Response is indicated.</p>

Levels	Alarms	Actions
II	Intermittent audible alarm sounded and/or flashing red lights activated for H ₂ S greater than 20 ppm	<p>1. The intermittent alarm and red flashing lights indicate the detection of H₂S greater than or equal to 20 ppm. (Flashing yellow lights indicate a H₂S release of 10 ppm or greater and they will change to red for a release of 20 ppm or greater.) The audible alarm and flashing red lights are redundant systems which function independently of one another so that should one system fail, the other would remain active. These systems incorporate back-up battery capabilities as recommended in API RP 55 which insure their operation in the event of a power failure. A control panel in the Plant supervisor's office establishes which H₂S monitor has activated the alarm and or flashing red beacon, be it a plant monitor or a well monitor. At the initial sound of the intermittent alarm or observance of the flashing red beacons, the operators will exit to the Emergency Assembly Area specified by the Plant Manager or his designee. All personnel in the Plant complex will put on emergency escape packs located throughout the plant, or at the well location and evacuate, using the evacuation routes to the Emergency Assembly Area (see Appendix A, Maps A-4 and A-6 and Appendix D, Map D-1) and then to the Muster Area (see Appendix D, Map D-1) specified by the Plant Manager or designee. At the assembly area, the Plant Manager or designee may assign operators to put on a 30 minute self-contained breathing apparatus (SCBA). Local emergency response service providers will be contacted by Plant Manager or designee. See Section F. 4. (Page 11) for a listing of respirator equipment.</p> <p>2. All other entities within the 100 ppm radius of impact (ROE) will be contacted by phone and notified of release and asked to evacuate when a <u>perimeter monitor</u> reads 10 ppm H₂S or greater. All entities within the 100 ppm radius of impact (ROE) will be contacted by phone and notified of release. The nature of the release and status of containment will be conveyed. Depending on release status and prevailing wind conditions, some entities within the 100 ppm radius of impact (ROE) may be asked to shelter in place or evacuate. Notifications will include but are not limited to the following:</p> <ul style="list-style-type: none"> a) Other entities within the 100 ppm radius of impact (ROE), depending on release status and prevailing wind conditions, will be asked to shelter in place. Those entities will be instructed to close any windows and shut off any air conditioning/heating until further notice. In addition, they will be instructed to contact other employees/residents not currently present and instruct them not to enter/reenter the area until further instruction. b) If a <u>perimeter monitor</u> is activated, the LEPC and law enforcement will be contacted by phone and notified of the release and status of containment. The Incident Commander (IC) will assign personnel notification responsibility. <p>It should be noted that at the time of submission of this plan there are no known occupants, businesses or residences within the 100 ppm ROE; however, Agave personnel will make a visual inspection of the ROE area to insure that no individuals are seen inside the ROE, and if any are observed, they will be advised to immediately evacuate to the designated Muster Area, described above.</p> <p>3. Operator(s) with 30 minute self-contained breathing apparatus (SCBA) will assess the release and attempt to resolve it. If after 45 minutes on scene there is no resolution, the operator(s) will notify the Plant Manager to determine if the emergency shut down (ESD) should be activated.</p> <p>4. If monitored H₂S levels at Muster Area exceed 10 ppm, evacuate to an alternate Muster Area. If deemed necessary, local emergency response service providers will be contacted by the Incident Commander (IC).</p> <ul style="list-style-type: none"> a) Re-entry will occur in full self-contained breathing apparatus (SCBA) and in 15 minute shifts at the direction of the IC until IC determines problem has been resolved or emergency shut downs (ESDs) are activated. b) If release is resolved and monitored levels of H₂S in the Plant are less than 10

		<p>ppm, personnel may return to Plant. The Oil Conservation Division (OCD) shall be notified within four hours of any release that activates the Plan. All entities previously notified will be informed that the release has been resolved and advised of the current monitored H₂S levels at the Plant.</p> <p>c) No resolution requires activation of Level III Response with notifications and reporting as per Plan. If the release is not resolved and/or H₂S levels continue to increase, Level III Response is indicated.</p> <p>d) Monitoring will continue after problems are abated, at the direction of the Plant Manager.</p> <p>5. Initiate and maintain a Chronological Record of Events log.</p>

Level	Alarms	Actions
III	<p>Intermittent audible alarm sounded and/or flashing red lights activated for catastrophic release; fire; or explosion</p> <p>ESD alarm is a continuous siren with red, amber, and blue lights that flash</p>	<ol style="list-style-type: none"> 1. If H₂S is at 20 ppm or greater and repair efforts at Level II have been unsuccessful, worst case scenario, and/or catastrophic release have occurred, then a Level III response will be implemented. 2. Road blocks will be set up near the Muster Areas on Kincaid Road and Pipeline Road (see Appendix D, Map D-1). 3. All personnel shall have evacuated to a designated Muster Areas. Evacuation of all entities within the 500 ppm radius of impact (ROE) will have been confirmed. Implement full H₂S Plan with all notifications and public agency involvement. Notifications to all entities within the 100 ppm radius of impact (ROE) will include the nature of the release and status of containment. Notifications will include but are not limited to the following: <ol style="list-style-type: none"> a) All businesses within the 100 ppm radius of impact (ROE) will be instructed to immediately alert all company personnel, third party contractors and/or services companies working in the area, and those imminently scheduled to work in the area, of the release and evacuation status of the Plant. They will be instructed to immediately leave and/or not enter/reenter the area within the roadblocks until further instruction. b) All other entities (including private residents) within the 100 ppm radius of impact (ROE) will be instructed to immediately shelter in place, if appropriate based on the source of the release and the wind direction. Those entities will be instructed to close any windows and shut off any air conditioning/heating until further notice. In addition, they will be instructed to contact other employees/residents not currently present to not enter/reenter the area until further instruction. c) The Incident Commander (IC) will make the decision based on, but not limited to, H₂S concentration and wind direction, whether a safe evacuation can be implemented, and recommend an evacuation route. <p>It should be noted that at the time of submission of this plan there are no known occupants, businesses or residences within the 100 ppm ROE; however, Agave personnel will make a visual inspection of the ROE area to insure that no individuals are seen inside the ROE, and if any are observed, they will be advised to immediately evacuate to the designated Muster Area, described above.</p> 4. If escaping vapors have ignited, the vapors should be allowed to continue to burn unless the fire endangers personnel, other property, or other equipment. 5. When applicable, maintain communication with the Plant Manager, or his designee, to keep him up-to-date of the situation and the action taken prior to his arrival at the location. 6. Initiate and maintain a Chronological Record of Events log. 7. Within one hour after the activation of the H₂S Plan, begin agency notifications by calling Oil Conservation Division (OCD) and National Response Center (NRC). 8. Establish media staging area adjacent to Muster Area 2 and direct all media to it. 9. Once resolved and monitored levels in the Plant and at Muster Area are less than 10 ppm, roadblocks will be removed, and all entities within the 100 ppm radius of impact (ROE) will be allowed to return. All entities previously notified will be informed that the release has been resolved and advised of the current monitored H₂S levels. 10. Monitoring will continue after problems are abated, at the direction of the Plant Manager 11. Agency reports to be submitted as required.

C. Telephone Numbers and Communication Methods

1. Emergency Services

AGENCY	TELEPHONE #
Artesia Fire Department	(575) 946-5050
Atoka Fire Department	(575) 946-5050
Artesia Police Department	(575) 746-5000
Eddy County Sheriff	(575) 887-7551
Carlsbad Police Department	(575) 885-2111
State Police (HMER)	
District 3 Roswell	(575) 827-9312
Sub District 3 Carlsbad	(575) 885-3138
Sub District 3 Hobbs	(575) 827-9320
Ambulance Services	
Artesia	(575) 746-5050
Carlsbad	(575) 885-2111
Hospitals	
Artesia General	(575) 748-3333
Carlsbad Medical Center	(575) 887-4100
<i>Veterinarians</i>	
Artesia Animal Clinic	(575) 748-2042
Livingston Animal Clinic	(575) 746-6167
Helicopter Services	
Lifeguard (Albuquerque)	1-800-633-5438
Southwest Medivac (Hobbs)	1-800-242-6199
AeroCare (Lubbock)	1-800-627-2376
Air Med (El Paso)	(915) 772-1449

2. Government Agencies

AGENCY	TELEPHONE #
Oil Conservation Division (OCD)	(505) 476-3440 (575) 748-1283
US BLM	(575) 887-6544
Local Emergency Planning Committee (LEPC)	(575) 887-9511
National Response Center (NRC)	1-800-424-8802

3. Operators and Contractors

COMPANY	TELEPHONE #
CVE	(575) 746-3571
PVT	(575) 748-1241
DCP Midstream	(800) 435-1679
Chevron/West Texas Pipeline Company	(800) 762-3404
Transwestern Pipeline	(281) 714-2265
Yates Petroleum Corporation	(575) 748-1471

4. Public

Name	Address	TELEPHONE #
David and Diana Wilson	80 West Kincaid Ranch Road	(575) 457-2309
Raul and Delilah Baeza	193 West Kincaid Ranch Road	(575) 308-3195
Efrin and Maria Baeza	179 West Kincaid Ranch Road	(575) 513-0471
Christine Baeza	175 West Kincaid Ranch Road	(575) 457-2585

5. Agave Internal Call List

NAME	TITLE	Office #	Cell #
J.B. Smith	President	(575) 748-4414	(575) 365-8517
Rusty Nasta	Operations Manager	(575) 748-4523	(575) 626-7971
Ivan Villa	Engineering Supervisor	(575) 748-4528	(575) 365-4888
Jennifer Knowlton	Environmental Engineer	(575) 748-4528	(505) 238-3588
Robert Moorhead	Plant Manager/South Mechanical Supervisor	(575) 748-6815	(575) 365-4840
Gary Greenwood	Plant Supervisor	(575) 748-8414	(575) 365-6794
Mark Smith	PSM Coordinator/Plant Operator	(575) 748-8410	(575) 365-5053
Dustin McNeely	Plant Operator	N/A	(575) 703-5493
Justin Troublefield	Plant Operator	N/A	(575) 365-7503
Glen Blake	Regulatory Coordinator	(575) 748-4546	(575) 626-8168
Bill Johnson	South Measurement Supervisor	(575) 748-6816	(575) 365-4615
Jason Fuentes	South Pipeline Supervisor	(575) 748-4518	(575) 365-8939

6. Agave Energy Company will use 2-way radios and telephones to communicate internally. Telephone will be used for external communication. Land lines and high speed internet access are available at the plant office.

D. Location of Nearby Residences, Roads, and Medical Facilities

- The following residences are located within the ROE of the:
 - Plant — None
 - Metropolis Disposal #1 Well – None
 - Pipeline – None
- The following roads are located within the ROE:
 - Kincaid Ranch Road
 - Pipeline Road
- There are no medical facilities located within the ROE.
- It should be noted that at the time of submission of this plan there are no known occupants, businesses or residences within the 100 ppm ROE; however, Agave personnel will make a visual inspection of the ROE area to insure that no individuals are seen inside the ROE, and if any are observed, they will be advised to immediately evacuate to the designated Muster Area, described above.

E. Evacuation Routes, Emergency Assembly Area, Muster Areas, and Road Block Locations

1. Evacuation Routes, Emergency Assembly Area, and Muster Areas are depicted on Maps A-4 and A-6 in Appendix A and Map D-1 in Appendix D.
2. Pre-planned road block locations are designated near the muster areas on Pipeline Road and Kincaid Ranch Road and are depicted on Map D-1 in Appendix D. Each location will have pre-positioned, portable road barriers with lights. The locations will have flashing lights and warning signs. If the release is sufficient to require evacuation to muster areas, then roadblocks near the muster areas on Kincaid Ranch Road and Pipeline Road to the west and north of the facility, respectively, will be established. The Incident Commander (IC) will designate a representative to staff each of the two roadblocks. If deemed necessary by the Incident Commander (IC), the State or Local Police will be asked to assist with maintaining the roadblocks.
3. Emergency lights on the Muster Area signs will be activated by any perimeter alarm of 10 ppm or greater H₂S or Level III activation.

F. Monitoring Equipment, Alarm Systems, Safety Equipment, and Supplies Available

1. EMERGENCY SHUTDOWN SYSTEM (ESD): There are (8) ESD manual stations located at various points in the facility. See Maps A-2 and A-3 in Appendix A. The Plant ESD can be activated at any time by any employee or at the direction of the Incident Commander (IC). If any of the perimeter H₂S sensors at the plant detect a concentration of 10 ppm or higher the Plant ESD is automatically activated.

When any one of the eight (8) manual stations is activated, the system will be shutdown and the natural gas inlets and outlets will be blocked. The operators are also able to auto close the one (1) main block valve on the incoming gas line to the Plant. Activating these should allow the plant to avoid a Level III response. The Incident Commander (IC) can send trained personnel to designated off-site manual block valves. There are also various methods to shut down gas flow at the various wellheads and incoming gathering lines. These can and would be evaluated on a case by case basis.

Designated employees will have remote access to the plant controls including ESD capabilities.

2. PLANT ALARMS, VISIBLE BEACONS & WIND INDICATORS: Colored beacons, horns, and wind direction indicators are located in various locations throughout the Plant and are indicated in Appendix A on Maps A-2, A-3, and A-6.

The audible signal for an emergency response and Plant evacuation is a repeating intermittent alarm that sounds at H₂S concentrations of 10 ppm or greater. The alarm will remain intermittent when the concentration of the H₂S release is 20 ppm or higher. At the initial sound of this intermittent alarm, the plant operators will evacuate to the emergency assembly area put on a self-contained breathing apparatus (SCBA) and all personnel in the plant complex shall immediately proceed in a safe manner to the Emergency Assembly Areas as prescribed by the Emergency Action Plan.

A flashing red beacon signifies an H₂S release of 20 ppm or higher and all personnel in the plant complex shall immediately proceed in a safe manner to the Emergency Assembly Area located outside of the plant office. If this area is not determined to be safe, all will move to designated Muster Area. Evacuation routes and Muster Areas are indicated on the map in Appendix A, on Map A-4 and A-6 as well as Appendix D, on Map D-1.

A routine process alarm will cause a horn to sound. This horn sound is used to alert the plant Operator to return to the Control Room. No emergency response or evacuation is required when this horn sounds.

Wind direction indicators are installed throughout the plant. At least one wind direction indicator can be seen at any location within the Plant complex, as well as from any point on the perimeter of the plant. There are ten (10) windsocks located in the Plant.

3. GAS DETECTION EQUIPMENT: The Plant uses a Smart Sensor System™ fixed plant H₂S Sensors. These sensors are a fixed point monitoring system used to detect the presence of hydrogen sulfide in ambient air. The yellow flashing beacon is activated at H₂S concentrations of 10 ppm or greater. The horn is activated with an intermittent alarm at H₂S concentrations of 10 ppm or greater. The lights change to red at 20 ppm H₂S and the horn remains intermittent. The fixed hydrogen sulfide monitors are strategically located throughout the Plant to detect an uncontrolled released of hydrogen sulfide. The Plant operators are able to monitor the H₂S level of all the Plant sensors on the control monitor located in the control room and the Dagger Draw Plant Field Office. In addition, select employees can access this information remotely. These sensors are located on the plot plan in Appendix A, Maps A-2 and A-3. These sensors all have to be acknowledged and will not clear themselves. This requires immediate action for any occurrence or malfunction. The Plant sensors have battery backup systems and are calibrated monthly. Audible alarm systems are also calibrated monthly.

Redline™ wireless H₂S detectors with battery backup systems are installed along the perimeter of the plant and the perimeter of the acid gas disposal well. Perimeter H₂S detectors report to the Redline monitor every five minutes to confirm detector functionality. Once H₂S gas is detected, the H₂S detectors report to the monitor every five seconds. The detectors will go into alarm at H₂S values of 10 ppm and above. Redline H₂S head unit locations are depicted on Map A-5 and A-6 in Appendix A.

Handheld gas detection monitors are available to plant personnel to check specific areas and equipment prior to initiating maintenance or work on the process equipment. There are 3 handheld monitors and each individual is assigned a personal H₂S monitor. The handheld gas detection devices are Industrial Scientific ITX 3-gas detectors and BW Gas Alert Micro 5 4-way monitors. The detectors have sensors for oxygen, LEL (explosive hydrocarbon atmospheres), hydrogen sulfide, and carbon dioxide. They indicate the presence of H₂S with a beeping sound at 10 ppm. The beeps change in tone as H₂S increases to 20 ppm. The personal monitors are set to alarm (beep) at 10 ppm with the beeps becoming closer together as the H₂S concentration increases to 20 ppm. Both the handheld and personal monitors have digital readouts of H₂S ppm concentration.

- a) The compressor building has two methane sensors; one sends a call out at 30% lower explosive limit (LEL); the second shuts the compressors down at 50% lower

explosive limit (LEL). The methane sensors are visual and audible alarms. The compressor building also is equipped with fire eyes that will also shut the units down. The four product pumps also have LEL sensors.

4. RESPIRATORS: The facility has seven (7) 30 minute self-contained breathing apparatus (SCBA) respirators and six (6) 5 minute escape packs strategically located throughout the Plant. There are also five (5) emergency packs with supplied air lines distributed throughout the plant. The respirator locations are identified in Appendix A on Maps A-3 and A-6. All Plant personnel are certified to use the self-contained breathing apparatus (SCBA) respirators and emergency packs.

5. FIRE FIGHTING EQUIPMENT: The Plant personnel are trained only for insipient stage fire fighting. The fire extinguishers located in the Plant process areas, compressor buildings, process buildings, and company vehicles are typically a 20# ABC dry chemical fire extinguisher. See Appendix A, Maps A-3 and A-6 for locations. The Plant does not have a fire water system, only a utility water system that is not designed for fire fighting.

6. EMERGENCY RESPONSE TRAILER AND EQUIPMENT: Agave Energy Company has an Emergency Response Trailer located at the Atoka Facility (Map 1; Map D-2 Appendix D). This is located outside all radii of exposure (ROE) from the facility along the pipeline to the well.

Driving Directions: From Artesia, drive south on Highway 285 to County Road 39. Turn east and drive approximately 2 miles. The facility is on the south side of the road in the NW/NE Sec 14 18S 26 E. See Map D-2 in Appendix D. The trailer can serve as a mobile resource center or Incident Command Center.

a) EMERGENCY RESPONSE TRAILER CONTENTS

- 2 wind socks / wind direction indicators w/poles & spares
- 1 – 110 volt generator, portable w/wheels
- 4 5-gas sensor ambient monitors (O₂, SO₂, LEL, CO, H₂S) with automatic air pumps (15 sec per foot) and data logging capability
- 1 calibration unit for monitors
- 5 intrinsically safe communication radios & chargers, 32 channel with capability to be programmed to fire service and police channels
- 4 20# stored pressure, ABC class Fire Extinguishers
- 4 4500 Grade D breathing air cylinders, regulator, low pressure alarm, and hose reel w/ 300 ft hose (total) and correct quick disconnects.
- 1 stretcher
- 1 20-person First Aid Kit with burn gel packets
- 4 30-minute SCBA's
- 4 work unit SCBA's
- 2 lights, mounted on each rear of trailer for night operations
- 2 hand cleaner for decontamination of petroleum products.
- 3 traffic Control Kits
- 1 emergency flare gun for lighting uncontrollable hazardous gases
- 2 full body harness and 150' X 2 lifelines
- 2 "Hazardous Area" "Do Not Enter" signs / barricades

- 2 burn gel blankets
- 1 set of maps and Emergency Response Plans
- 4 temporary use Nomex Fire retardant clothing (2-LG & 2-XLG)

7. TRAFFIC CONTROL KIT CONTENTS

- 3 electronic road flares
- 1 28" stop sign paddle
- 4 reflective traffic control vests
- 2 emergency signal wands
- 1 emergency Response Guidebook

8. FIRST AID EQUIPMENT LOCATIONS:

- a) First Aid Kits are located at the following locations:
 - Lab
 - Office
- b) Eye Wash stations are located at the following locations:
 - Lab
 - Office

9. PERSONAL H₂S MONITORS: All Agave personnel assigned to the Plant and associated field personnel are issued personal H₂S monitors.

10. SIGNS and MARKERS: The Plant has warning signs indicating the presence of "H₂S/Poisonous Gas" and high pressure gas at the entrance to the Plant. Emergency response phone numbers are posted at the entrance to the Plant. Signs are located at the Plant gate entrance indicating that all visitors are to sign in.

V. Characteristics of Hydrogen Sulfide (H₂S), Sulfur Dioxide (SO₂) and Carbon Dioxide (CO₂) [NMAC 19.15.11.9.B(2)(b)] [API RP-55 7.4 b.]

A. Hydrogen Sulfide (H₂S): Hydrogen Sulfide (H₂S): The proposed inlet gas streams into the Plant will contain a maximum of 7,600 ppm (or 0.76 mole percent) of hydrogen sulfide based on data generated from the sampling of the inlet gas at least daily. Hydrogen sulfide is a colorless, toxic and flammable gas, and has the odor of rotten eggs. Hydrogen sulfide gas is heavier than air. Hydrogen sulfide presents a significant health hazard by paralyzing the respiratory system resulting in serious injury or death.

Hydrogen Sulfide Properties and Characteristics	
CAS No.	7783-06-4
Molecular Formula	H ₂ S
Molecular Weight	34.082 g/mol
Ceiling Concentration	20 ppm (OSHA)
Ceiling Peak Concentration	50 ppm (OSHA)
Threshold Limit Value (TLV)	15 ppm (ACGIH)
Time Weighted Average (TWA)	10 ppm (NIOSH)
Short Term Exposure Level (STEL)	15 ppm (ACGIH)
Immediately Dangerous to Life or Health (IDLH)	100 ppm
Specific Gravity Relative to Air (Air=1.0)	1.189
Boiling Point	-76.5F

Freezing Point	-121.8F	
Vapor Pressure	396 psia	
Autoignition Temperature	518F	
Lower Flammability Limit	4.3%	
Upper Flammability Limit	46.0%	
Stability	Stable	
pH in water	3	
Corrosivity	Reacts with metals, plastics, tissues and nerves	
Physical Effects of Hydrogen Sulfide		
Concentration		
ppm	%	Physical Effects
1	0.00010	Can be smelled (rotten egg odor)
10	0.0010	Obvious & unpleasant odor; Permissible exposure level; safe for 8 hour exposure
20	0.0020	Acceptable ceiling concentration
50	0.0050	Loss of sense of smell in 15 minutes
100	0.0100	Immediately dangerous to life and health(IDLH) loss of sense of smell in 3-15 minutes; stinging in eyes & throat; Altered breathing
200	0.0200	Kills smell rapidly; stinging in eyes & throat
500	0.0500	Dizziness; Unconscious after short exposure; Need artificial respiration
700	0.0700	Unconscious quickly; death will result if not rescued promptly
1000	0.1000	Instant unconsciousness; followed by death within minutes

Sulfur Dioxide (SO₂): Sulfur dioxide is produced as a by-product of H₂S combustion at the flare. The flare unit receives the residual hydrogen sulfide and carbon dioxide stream that is routed from the amine unit. It is colorless, transparent, and is non-flammable, with a pungent odor associated with burning sulfur. Sulfur dioxide is heavier than air, but will be picked up by a breeze and carried downwind at elevated temperatures. Sulfur dioxide can be extremely irritating to the eyes and mucous membranes of the upper respiratory tract.

Sulfur Dioxide Properties & Characteristics	
CAS No.	7446-09-5
Molecular Formula	SO ₂
Molecular Weight	64.07 g/mol
Permissible Exposure Limit (PEL)	5 ppm(OSHA)
Time Weighted Average (TWA)	2 ppm(ACGIH)
Short Term Exposure Level (STEL)	5 ppm(ACGIH)
Immediately Dangerous to Life and Health (IDLH)	100 ppm
Specific Gravity Relative to Air (Air = 1.0)	2.26
Boiling Point	14°F
Freezing Point	-103.9°F
Vapor Pressure	49.1 psia
Auto ignition Temperature	N/A
Lower Flammability Limit	N/A
Upper Flammability Limit	N/A
Stability	Stable
Corrosivity	Could form an acid rain in aqueous solutions
Physical Effects of Sulfur Dioxide	
Concentration	Effect
1 ppm	Pungent odor, may cause respiratory changes
2 ppm	Permissible exposure limit; Safe for an 8 hour exposure
3-5 ppm	Pungent odor; normally a person can detect sulfur dioxide in this range
5 ppm	Short Term Exposure Limit (STEL); Safe for 15 minutes of exposure
12 ppm	Throat irritation, coughing, chest constriction, eyes tear and burn
100 ppm	Immediately Dangerous To Life & Health (IDLH)
150 ppm	So irritating that it can only be endured for a few minutes
500 ppm	Causes a sense of suffocation, even with first breath
1,000 ppm	Death may result unless rescued promptly.

B. Carbon Dioxide (CO₂): The proposed inlet streams into the Plant will contain a maximum of 383,100 ppm (or 38.31 mole percent) of carbon dioxide based on data generated from the sampling of the inlet gas at least daily. Carbon dioxide gas is colorless, odorless and non-flammable and is heavier than air.

Carbon Dioxide Properties & Characteristics	
CAS No.	124-38-9
Molecular Formula	CO ₂
Molecular Weight	44.010 g/mol
Time Weighted Average (TWA)	5,000 ppm
Short Term Exposure Level (STEL)	30,000 ppm
Immediately Dangerous to Life and Health (IDLH)	40,000 ppm
Specific Gravity Relative to Air (Air = 1.0)	1.5197
Boiling Point	-109.12°F
Freezing Point	-69.81°F
Vapor Pressure	830 psia
Autoignition Temperature	N/A
Lower Flammability Limit	N/A
Upper Flammability Limit	N/A
Stability	Stable
pH in Saturated Solution	3.7
Corrosivity	dry gas is relatively inert & not corrosive; can be corrosive to mild steels in aqueous solutions
Physical Effects of Carbon Dioxide	
Concentration	Effect
1.0 %	Breathing rate increases slightly
2.0 %	Breathing rate increases to 50% above normal level. Prolonged exposure can cause headache, tiredness
3.0 %	Breathing rate increases to twice normal rate and becomes labored. Weak narcotic effect. Impaired hearing, headache, increased blood pressure and pulse rate
4 – 5 %	Breathing increases to approximately four times normal rate, symptoms of intoxication become evident, and slight choking may be felt
5 – 10 %	Characteristic sharp odor noticeable. Very labored breathing, headache, visual impairment, and ringing in the ears. Judgment may be impaired, followed within minutes by loss of consciousness
10 – 100 %	Unconsciousness occurs more rapidly above 10% level. Prolonged exposure to high concentrations may eventually result in death from asphyxiation

C. Radii of Exposure (ROE) [NMAC 19.15.11.7.K]

The basis for worst case scenario calculations is as follows:

- The hydrogen sulfide content of the inlet natural gas stream into the Agave Dagger Draw Gas Plant is variable, ranging upwards to 7,600 parts per million (ppm) or 0.76 mole percent. In reality, the actual H₂S concentration that the plant processes will be much less than this.
- The inlet gas H₂S concentration of 0.76 mole percent was determined using a mass-balance approach, an analysis of 60.8 mole percent H₂S in the acid gas stream and a maximum acid gas flow rate of 0.5 MMSCFD. It is assumed that the amine system removes 100% of the H₂S from the inlet gas.
- The plant has a maximum daily (24 hour) processing volume of 40 MMSCF.
- The worst case scenario radius of exposure (ROE) also assumes an uncontrolled instantaneous release from the area around either the Metropolis Disposal #1 Well, the amine still at the facility and/or at any point along the pipeline connecting the two of the above referenced volume and concentration. Because the Plant is a throughput process plant, it is impossible that the entire 24 hour-throughput volume of the Plant could be released instantaneously as is assumed in the worst case scenario calculations of the ROE. However, to comply with NMAC 19.15.11, that assumption is the worst case scenario in the formulas/calculations provided here.

It should further be noted that the reason this rate, used as worst case, could not be released over a 24 hour period is the Plant's emergency shutdown (ESD) systems would be activated. The emergency shutdown (ESD) would prevent the flow of gas into the Plant in the event of an emergency. See Appendix C and Map C-1 for more information.

The formulas for calculating the two radius of exposure (ROE) are as follows:

100 ppm Radius of Exposure Calculation (as per 19 NMAC 15.11.7.K.1):

$$X = [(1.589)(\text{hydrogen sulfide concentration})(Q)]^{(0.6258)}$$

500 ppm Radius of Exposure Calculation (as per 19 NMAC 15.11.7.K.2):

$$X = [(0.4546)(\text{hydrogen sulfide concentration})(Q)]^{(0.6258)}$$

Where:

X = radius of exposure in feet

"hydrogen sulfide concentration" = the decimal equivalent of the mole or volume fraction of hydrogen sulfide in the gaseous mixture

Q = Escape rate expressed in cubic feet per day (corrected for standard conditions of 14.73 psi absolute and 60 degrees Fahrenheit)

Amine Unit (Facility)

500-ppm ROE	1648 feet
100-ppm ROE	3606 feet

Pipeline

500-ppm ROE	1648 feet
100-ppm ROE	3606 feet

Acid Gas Disposal Well

500-ppm ROE	1648 feet
100-ppm ROE	3606 feet

The ROE for the facility, pipeline and well are shown on Map C-1 of Appendix C. This ROE pattern is designed to include the 100 and 500 ppm radii for a potential worst case failure at any point in the system from the facility at the north to the well to the south.

VI. Facility Description, Maps, and Drawings

[NMAC 19.15.11.9.B(2)(c)] [API RP-55 7.4 c.]

A. Dagger Draw Processing Plant Description of Operations- The primary function of the plant is to remove H₂S and CO₂ from sour field gas so that the gas can meet pipeline specifications. The plant has been designated a primary Standard Industrial Classification (SIC) Code of 1311. The operation of the Agave Dagger Draw Gas Plant is intended to process 40 MMSCFD of gas. The facility is authorized to operate continuously (8,760 hr/yr) at design maximum capacity processing rates. The gas will be treated to remove acid gas components, dehydrated to remove water and processed to remove heavy (liquid) hydrocarbons from the gas stream. Several plant systems will be involved to perform these functions.

The amine unit is designed to remove acid gas components (carbon dioxide, hydrogen sulfide and mercaptans) from the natural gas stream. These components are removed from the natural gas because they are corrosive, hazardous to health, and reduce the heating value of the natural gas stream. In addition, the carbon dioxide can freeze in the cryogenic unit forming dry ice and forcing the shutdown of the facility. This is known as the gas sweetening process. The acid gas removed by the amine unit will be disposed of by either acid gas injection into a disposal well or by incinerating in a flare. The preferred method of disposal will be to compress the gas and inject it into the well. Under emergency situations, the gas will be flared to prevent the emission of lethal hydrogen sulfide to atmosphere.

The glycol dehydration unit will receive approximately 40.0 MMSCFD of treated gas (sweet) from the amine unit and reduce the water content of the gas by circulating triethylene glycol (TEG). Molecular sieve dehydration is used upstream of the cryogenic processes to achieve a -150°F dew point. The process uses two molecular sieve vessels with one vessel in service absorbing moisture from the gas stream and the other vessel in the regeneration mode.

The cryogenic unit is designed to liquefy natural gas components from the sweet, dehydrated inlet gas by removing work (heat) from the gas by means of the turbo expander. The cryogenic unit recovers natural gas liquids (NGL) by cooling the gas stream

to extremely cold temperatures (-150°F) and condensing components such as ethane, propane, butanes and heavier hydrocarbons. Once the sweet, dry gas exits the cryogenic unit, it needs to be recompressed to approximately 800 to 1200 psi before the gas is sent to the main transportation pipeline. This is accomplished with two 2500 horsepower electric drive compressors.

The hot oil system in the plant is used to provide heat to certain processes within the facility. The system will circulate approximately 600 GPM of hot oil and deliver 15.5 MMBTU/hr to other processes.

B. Metropolis Disposal #1 Well Description of Operations- The low pressure (< 10 psig), acid gas stream from the amine unit is routed to the acid gas compressor. The stream is then subject to a series of compression and cooling cycles, thus dehydrating and compressing the acid gas stream to the required injection pressure of approximately 1100-1600 psig which is well under the maximum allowable working pressure for the pipeline of 2350 psig. The high pressure acid gas stream then flows through a 2" stainless steel pipeline to the injection well site. At this point, the stream is introduced into the well.

There are a number of safeguards designed to prevent leaks or overpressure of the system. The acid gas compressor is equipped with multiple pressure transmitters. These transmitters monitor compressor suction and discharge pressures and are programmed to shut the acid gas system down when the pressures fall outside a pre-programmed operating range. As an additional safeguard, the compressor panel is also equipped with high and low pressure shutdowns for each stage of compression that will shut the compressor down when pressures reach preset high and low pressure set points.

As shown on Map 2, the acid gas pipeline runs from the Agave Dagger Draw Plant in a southwesterly direction, crosses Kincaid Ranch Road at the plant boundary and continues southwesterly along a gravel road for approximately 3680 feet. The pipeline then turns east along the Metropolis Disposal #1 Well access road for an additional 900 feet to the wellhead. South of Kincaid Ranch Road, the pipeline and well are entirely contained within Section 36, Township 18 South, Range 25 East. This land is owned by the State of New Mexico. Agave Energy has the following three Rights-of-Way from the State of New Mexico in this section for the pipeline: R18068, R17745 and R17949. The Metropolis Disposal #1 Well Site is covered under Yates Petroleum Company Oil Leases VO-6141-0000 and E1-0165-0001. The pipeline is buried at a depth of 6-1/2 feet for its entire length and is marked, as required, with permanent surface markers. (See Map 2 and Figure 1)

The acid gas pipeline is constructed from 2" inch 304 stainless steel tubing consistent with NACE standards for sour gas service. The pipeline has been designed with a maximum allowable working pressure of 2350 psig. In order to assure the safety of the pipeline system, the acid gas pipeline is contained within a 6" SDR 11 polyethylene pipeline (rated at 100 psig) which is swept from the wellhead location to the main plant with pure "sweet" gas for leak detection purposes. This "sweet" gas stream flows through the annulus between the 6" and 2" pipelines at a preset pressure of 5 psig and flow rate sufficient to continuously be monitored by a Delmar™ H₂S gas analyzer. This sweet gas stream is monitored continuously for H₂S and over/ under pressure. If any one variable falls outside the narrow predetermined operating range, the automatic safety valves are activated, the acid gas compressor is shut down and the acid gas stream is routed to the flare.

The injection string within the well is also constructed with multiple safety features which include L80 FX FJ 2 7/8" corrosion resistant tubing stabbed into a Halliburton 13-20# permanent packer, made of Incoloy® 925 with fluorel elements set at 9,857 ft and an automated Halliburton subsurface safety valve also made of Incoloy® 925, set at 250 ft. Incoloy® 925 is a nickel-iron chromium alloy that is resistant to corrosion and pitting. This valve is designed to isolate and automatically shut in the injection well if a leak occurs along the acid gas pipeline or at the surface of the well. The annular space between the tubing and the production casing above the packer is filled with diesel which is designed to allow the pressure in the annular space to be monitored and recorded continuously. If a pressure excursion outside of the narrow predetermined operating range occurs, the acid gas compressor is shut down and the automatic safety valves at the pipeline inlet (located at the plant) and at the wellhead are automatically closed preventing any escape of acid gas. The acid gas stream would then be routed to the flare until the problem with the well is corrected and the system can be safely re-started. These redundant systems are compliant with API RP 55 and API RP 49, various applicable NACE standards for sour service and current best management practices.

C. Map of Plant and Metropolis Disposal #1 Well

See Appendix A, Map A-1

VII. Training and Drills

[NMAC 19.15.11.9.B(2)(d)] [API RP-55 7.4 d]

A. Responsibilities and Duties of Essential Personnel

1. Personnel responsible for implementing this plan shall be trained on their duties and responsibilities related to this plan during the annual on-site or table top training exercises.
2. Plant Orientation Training - All Plant personnel, visitors, and contractors must attend a Plant overview orientation prior to obtaining permission to enter the Plant. A refresher course on this training is required annually for all persons. This training also complies with the requirements of the Agave Energy Company Process Safety Management Program and Procedures Manual.

B. On-site or Classroom Drills

Agave Energy Company may use table top exercises as well as hands on emergency response training methods. Agave Energy Company shall conduct a table top exercise annually at a minimum.

C. Notification and Training of Others on Protective Measures in Emergency Situations

While at the time of submission of this plan there are no residences or businesses within the 100 ppm ROE, nearby residents who live outside of the ROE will be invited to participate in and/or observe annual drills, where they will be briefed on notification, evacuation, and shelter in place options such as closing windows and shutting off any air conditioning/heating until they are notified that it is safe.

D. Training and Attendance Documentation

All training and drills will be documented. Documentation shall include sign in sheets, synopsis of the training conducted, and an after action review of the training.

E. Briefing of Public Officials on Evacuation and Shelter in Place Plans

Local law enforcement, first responders, and fire personnel will also be invited to participate and/or observe annual drills, as well as being briefed on notification, evacuation, and shelter in place plans.

VIII. Coordination with State Emergency Plans

[NMAC 19.15.11.9.B(2)(e)]

A. Oil Conservation Division (OCD)

1. Oil Conservation Division (OCD) will be notified with an automatic email to the District II office advising of the activation of the H₂S Contingency Plan if any of the alarms are activated at 10 ppm H₂S or greater. In the event of a power failure, a phone call will be made within four hours. All subsequent paperwork will be filed in a timely fashion.

B. New Mexico State Police/ New Mexico Hazardous Materials Emergency Response Plan

1. The New Mexico State Police are responsible for overall scene management and coordination of all resources. A designated Emergency Response Officer (ERO) will establish the National Interagency Incident Management System (NIIMS) Incident Command System (ICS) as the Incident Commander (IC) and be responsible for management of all response resources on scene. Off-scene coordination of response resources will be handled through designated Headquarters Emergency Response Officers. Law enforcement-related activities will be coordinated by State Police.

IX. Plan Activation

[NMAC 19.15.11.9.C] [API RP-55 7.4 d]

A. Activation Levels

Level I– Intermittent alarm sounded and/or flashing amber beacons activated for H₂S greater than or equal to 10 ppm

Level II – Intermittent alarm sounded and/or flashing red beacons activated for H₂S greater than or equal to 20 ppm

Level III–Catastrophic release; fire; explosion; a continuous release of maximum volume for 24 hours; or NMAC 19.15.11: mandatory activation of indication of 100 ppm in any defined public area; 500 ppm at any public road; or 100 ppm at a distance greater than 3000 feet from the site or the release. Because the 100 ppm radius of impact (ROE) boundary is greater than 3000 feet from the site of release, a Level III response would occur before the escape of the 24 hour release volume.

B. Events that Could Lead to a Release of H₂S

- Inlet and plant piping failure
- Amine still failure
- Flange/gasket leaks on inlet and plant piping
- Flange/gasket leaks on the acid gas compressor
- Flange/gasket leaks at metropolis disposal well
- Failure of acid gas pipeline
- Valve packing
- Seal failure on acid gas compressor
- Failure of flare to ignite during Plant emergency blow down

X. Submission of H₂S Contingency Plans

[NMAC 19.15.11.9.D]

A. Submission

1. Agave Energy Company will submit the H₂S Contingency Plan to the Oil Conservation Division (OCD).

B. Retention

1. Agave Energy Company shall maintain a copy of the contingency plan in the Main Office at 105 South 4th Street in Artesia, NM. The plan shall be readily accessible for review by the Oil Conservation Division (OCD) upon request.

C. Inventory


1. Agave Energy Company will file an annual inventory of wells, facilities and operations for which plans are on file with the Oil Conservation Division (OCD), to the Local Emergency Planning Committee (LEPC) and the State Emergency Response Commission as per NMAC 19.15.11.
2. The inventory shall include the name, address, telephone number, and point of contact for all operations in which plans are on file.

MAPS AND FIGURES

MAP 1: Agave Dagger Draw Plant Facilities Locations

**MAP 2: General Diagram of Agave Dagger Draw Gas Plant and Location of Pipeline
Connecting Plant with Metropolis Disposal #1 Well**

FIGURE 1: Photos of Pipeline



M4F 1



AGAVE ENERGY COMPANY 105 South Fourth Street, Artesia, New Mexico 88210		
AGAVE DAGGER GAS DRAW PLANT HYDROGEN SULFIDE CONTINGENCY PLAN FACILITIES LOCATIONS		
DRAWING TITLE	PROJECT	REV.
DRAWN BY	DATE	SCALE
APPROVED BY	DATE	SHEET



Map 2: General Diagram of Agave Dagger Draw Gas Plant and Location of Pipeline Connecting the Plant with the Metropolis Disposal #1 Well. Please note that the former Agave Energy Facility located immediately south of the Dagger Draw Gas Processing Plant is an inactive, unmanned facility.



Figure 1: Photos of Pipeline Connecting Agave Energy's Dagger Draw Gas Plant With Metropolis Disposal #1 well. A) Acid Gas Compressed at the Gas Plant is Introduced to a 2" Stainless Steel Pipeline Surrounded by a 6" Polyethylene Pipe. Pipeline Integrity is Monitored Using a Stream of Sweet Natural Gas in the Volume Between the Two Pipes. B) Outside of the Fenced in Areas at the Plant and Wellhead, the Pipeline is Buried and Clearly Marked. C) The Pipeline Rises Above Ground and Connects to the Production Tree at the Metropolis Disposal #1 Wellhead

APPENDIX A – Facility Maps

Map A-1: Facility Map

Map A-2: Alarms and Monitors, Dagger Draw Active Equipment



Map A-3: Safety and Fire Equipment, Dagger Draw Active Equipment

Map A-4: Evacuation Router, Dagger Draw Active Equipment

Map A-5: Proposed Perimeter Alarms

Map A-6: Metropolis Disposal Well

MAP A-1



AGAVE ENERGY COMPANY 100 South Fourth Street, Armonk, New Mexico 88210	
AGAVE DAGGER DRAW GAS PROCESSING PLANT	
PROJECT NO.	1000000000
DATE	10/15/10
DESIGNED BY	DAVID W. BROWN
CHECKED BY	DAVID W. BROWN
SCALE	AS SHOWN
Facility Map & Metropolis Disposal Well	
PROJECT NO. 1000000000	
SHEET 1 OF 1	




<p>DETECTION</p> <ul style="list-style-type: none"> #1 LAB #2 GATE #3 DEL MAR BUILDING #2 #4 DEL MAR ANALYZING BUILDING #5 ACID GAS COMPRESSOR WEST #6 FLARE KNOCKOUT #7 AM COMPRESSOR BUILDING #8 PIPER DISTRIBUTION AREA #9 FLARE PIPERACK 	<p>DETECTION</p> <ul style="list-style-type: none"> #10 DEL MAR BUILDING #1 #11 DEL MAR ANALYZING BUILDING #12 ACID GAS COMPRESSOR WEST #13 AM COMPRESSOR BUILDING #14 PIPER DISTRIBUTION AREA #15 FLARE PIPERACK #16 DEL MAR BUILDING #2 #17 DEL MAR ANALYZING BUILDING #18 ACID GAS COMPRESSOR WEST #19 AM COMPRESSOR BUILDING #20 PIPER DISTRIBUTION AREA #21 FLARE PIPERACK 	<p>DETECTION</p> <ul style="list-style-type: none"> #22 DEL MAR BUILDING #1 #23 DEL MAR ANALYZING BUILDING #24 ACID GAS COMPRESSOR WEST #25 AM COMPRESSOR BUILDING #26 PIPER DISTRIBUTION AREA #27 FLARE PIPERACK #28 DEL MAR BUILDING #2 #29 DEL MAR ANALYZING BUILDING #30 ACID GAS COMPRESSOR WEST #31 AM COMPRESSOR BUILDING #32 PIPER DISTRIBUTION AREA #33 FLARE PIPERACK 	<p>DETECTION</p> <ul style="list-style-type: none"> #34 DEL MAR BUILDING #1 #35 DEL MAR ANALYZING BUILDING #36 ACID GAS COMPRESSOR WEST #37 AM COMPRESSOR BUILDING #38 PIPER DISTRIBUTION AREA #39 FLARE PIPERACK #40 DEL MAR BUILDING #2 #41 DEL MAR ANALYZING BUILDING #42 ACID GAS COMPRESSOR WEST #43 AM COMPRESSOR BUILDING #44 PIPER DISTRIBUTION AREA #45 FLARE PIPERACK
--	--	--	--

AGAVE ENERGY COMPANY
 105 South Fourth Street, Arroyo, New Mexico 88210
 AGAVE DAGGER DRAW
 GAS PROCESSING PLANT

Alarms & Monitors

REVISIONS

NO.	DATE	DESCRIPTION
1	11/11/08	ISSUED FOR PERMITS
2	01/14/09	REVISED FOR PERMITS
3	03/11/09	REVISED FOR PERMITS
4	04/14/09	REVISED FOR PERMITS
5	05/14/09	REVISED FOR PERMITS
6	06/14/09	REVISED FOR PERMITS
7	07/14/09	REVISED FOR PERMITS
8	08/14/09	REVISED FOR PERMITS
9	09/14/09	REVISED FOR PERMITS
10	10/14/09	REVISED FOR PERMITS
11	11/14/09	REVISED FOR PERMITS
12	12/14/09	REVISED FOR PERMITS
13	01/14/10	REVISED FOR PERMITS
14	02/14/10	REVISED FOR PERMITS
15	03/14/10	REVISED FOR PERMITS
16	04/14/10	REVISED FOR PERMITS
17	05/14/10	REVISED FOR PERMITS
18	06/14/10	REVISED FOR PERMITS
19	07/14/10	REVISED FOR PERMITS
20	08/14/10	REVISED FOR PERMITS
21	09/14/10	REVISED FOR PERMITS
22	10/14/10	REVISED FOR PERMITS
23	11/14/10	REVISED FOR PERMITS
24	12/14/10	REVISED FOR PERMITS
25	01/14/11	REVISED FOR PERMITS
26	02/14/11	REVISED FOR PERMITS
27	03/14/11	REVISED FOR PERMITS
28	04/14/11	REVISED FOR PERMITS
29	05/14/11	REVISED FOR PERMITS
30	06/14/11	REVISED FOR PERMITS
31	07/14/11	REVISED FOR PERMITS
32	08/14/11	REVISED FOR PERMITS
33	09/14/11	REVISED FOR PERMITS
34	10/14/11	REVISED FOR PERMITS
35	11/14/11	REVISED FOR PERMITS
36	12/14/11	REVISED FOR PERMITS
37	01/14/12	REVISED FOR PERMITS
38	02/14/12	REVISED FOR PERMITS
39	03/14/12	REVISED FOR PERMITS
40	04/14/12	REVISED FOR PERMITS
41	05/14/12	REVISED FOR PERMITS
42	06/14/12	REVISED FOR PERMITS
43	07/14/12	REVISED FOR PERMITS
44	08/14/12	REVISED FOR PERMITS
45	09/14/12	REVISED FOR PERMITS
46	10/14/12	REVISED FOR PERMITS
47	11/14/12	REVISED FOR PERMITS
48	12/14/12	REVISED FOR PERMITS
49	01/14/13	REVISED FOR PERMITS
50	02/14/13	REVISED FOR PERMITS
51	03/14/13	REVISED FOR PERMITS
52	04/14/13	REVISED FOR PERMITS
53	05/14/13	REVISED FOR PERMITS
54	06/14/13	REVISED FOR PERMITS
55	07/14/13	REVISED FOR PERMITS
56	08/14/13	REVISED FOR PERMITS
57	09/14/13	REVISED FOR PERMITS
58	10/14/13	REVISED FOR PERMITS
59	11/14/13	REVISED FOR PERMITS
60	12/14/13	REVISED FOR PERMITS
61	01/14/14	REVISED FOR PERMITS
62	02/14/14	REVISED FOR PERMITS
63	03/14/14	REVISED FOR PERMITS
64	04/14/14	REVISED FOR PERMITS
65	05/14/14	REVISED FOR PERMITS
66	06/14/14	REVISED FOR PERMITS
67	07/14/14	REVISED FOR PERMITS
68	08/14/14	REVISED FOR PERMITS
69	09/14/14	REVISED FOR PERMITS
70	10/14/14	REVISED FOR PERMITS
71	11/14/14	REVISED FOR PERMITS
72	12/14/14	REVISED FOR PERMITS
73	01/14/15	REVISED FOR PERMITS
74	02/14/15	REVISED FOR PERMITS
75	03/14/15	REVISED FOR PERMITS
76	04/14/15	REVISED FOR PERMITS
77	05/14/15	REVISED FOR PERMITS
78	06/14/15	REVISED FOR PERMITS
79	07/14/15	REVISED FOR PERMITS
80	08/14/15	REVISED FOR PERMITS
81	09/14/15	REVISED FOR PERMITS
82	10/14/15	REVISED FOR PERMITS
83	11/14/15	REVISED FOR PERMITS
84	12/14/15	REVISED FOR PERMITS
85	01/14/16	REVISED FOR PERMITS
86	02/14/16	REVISED FOR PERMITS
87	03/14/16	REVISED FOR PERMITS
88	04/14/16	REVISED FOR PERMITS
89	05/14/16	REVISED FOR PERMITS
90	06/14/16	REVISED FOR PERMITS
91	07/14/16	REVISED FOR PERMITS
92	08/14/16	REVISED FOR PERMITS
93	09/14/16	REVISED FOR PERMITS
94	10/14/16	REVISED FOR PERMITS
95	11/14/16	REVISED FOR PERMITS
96	12/14/16	REVISED FOR PERMITS
97	01/14/17	REVISED FOR PERMITS
98	02/14/17	REVISED FOR PERMITS
99	03/14/17	REVISED FOR PERMITS
100	04/14/17	REVISED FOR PERMITS



PROPOSED WELL SITE

WELL SOCK


FENCING/AUDIBLE ALARMS MONITORS

SECURITY FENCE

AGAVE ENERGY COMPANY
100 SOUTH FORT STREE, JORDAN, NEW MEXICO 87003
AGAVE DAGGER DRAW
GAS PROCESSING PLANT

Proposed
Perimeter Alarms

DATE: 12/08/2011	SCALE: 1" = 100'	PROJECT: 28
DRAWN BY: J. W. HARRIS	DATE: 12/08/2011	PROJECT: 28
CHECKED BY: J. W. HARRIS	DATE: 12/08/2011	PROJECT: 28
DATE: 12/08/2011	SCALE: 1" = 100'	PROJECT: 28




<p>EMERGENCY WELL SITE</p> <p>FENCELINE AUDIBLE VIS MONITORS</p>	
<p>BREATHING AIR</p> <p>ESCAPE PACK</p> <p>SCBA</p> <p>FIRE EXTINGUISHER</p> <p>#40 DRY</p> <p>#41 DRY</p>	<p>H2S DETECTOR</p> <p>#1 SOUTHWEST</p> <p>#2 SOUTHEAST</p> <p>#3 NORTHWEST</p> <p>#4 NORTHEAST</p> <p>#5 WELLHEAD</p>
<p>WIND WARN BELL</p> <p>SECURITY FENCE</p>	<p>AS2 ALARM</p> <p>LIGHTS</p>

<p>AGAVE ENERGY COMPANY</p> <p>10000 S. STATE AVENUE, SUITE 100, DENVER, CO 80202</p> <p>AGAVE DAGGER DRAW</p> <p>GAS PROCESSING PLANT</p> <p>Metrolopolis</p> <p>Disposal Well</p>	
<p>DATE: 11/15/2018</p> <p>SCALE: AS SHOWN</p> <p>PROJECT: 18-00000000</p> <p>DATE: 11/15/2018</p> <p>SCALE: AS SHOWN</p> <p>PROJECT: 18-00000000</p>	<p>DATE: 11/15/2018</p> <p>SCALE: AS SHOWN</p> <p>PROJECT: 18-00000000</p> <p>DATE: 11/15/2018</p> <p>SCALE: AS SHOWN</p> <p>PROJECT: 18-00000000</p>

Appendix B – Response Flow Diagrams

LEVEL I RESPONSE



LEVEL II RESPONSE

CALL 911 for death or injury for emergency assistance

H₂S detected greater than or equal to 20 ppm: intermittent audible alarm and flashing red lights

- Put on Emergency Respirators
- Evacuate to Emergency Assembly Area
- Evacuate visitors from plant to designated Muster Area
- Assign operators to suit up in SCBA
- Check Plant Control System for location of H₂S alarm
- Notify all entities in the 500 ppm ROE if perimeter alarms are activated
- Notify residents in the 100 ppm ROE to shelter in place or evacuate depending on weather and release conditions (IC determines this) if perimeter alarms are activated
- Wearing SCBA attempt to locate and repair leak
- Rotate Operators in 15 minute shifts
- Re-entry will occur for 45 minutes or until the IC determines the ESD must be activated
- Notify LEPC
- If H₂S levels exceed 10 ppm in emergency assembly area relocate to an alternate Muster Area

- If H₂S levels exceed 20 ppm and repair efforts are unsuccessful, worst case scenario and/or catastrophic release have occurred then implement Level 3 response

Once resolved and monitored levels in Plant are less than 10 ppm H₂S: return to plant and continue to monitor

LEVEL III RESPONSE

CALL 911 for death or injury for emergency assistance

H₂S detected greater than 20 ppm: intermittent audible alarm and flashing red lights repair efforts are unsuccessful, worst case scenario and/or catastrophic release have occurred

H₂S detected greater than 50 ppm: plant will automatically go in to ESD. IC determines to proceed with Level III or Level II after ESD

- Set up road blocks on Kincaid and Pipeline Roads near the muster areas
- Confirm all personnel have evacuated the 500 ppm ROE
- Instruct all personnel in the 100 ppm ROE to evacuate to Muster Area as determined by the IC
- If vapors have ignited, continue to let burn unless fires endanger personnel
- Initiate a chronological record of events
- Within one hour of activation of the plan notify NMOCD and the NRC
- Establish a Media staging area in Muster Area 2 or other location as the situation permits
- Submit agency reports as required

Once resolved and monitored levels in Plant are less than 10 ppm H₂S: return to Plant continue to monitor

Appendix C - Radius of Exposure Calculations

Map C-1 Radius of Exposure

APPENDIX C-RADIUS OF EXPOSURE CALCULATIONS

The basis for worst case scenario calculations is as follows:

- The hydrogen sulfide content of the inlet natural gas stream into the Agave Dagger Draw Gas Plant is variable, ranging upwards to 7,600 parts per million (ppm) or 0.76 mole percent. In reality, the actual H₂S concentration that the plant processes will be much less than this.
- The inlet gas H₂S concentration of 0.76 mole percent was determined using a mass-balance approach, an analysis of 60.8 mole percent H₂S in the acid gas stream and a maximum acid gas flow rate of 0.5 MMSCFD. It is assumed that the amine system removes 100% of the H₂S from the inlet gas.

The plant has a maximum daily (24 hour) processing volume of 40 MMSCF.

- The worst case scenario radius of exposure (ROE) also assumes an uncontrolled instantaneous release from the area around either the Metropolis #1 Well, the amine still at the facility and at any point along the pipeline connecting the two of the above referenced volume and concentration. Because the Plant is a throughput process plant, it is impossible that the entire 24 hour-throughput volume of the Plant could be released instantaneously as is assumed in the worst case scenario calculations of the ROE. However, to comply with NMAC 19.15.11, that assumption is the worst case scenario in the formulas/calculations provided here.

It should further be noted that the reason this rate, used as worst case, could not be released over a 24 hour period is the Plant's emergency shutdown (ESD) systems would be activated. The emergency shutdown (ESD) would prevent the flow of gas into the Plant in the event of an emergency. See Appendix C and Map C-1 for more information.

The formulas for calculating the two radius of exposure (ROE) are as follows:

100 ppm Radius of Exposure Calculation (as per 19 NMAC 15.11.7.K.1):

$$X=[(1.589)(\text{hydrogen sulfide concentration})(Q)]^{(0.6258)}$$

500 ppm Radius of Exposure Calculation (as per 19 NMAC 15.11.7.K.2):

$$X=[(0.4546)(\text{hydrogen sulfide concentration})(Q)]^{(0.6258)}$$

Where:

X = radius of exposure in feet

"hydrogen sulfide concentration" = the decimal equivalent of the mole or volume fraction of hydrogen sulfide in the gaseous mixture

Q = Escape rate expressed in cubic feet per day (corrected for standard conditions of 14.73 psi absolute and 60 degrees Fahrenheit)

ROE Inside the Plant

The escape rate (Q) is the maximum daily rate of the gaseous mixture produced or handled or the best estimate thereof. For releases inside the Agave Dagger Draw Gas Plant, the Company is using for contingency planning purposes an "escape rate" equal to the maximum inlet gas volume of 40,000 MCFD. The (actual) inlet gas volume at the Plant will be somewhat variable and is continuously metered. The Plant records daily inlet gas volumes and prepares a daily volume report. The assumed 40,000 MCFD inlet gas volume has been selected as the "escape rate" because it is the highest anticipated inlet volume that the Plant would handle under its proposed operations and is considered worst case interpretation of the volume of gas.

It should be noted that the plan will remain effective as long as the processed volume and H₂S content equate to the same or smaller ROE.

Previous monitoring data indicated variable inlet concentrations of hydrogen sulfide, but concentration will not exceed 7,600 ppm or .76 mole percent. Therefore, 7,600 ppm or .76 mole percent has been used in the worst case scenario operations for contingency planning purposes.

Using:

Q = 40,000,000

H₂S conc = 7,600 ppm or .76 mole%

500-ppm RADIUS OF EXPOSURE CALCULATION

$$X = [(0.4546) * (\text{H}_2\text{S concentration}) * (\text{gas volume (Q)})]^{0.6258}$$

$$X = [(0.4546) * (7,600 * .000001) * (40,000,000)]^{0.6258}$$

X = 1648 feet = 500-ppm ROE

100-ppm RADIUS OF EXPOSURE CALCULATION

$$X = [(1.589) * (\text{H}_2\text{S concentration}) * (\text{gas volume})]^{0.6258}$$

$$X = [(1.589) * (7,600 * .000001) * (40,000,000)]^{0.6258}$$

X = 3606 feet = 100-ppm ROE

ROE Along the Pipeline and At the Injection Well

The escape rate (Q) is the best estimate of the maximum daily flow rate of the acid gas. For releases inside the Agave Dagger Draw Gas Plant, the Company is using for contingency planning purposes an "escape rate" equal to the 500 MCFD. The assumed 500 MCFD acid gas volume has been selected as the "escape rate" because it is the highest anticipated gas volume that the Plant would handle under its proposed operations and is considered the worst case interpretation of the volume of gas.

It should be noted that the plan will remain effective as long as the processed volume and H₂S content equate to the same or smaller ROE.

Previous monitoring data indicated variable inlet concentrations of hydrogen sulfide, but concentration will not exceed 608,000 ppm or 60.8 mole% at the inlet. Therefore, 608,000 ppm or 60.8 mole percent has been used in the worst case scenario operations for contingency planning purposes. Again, Agave does not measure the H₂S concentration in the acid gas stream; rather the concentration is calculated based on the inlet conditions.

Using:

Q = 500,000

H₂S conc = 608,000 ppm or 60.8 mole%

500-ppm RADIUS OF EXPOSURE CALCULATION

$$X = [(0.4546) \cdot (\text{H}_2\text{S concentration}) \cdot (\text{gas volume (Q)})^{0.6258}]$$

$$X = [(0.4546) \cdot (608,000 \cdot 0.000001) \cdot (500,000)^{0.6258}]$$


X = 1648 feet = 500-ppm ROE

100-ppm RADIUS OF EXPOSURE CALCULATION

$$X = [(1.589) \cdot (\text{H}_2\text{S concentration}) \cdot (\text{gas volume})^{0.6258}]$$

$$X = [(1.589) \cdot (608,000 \cdot 0.000001) \cdot (500,000)^{0.6258}]$$

X = 3606 feet = 100-ppm ROE



- 1648 Ft (500 ppm)
- 3606 Ft (100 ppm)
- AMINE STILL
- METROPOLIS WELL HEAD
- ACID GAS PIPELINE




AGAVE ENERGY COMPANY			
105 South Fourth Street, Artesia New Mexico 88210			
AGAVE DAGGER GAS DRAW PLANT			
HYDROGEN SULFIDE CONTINGENCY PLAN			
AMINE STILL RADIUS OF EXPOSURE			
DRAFTING: TWH	PRINTED: 11/29/10	SIZE: ANSI B	REV
CHK: JK	DATE: 11/29/10	SCALE: 1"=2000'	0
APPROVED: JK	DATE: 11/29/10	SHEET 1 of 1	

MAP C-1

APPENDIX D – Muster Areas, Evacuation Routes

Map D-1: Evacuation Routes to Muster Areas

Map D-2: Atoka Facility– Safety Trailer Location



MAP 1



AGAVE ENERGY COMPANY
 105 South Fourth Street, Artesia New Mexico 88210

AGAVE DAGGER GAS DRAW PLANT
 HYDROGEN SULFIDE CONTINGENCY PLAN
 FACILITIES LOCATIONS

DRAFTING: TWH	PRINTED: 11/29/10	SIZE: ANSI B	REV: 0
CHK: JK	DATE: 11/29/10	SCALE: 1"=4000'	
APPROVED: JK	DATE: 11/29/10	SHEET: 1 of 1	



Map 2: General Diagram of Agave Dagger Draw Gas Plant and Location of Pipeline Connecting the Plant with the Metropolis Disposal #1 Well. Please note that the former Agave Energy Facility located immediately south of the Dagger Draw Gas Processing Plant is an inactive, unmanned facility.

APPENDIX E – H₂S Contingency Plan Distribution List

APPENDIX E – H₂S Contingency Plan Distribution List

New Mexico Oil Conservation Division
1301 West Grand Avenue
Artesia, NM 88210-1729

New Mexico Department of Public Safety
4207 W 2nd Street
Roswell, NM 88201-8857

Local Emergency Planning Committee
324 S Canyon Street, Suite B
Carlsbad, NM 88210


Artesia Fire Department
309 North 7th Street
Artesia, NM 88210-1913

Atoka Fire Department
2611 South 13th Street
Artesia, NM 88210-9333

Eddy County Sheriff's Department
Eddy County Courthouse
102 N. Canal
Carlsbad, NM 88220

Dagger Draw Plant
278 Pipeline Road
Artesia, NM 88210

Agave Main Office
105 South 4th Street
Artesia, NM 88210



HINKLE, HENSLEY, SHANOR & MARTIN, L.L.P.

ATTORNEYS AT LAW

218 MONTEZUMA

SANTA FE, NEW MEXICO 87501

505-982-4554 (FAX) 505-982-8623

WRITER:

Gary W. Larson,
Partner
glarson@hinklelawfirm.com

January 25, 2011

VIA HAND DELIVERY

Glenn von Gonten
Oil Conservation Division
1220 S. St. Francis Drive
Santa Fe, NM 87505

Re: Agave Energy Company/Case No. 14601

Dear Glenn:

Enclosed is Agave Energy Company's H2S Contingency Plan for the Dagger Draw Processing Plant and Metropolis Disposal #1 Well, which is dated December 20, 2010.

Thank you for your attention to this matter.

Sincerely,

A handwritten signature in black ink that reads "Gary W. Larson".

Gary W. Larson

GWL:js
Encl.

H₂S Contingency Plan

Agave Dagger Draw Processing Plant
and the
Metropolis Disposal #1 Well



Agave Energy Company

105 South 4th Street
Artesia, NM 88210
(575-748-4555)

December 20, 2010

TABLE OF CONTENTS

	Page
I. Introduction	
[API RP-55 7.1].....	1
II. Scope	
[API RP-55 7.2].....	1
III. Plan Availability	
[API RP-55 7.3].....	1
IV. Emergency Procedures.....	1
[NMAC 19.15.11.9.B(2)(a)][API RP-55 7.4 a.]	
A. Responsibilities and Duties of Personnel During an Emergency	
B. Immediate Action Plan	
C. Telephone Numbers and Communication Methods	
D. Location of Residents, Roads, and Medical Facilities	
E. Evacuation Routes, Muster Areas, and Road Block Locations	
F. Monitoring Equipment, Alarm Systems, Safety Equipment, and Supplies	
V. Characteristics of Hydrogen Sulfide (H₂S), Sulfur Dioxide (SO₂), and Carbon Dioxide (CO₂) [NMAC 19.15.11.9.B(2)(b)][API RP-55 7.4 b.].....	10
A. Characteristics of Hydrogen Sulfide (H ₂ S)	
B. Sulfur Dioxide (SO ₂)	
C. Carbon Dioxide (CO ₂)	
D. Radii of Exposure (ROE)	
VI. Facility Description, Maps, and Drawings	
[AC [19.15.11.9.B(2)(c)][API RP-55 7.4 c.].....	14
A. Dagger Draw Processing Plant	
B. Metropolis Disposal #1 Well	
C. Map of Plant and Well	
VII. Training and Drills	
[NMAC 19.15.11.9.B(2)(d)][API RP-55 7.4 d.].....	16
A. Responsibilities and Duties of Essential Personnel	
B. On-site or Classroom Drills	
C. Notification and Training of Residents on Protective Measures in Emergency Situations	
D. Training and Attendance Documentation	
E. Briefing of Public Officials on Evacuation and Shelter in Place Plans	
VIII. Coordination with State Emergency Plans	
[NMAC 19.15.11.9.B(2)(e)].....	16
A. Oil Conservation Division	
B. New Mexico State Police	
IX. Plan Activation	
[NMAC 19.15.11.9.C][API RP-55 7.4 d.].....	17
A. Activation Levels	
B. Events that Could Lead to a Release	

X. Submission of H₂S Contingency Plans
[NMAC 19.15.11.9.D]..... 17
A. Submission
B. Retention
C. Inventory

MAPS AND FIGURES

- Map 1 Agave Dagger Draw Plant Facilities Locations
- Map 2 General Diagram of Agave Dagger Draw Gas Plant and Location of Pipeline
Connecting Plant with Metropolis Disposal #1 Well
- Figure 1 Photos of Pipeline

APPENDICES

Appendix A – Facility Maps and Drawings

- Map A-1: Facility Map
- Map A-2: Alarms and Monitors, Dagger Draw Active Equipment
- Map A-3: Safety and Fire Equipment, Dagger Draw Active Equipment
- Map A-4: Evacuation Router, Dagger Draw Active Equipment
- Map A-5: Proposed Perimeter Alarms
- Map A-6: Metropolis Disposal #1 Well

Appendix B – Response Flow Diagram

Appendix C – ROE Calculations

- Map C-1: Facility, Pipeline and Well Site ROE


Appendix D – Muster Areas and Evacuation Routes

- Map D-1: Evacuation Routes to Muster Areas

Appendix E – Distribution List

OPERATOR QUICK REFERENCE GUIDE

Dagger Draw Processing Plant Level 1 Response FOR PLANT OR WELLHEAD ALARMS



Location of Facilities

Agave Dagger Draw Processing Plant (See Map 1)

Go south of Artesia, NM on Hwy 285 approximately 9 miles to County Road 38 (Kincaid Ranch Road). Turn right (west) on Kincaid Ranch Road and go approximately 2.8 miles to Pipeline Road. Turn right (north) and go 0.2 miles to the Dagger Draw Gas Plant Office. Physical address is 278 Pipeline Road, Artesia, NM 88210.

Section 25-Township 18S-Range 25E

Metropolis Disposal #1 Well (See Map 1)

Go south of Artesia, NM on Hwy 285 approximately 9 miles to County Road 38 (Kincaid Ranch Road). Turn right (west) on Kincaid Ranch Road and go 2.6 miles (just past the Agave Field Office). Turn left (south) on dirt lease road and go approximately 0.6 miles then turn left (east) and go 0.2 miles to the Metropolis Disposal #1 Well. **Section 36-Township 18S-Range 25E**

Emergency Trailer – Atoka Facility Location (See Map 1)

From Artesia, drive south on Highway 285 to County Road 39. Turn east and drive approximately 2 miles. The facility is on the south side of the road in NW/NE Sec 14 18S 26 E.

I. Introduction

[API RP-55 7.1]

The Agave Dagger Draw Processing Plant is a natural gas processing plant which handles and/or generates hydrogen sulfide (H₂S) and/or sulfur dioxide (SO₂). This H₂S contingency plan was created to outline procedures that are to be followed in the event of an H₂S release that occurs at the plant, the acid gas well, or on the acid gas pipeline. The response plan is the same regardless of where the release takes place. This plan complies with the New Mexico Oil Conservation Division (OCD) Rule 11. This plan also conforms to API RP-55.

II. Scope

[API RP-55 7.2]

This contingency plan is specific to the Agave Dagger Draw Gas Processing Plant and acid gas injection system. This plan contains procedures to provide an organized response to an unplanned release from the plant, well site and pipeline connecting them.

III. Plan Availability

[API RP-55 7.3]

This contingency plan shall be available to all personnel responsible for implementing any portion of the plan. Copies of the plan will be distributed to the following agencies: New Mexico Oil Conservation Division (OCD), New Mexico Department of Public Safety, Local Emergency Planning Committee (LEPC), Artesia Fire Department, Atoka Fire Department, Artesia Police Department, and Eddy County Sheriff's Department. The Plan will be available at the following Agave Energy Company locations: Dagger Draw Processing Plant, the Artesia Field Office, Emergency Response Trailer at Atoka (Map 1) and the Agave Main Office in Artesia.

IV. Emergency Procedures

[NMAC 19.15.11.9.B(2)(a)] [API RP-55 7.4 a]

A. Responsibilities and Duties of Personnel during an Emergency

1. Plant Manager or designee will serve as the Incident Commander (IC); is responsible for training operators assigned to the plant, contractors and visitors on the implementation of this plan; and will maintain communication with Agave management and residents within the radius of exposure (ROE).
2. Plant Supervisor or designee will serve as the Incident Commander (IC) in the absence of the Plant Manager; is responsible for training and supervising plant operators on the implementation of this plan, will maintain accountability of all contractors and visitors; and will maintain communication with the plant manager and Agave management.
3. Plant Operators will perform operations in accordance with this safety plan; assist in the accountability and evacuation of visitors and contractors to designated muster areas; and keep the plant supervisor and manager informed on the repair progress.
4. Essential Agave Personnel will be familiar with the procedures in this plan and assist plant operators in assisting with the implementation of this plan in a safe manner.
5. Visitors and contractors on site will be familiar with safety alarms and signals at the Dagger Draw Gas Processing Plant and the acid gas injection system; and adhere to instructions of Plant Operators and other Agave personnel in evacuation of the facilities.

B. Immediate Action Plan

1. The following outlines the immediate action Plan that is illustrated by the response flow diagram in Appendix B. This is to be used when responding to an H₂S release. Response levels are the same for a release at the plant or the acid gas well. Additional or long term response actions will be determined on a case-by-case basis, if needed, once the Incident Command Center (ICC) and System (ICS) are established following the immediate response.

Level	Alarms	Actions
I	Intermittent audible alarm sounded and/or flashing yellow lights activated for H ₂ S at 10 ppm or greater.	<p>1. The audible signal for a Plant emergency and evacuation is an intermittent alarm and yellow lights (repeating off/on) activated when levels of H₂S of 10 ppm or greater are detected. In addition, a flashing yellow light or beacon will be activated at 10 ppm or greater of H₂S. A computer in the control room and in the Plant Supervisor office establishes which H₂S monitor has activated the alarm and/or flashing yellow beacon, be it a plant monitor or well monitor. At the initial sound of the intermittent alarm or the flashing yellow beacon, assigned operators will put on a 30 minute self-contained breathing apparatus (SCBA) and all other personnel in the Plant complex or well site shall immediately evacuate the Plant or well site to the Emergency Assembly Area. If H₂S concentrations are 10 ppm or greater, then personnel will evacuate to a designated Muster Area determined by the Incident Commander (IC) (see Appendix D). The operators, upon suit up with the self-contained breathing apparatus (SCBA), will first help any persons in distress evacuate to the Emergency Assembly Area. If deemed necessary by the Plant Manager or Plant Supervisor, local emergency response service providers will be contacted by Plant personnel designated by the Plant Manager or Supervisor.</p> <p>2. All entities within the 500 ppm radius of impact (ROE) will be notified (by telephone) of a release if the <u>perimeter alarms</u> are activated at 10 ppm H₂S or greater. Notification will be done by personnel designated by the Plant Manager or his designee. The nature of the release and status of containment will be conveyed. Businesses will be advised to report the incident to employees working near the Plant and to alert any third party contractors or service companies working in the Plant vicinity or imminently scheduled to work in the vicinity of the release. All should be instructed to leave the area and not to enter/re-enter area until further notice. Operators will put on self-contained breathing apparatus (SCBA).</p> <p>3. Wearing the self-contained breathing apparatus (SCBA), the operator(s) will attempt to fix the cause of the release. The H₂S levels at the Emergency Assembly Area will be monitored with a hand held or personal monitor and with the fixed monitor.</p> <p>4. The Incident Commander (IC) will set up secondary re-entry team(s) with 30 minute self-contained breathing apparatus (SCBA) to re-enter and resolve the situation. Re-entry will occur in 15 minute shifts at the direction of the Incident Commander (IC) until the problem is resolved or the emergency shut down (ESD) is activated. If H₂S levels in the Emergency Assembly Areas exceed 10 ppm H₂S, evacuate to alternate Emergency Assembly Area and continue to monitor Emergency Assembly Area with personal or handheld H₂S monitors. If evacuation to Muster Area occurs, road blocks will be established near the Muster Areas on Kincaid and Pipeline Road. If release is resolved and monitored levels in the Plant are less than 10 ppm H₂S, personnel may re-enter the Plant. The Oil Conservation Division (OCD) shall be notified within four hours of any release that activates the Plan. If the release is not resolved and H₂S levels continue to increase, Level 2 Response is indicated.</p>

Levels	Alarms	Actions
II	Intermittent audible alarm sounded and/or flashing red lights activated for H ₂ S greater than 20 ppm	<p>1. The intermittent alarm and red flashing lights indicate the detection of H₂S greater than or equal to 20 ppm. (Flashing yellow lights indicate a H₂S release of 10 ppm or greater and they will change to red for a release of 20 ppm or greater.) A control panel in the Plant supervisor's office establishes which H₂S monitor has activated the alarm and or flashing red beacon, be it a plant monitor or a well monitor. At the initial sound of the intermittent alarm or observance of the flashing red beacons, the operators will exit to the Muster Area designated by the Plant Manager or his designee. Other personnel in the Plant complex will put on emergency escape packs located throughout the plant, or well location and evacuate along with the operators using the evacuation routes to the Emergency Assembly Area and then to the Muster Area (see Appendix D) designated by the Plant Manager or designee. At the assembly area, the Plant Manager or designee will assign operators to put on a 30 minute self-contained breathing apparatus (SCBA). Local emergency response service providers will be contacted by Plant Manager or designee.</p> <p>2. All other entities within the 100 ppm and 500 ppm radius of impact (ROE) will be contacted by phone and notified of release and asked to evacuate when a <u>perimeter monitor</u> reads 10 ppm H₂S or greater. All entities within the 100 ppm radius of impact (ROE) will be contacted by phone and notified of release. The nature of the release and status of containment will be conveyed. Depending on release status and prevailing wind conditions, some entities within the 100 ppm radius of impact (ROE) may be asked to shelter in place or evacuate. Notifications will include but are not limited to the following:</p> <ul style="list-style-type: none"> a) Other entities within the 100 ppm radius of impact (ROE), depending on release status and prevailing wind conditions, will be asked to shelter in place. Those entities will be instructed to close any windows and shut off any air conditioning/heating until further notice. In addition, they will be instructed to contact other employees/residents not currently present and instruct them not to enter/reenter the area until further instruction. b) If a <u>perimeter monitor</u> is activated, the LEPC and law enforcement will be contacted by phone and notified of the release and status of containment. The Incident Commander (IC) will assign personnel notification responsibility. <p>3. Operator(s) with 30 minute self-contained breathing apparatus (SCBA) will assess the release and attempt to resolve it. If after 45 minutes on scene there is no resolution, the operator(s) will notify the Plant Manager to determine if the emergency shut down (ESD) should be activated.</p> <p>4. If monitored H₂S levels at Muster Area exceed 10 ppm, evacuate to an alternate Muster Area. If deemed necessary, local emergency response service providers will be contacted by the Incident Commander (IC).</p> <ul style="list-style-type: none"> a) Re-entry will occur in full self-contained breathing apparatus (SCBA) and in 15 minute shifts at the direction of the IC until IC determines problem has been resolved or emergency shut downs (ESDs) are activated. b) If release is resolved and monitored levels of H₂S in the Plant are less than 10 ppm, personnel may return to Plant. The Oil Conservation Division (OCD) shall be notified within four hours of any release that activates the Plan. All entities previously notified will be informed that the release has been resolved and advised of the current monitored H₂S levels at the Plant. c) No resolution requires activation of full H₂S Plan with notifications and reporting as per Plan. If the release is not resolved and/or H₂S levels continue to increase, Level 3 Response is indicated. d) Monitoring will continue after problems are abated, at the direction of the Plant Manager.

Level	Alarms	Actions
III	<p>Intermittent audible alarm sounded and/or flashing red lights activated for catastrophic release; fire; or explosion</p> <p>ESD alarm is a continuous siren with red, amber, and blue lights that flash</p>	<ol style="list-style-type: none"> 1. If H₂S is at 20 ppm or greater and repair efforts at Level 2 have been unsuccessful, worst case scenario, and/or catastrophic release have occurred, then implement a Level 3 response. 2. Road blocks will be set up near the Muster Areas on Kincaid Road and Pipeline Road. 3. All personnel shall have evacuated to a designated Muster Areas. Evacuation of all entities within the 500 ppm radius of impact (ROE) will have been confirmed. Implement full H₂S Plan with all notifications and public agency involvement. Notifications to all entities within the 100 ppm radius of impact (ROE) will include the nature of the release and status of containment. Notifications will include but are not limited to the following: <ol style="list-style-type: none"> a) All businesses within the 100 ppm radius of impact (ROE) will be instructed to immediately alert all company personnel, third party contractors and/or services companies working in the area, and those imminently scheduled to work in the area, of the release and evacuation status of the Plant. They will be instructed to immediately leave and/or not enter/reenter the area within the roadblocks until further instruction. b) All other entities (including private residents) within the 100 ppm radius of impact (ROE) will be instructed to immediately shelter in place, if appropriate based on the source of the release and the wind direction. Those entities will be instructed to close any windows and shut off any air conditioning/heating until further notice. In addition, they will be instructed to contact other employees/residents not currently present to not enter/reenter the area until further instruction. c) The Incident Commander (IC) will make the decision based on, but not limited to, H₂S concentration and wind direction, whether a safe evacuation can be implemented, and recommend an evacuation route. 4. If escaping vapors have ignited, the vapors should be allowed to continue to burn unless the fire endangers personnel, other property, or other equipment. 5. When applicable, maintain communication with the Plant Manager, or his designee, to keep him up-to-date of the situation and the action taken prior to his arrival at the location. 6. Initiate and maintain a Chronological Record of Events log. 7. Within one hour after the activation of the H₂S Plan, begin agency notifications by calling Oil Conservation Division (OCD) and National Response Center (NRC). 8. Establish media staging area adjacent to Muster Area 2 and direct all media to it. 9. Once resolved and monitored levels in the Plant and at Muster Area are less than 10 ppm, roadblocks will be removed, and all entities within the 100 ppm radius of impact (ROE) will be allowed to return. All entities previously notified will be informed that the release has been resolved and advised of the current monitored H₂S levels. 10. Monitoring will continue after problems are abated, at the direction of the Plant Manager 11. Agency reports to be submitted as required.

C. Telephone Numbers and Communication Methods

1. Emergency Services

AGENCY	TELEPHONE #
Artesia Fire Department	(575) 946-5050
Atoka Fire Department	(575) 946-5050
Artesia Police Department	(575) 746-5000
Eddy County Sheriff	(575) 887-7551
Carlsbad Police Department	(575) 885-2111
State Police (HMER)	
District 3 Roswell	(575) 827-9312
Sub District 3 Carlsbad	(575) 885-3138
Sub District 3 Hobbs	(575) 827-9320
Ambulance Services	
Artesia	(575) 746-5050
Carlsbad	(575) 885-2111
Hospitals	
Artesia General	(575) 748-3333
Carlsbad Medical Center	(575) 887-4100
<i>Veterinarians</i>	
Artesia Animal Clinic	(575) 748-2042
Livingston Animal Clinic	(575) 746-6167
Helicopter Services	
Lifeguard (Albuquerque)	1-800-633-5438
Southwest Medivac (Hobbs)	1-800-242-6199
AeroCare (Lubbock)	1-800-627-2376
Air Med (El Paso)	(915) 772-1449

2. Government Agencies

AGENCY	TELEPHONE #
Oil Conservation Division (OCD)	(505) 476-3440 (575) 748-1283
US BLM	(575) 887-6544
Local Emergency Planning Committee (LEPC)	(575) 887-9511
National Response Center (NRC)	1-800-424-8802

3. Operators and Contractors

COMPANY	TELEPHONE #
CVE	(575) 746-3571
PVT	(575) 748-1241
DCP Midstream	(800) 435-1679
Chevron/West Texas Pipeline Company	(800) 762-3404
Transwestern Pipeline	(281) 714-2265
Yates Petroleum Corporation	(575) 748-1471

4. Public

Name	Address	TELEPHONE #
David and Diana Wilson	80 West Kincaid Ranch Road	(575) 457-2309
Raul and Delilah Baeza	193 West Kincaid Ranch Road	(575) 308-3195
Efrin and Maria Baeza	179 West Kincaid Ranch Road	(575) 513-0471
Christine Baeza	175 West Kincaid Ranch Road	(575) 457-2585

5. Agave Internal Call List

NAME	TITLE	Office #	Cell #
J.B. Smith	President	(575) 748-4414	(575) 365-8517
Rusty Nasta	Operations Manager	(575) 748-4523	(575) 626-7971
Ivan Villa	Engineering Supervisor	(575) 748-4528	(575) 365-4888
Jennifer Knowlton	Environmental Engineer	(575) 748-4528	(505) 238-3588
Robert Moorhead	Plant Manager/South Mechanical Supervisor	(575) 748-6815	(575) 365-4840
Gary Greenwood	Plant Supervisor	(575) 748-8414	(575) 365-6794
Mark Smith	PSM Coordinator/Plant Operator	(575) 748-8410	(575) 365-5053
Dustin McNeely	Plant Operator	N/A	(575) 703-5493
Justin Troublefield	Plant Operator	N/A	(575) 365-7503
Glen Blake	Regulatory Coordinator	(575) 748-4546	(575) 626-8168
Bill Johnson	South Measurement Supervisor	(575) 748-6816	(575) 365-4615
Jason Fuentes	South Pipeline Supervisor	(575) 748-4518	(575) 365-8939

6. Agave Energy Company will use 2-way radios and telephones to communicate internally. Telephone will be used for external communication.

D. Location of Nearby Residences, Roads, and Medical Facilities

1. The following residences are located within the ROE of the:
 - a) Plant – None
 - b) Metropolis Disposal #1 Well – None
 - c) Pipeline – None
2. The following roads are located within the ROE:
 - a) Kincaid Ranch Road
 - b) Pipeline Road
3. There are no medical facilities located within the ROE.

E. Evacuation Routes, Emergency Assembly Area, Muster Areas, and Road Block Locations

1. Evacuation Routes, Emergency Assembly Area, and Muster Areas are depicted on Map D-1 in Appendix D.
2. Pre-planned road block locations are designated near the muster areas on Pipeline Road and Kincaid Ranch Road and are depicted on Map D-1 in Appendix D. Each location will have pre-positioned, portable road barriers with lights. The locations will have flashing lights and warning signs. If the release is sufficient to require evacuation to muster areas, then roadblocks near the muster areas on Kincaid Ranch Road and Pipeline Road to the west and north of the facility, respectively, will be established. The

Incident Commander (IC) will designate a representative to staff each of the two roadblocks. If deemed necessary by the Incident Commander (IC), the State or Local Police will be asked to assist with maintaining the roadblocks.

3. Emergency lights on the Muster Area signs will be activated by any perimeter alarm of 10 ppm or greater H₂S or Level III activation.

F. Monitoring Equipment, Alarm Systems, Safety Equipment, and Supplies Available

1. EMERGENCY SHUTDOWN SYSTEM: There are (8) ESD manual stations located at various points in the facility. See Maps A-2 and A-3 in Appendix A. The Plant ESD can be activated at any time by any employee or at the direction of the Incident Commander (IC).

When any one of the eight (8) manual stations is activated, the system will be shutdown and the natural gas inlets and outlets will be blocked. The operators are also able to auto close the one (1) main block valve on the incoming gas line to the Plant. Activating these should allow the plant to avoid a Level 3 response. The Incident Commander (IC) can send trained personnel to designated off-site manual block valves. There are also various methods to shut down gas flow at the various wellheads and incoming gathering lines. These can and would be evaluated on a case by case basis.

Designated employees will have remote access to the plant controls including ESD capabilities.

2. PLANT ALARMS, VISIBLE BEACONS & WIND INDICATORS: Colored beacons, horns, and wind direction indicators are located in various locations throughout the Plant and are indicated in Appendix A on Maps A-2, A-3, and A-6.

The audible signal for an emergency response and Plant evacuation is a repeating intermittent alarm that sounds at H₂S concentrations of 10 ppm or greater. The alarm will remain intermittent when the concentration of the H₂S release is 20 ppm or higher. At the initial sound of this intermittent alarm, the plant operators will evacuate to the emergency assembly area put on a self-contained breathing apparatus (SCBA) and all personnel in the plant complex shall immediately proceed in a safe manner to the Emergency Assembly Areas as prescribed by the Emergency Action Plan.

A flashing red beacon signifies an H₂S release of 20 ppm or higher and all personnel in the plant complex shall immediately proceed in a safe manner to the Emergency Assembly Area located outside of the plant office. If this area is not determined to be safe, all will move to designated Muster Area. Evacuation routes and Muster Areas are indicated on the map in Appendix A, on Map A-4 and A-6 as well as Appendix D, on Map D-1.

A routine process alarm will cause a horn to sound. This horn sound is used to alert the plant Operator to return to the Control Room. No emergency response or evacuation is required when this horn sounds.

Wind direction indicators are installed throughout the plant. At least one wind direction indicator can be seen at any location within the Plant complex, as well as from any point on the perimeter of the plant. There are ten (10) windsocks located in the Plant.

3. GAS DETECTION EQUIPMENT: The Plant uses a Smart Sensor System fixed plant H₂S Sensors. These sensors are a fixed point monitoring system used to detect the presence of hydrogen sulfide in ambient air. The yellow flashing beacon is activated at H₂S concentrations of 10 ppm or greater. The horn is activated with an intermittent alarm at H₂S concentrations of 10 ppm or greater. The lights change to red at 20 ppm H₂S and the horn remains intermittent. The fixed hydrogen sulfide monitors are strategically located throughout the Plant to detect an uncontrolled released of hydrogen sulfide. The Plant operators are able to monitor the H₂S level of all the Plant sensors on the control monitor located in the control room and the Dagger Draw Plant Field Office. In addition, select employees can access this information remotely. These sensors are located on the plot plan in Appendix A, Maps A-2 and A-3. These sensors all have to be acknowledged and will not clear themselves. This requires immediate action for any occurrence or malfunction. The Plant sensors are calibrated monthly.

Redline wireless H₂S detectors are installed along the perimeter of the plant and the perimeter of the acid gas disposal well. Perimeter H₂S detectors report to the Redline monitor every five minutes to confirm detector functionality. Once H₂S gas is detected, the H₂S detectors report to the monitor every five seconds. The detectors will go into alarm at H₂S values of 10 ppm and above. Redline H₂S head unit locations are depicted on Map A-5 and A-6 in Appendix A.

Handheld gas detection monitors are available to plant personnel to check specific areas and equipment prior to initiating maintenance or work on the process equipment. There are 3 handheld monitors and each individual is assigned a personal H₂S monitor. The handheld gas detection devices are Industrial Scientific ITX 3-gas detectors and BW Gas Alert Micro 5 4-way monitors. The detectors have sensors for oxygen, LEL (explosive hydrocarbon atmospheres), hydrogen sulfide, and carbon dioxide. They indicate the presence of H₂S with a beeping sound at 10 ppm. The beeps change in tone as H₂S increases to 20 ppm. The personal monitors are set to alarm (beep) at 10 ppm with the beeps becoming closer together as the H₂S concentration increases to 20 ppm. Both the handheld and personal monitors have digital readouts of H₂S ppm concentration.

a) The compressor building has two methane sensors; one sends a call out at 30% lower explosive limit (LEL); the second shuts the compressors down at 50% lower explosive limit (LEL). The methane sensors are visual and audible alarms. The compressor building also is equipped with fire eyes that will also shut the units down. The four product pumps also have LEL sensors.

4. RESPIRATORS: The Plant has 30 minute self-contained breathing apparatus (SCBA) respirators and 5 minute escape packs strategically located throughout the Plant. The respirator locations are identified in Appendix A on Maps A-3 and A-6. All Plant personnel are certified to use the self-contained breathing apparatus (SCBA) respirators.

5. FIRE FIGHTING EQUIPMENT: The Plant personnel are trained only for insipient stage fire fighting. The fire extinguishers located in the Plant process areas, compressor buildings, process buildings, and company vehicles are typically a 20# ABC dry chemical fire extinguisher. See Appendix A, Maps A-3 and A-6 for locations. The Plant does not have a fire water system, only a utility water system that is not designed for fire fighting.

6. EMERGENCY RESPONSE TRAILER AND EQUIPMENT: Agave Energy Company has an Emergency Response Trailer located at the Atoka Facility (Map 1; Map D-2 Appendix D). This is located outside all radii of exposure (ROE) from the facility along the pipeline to the well.

Driving Directions: From Artesia, drive south on Highway 285 to County Road 39. Turn east and drive approximately 2 miles. The facility is on the south side of the road in the NW/NE Sec 14 18S 26 E. See Map D-2 in Appendix D. The trailer can serve as a mobile resource center or Incident Command Center.

a) EMERGENCY RESPONSE TRAILER CONTENTS

- 2 wind socks / wind direction indicators w/poles & spares
- 1 – 110 volt generator, portable w/wheels
- 4 5-gas sensor ambient monitors (O₂, SO₂, LEL, CO, H₂S) with automatic air pumps (15 sec per foot) and data logging capability
- 1 calibration unit for monitors
- 5 intrinsically safe communication radios & chargers, 32 channel with capability to be programmed to fire service and police channels
- 4 20# stored pressure, ABC class Fire Extinguishers
- 4 4500 Grade D breathing air cylinders, regulator, low pressure alarm, and hose reel w/ 300 ft hose (total) and correct quick disconnects.
- 1 stretcher
- 1 20-person First Aid Kit with burn gel packets
- 4 30-minute SCBA's
- 4 work unit SCBA's
- 2 lights, mounted on each rear of trailer for night operations
- 2 hand cleaner for decontamination of petroleum products.
- 3 traffic Control Kits
- 1 emergency flare gun for lighting uncontrollable hazardous gases
- 2 full body harness and 150' X 2 lifelines
- 2 "Hazardous Area" "Do Not Enter" signs / barricades
- 2 burn gel blankets
- 1 set of maps and Emergency Response Plans
- 4 temporary use Nomex Fire retardant clothing (2-LG & 2-XLG)

7. TRAFFIC CONTROL KIT CONTENTS

- 3 electronic road flares
- 1 28" stop sign paddle
- 4 reflective traffic control vests
- 2 emergency signal wands
- 1 emergency Response Guidebook

8. FIRST AID EQUIPMENT LOCATIONS:

- a) First Aid Kits are located at the following locations:
- Lab
 - Office
- b) Eye Wash stations are located at the following locations:
- Lab
 - Office

9. PERSONAL H₂S MONITORS: All Agave personnel assigned to the Plant and associated field personnel are issued personal H₂S monitors.

10. SIGNS and MARKERS: The Plant has warning signs indicating the presence of "H₂S/Poisonous Gas" and high pressure gas at the entrance to the Plant. Emergency response phone numbers are posted at the entrance to the Plant. Signs are located at the Plant gate entrance indicating that all visitors are to sign in.

V. Characteristics of Hydrogen Sulfide (H₂S), Sulfur Dioxide (SO₂) and Carbon Dioxide (CO₂) [NMAC 19.15.11.9.B(2)(b)] [API RP-55 7.4 b.]

A. Hydrogen Sulfide (H₂S): Hydrogen Sulfide (H₂S): The proposed inlet gas streams into the Plant will contain a maximum of 7,600 ppm (or 0.76 mole percent) of hydrogen sulfide based on data generated from the sampling of the inlet gas at least daily. Hydrogen sulfide is a colorless, toxic and flammable gas, and has the odor of rotten eggs. Hydrogen sulfide gas is heavier than air. Hydrogen sulfide presents a significant health hazard by paralyzing the respiratory system resulting in serious injury or death.

Hydrogen Sulfide Properties and Characteristics		
CAS No.	7783-06-4	
Molecular Formula	H ₂ S	
Molecular Weight	34.082 g/mol	
Ceiling Concentration	20 ppm (OSHA)	
Ceiling Peak Concentration	50 ppm (OSHA)	
TLV	15 ppm (ACGIH)	
TWA	10 ppm (NIOSH)	
STEL	15 ppm (ACGIH)	
IDLH	100 ppm	
Specific Gravity Relative to Air (Air=1.0)	1.189	
Boiling Point	-76.5F	
Freezing Point	-121.8F	
Vapor Pressure	396 psia	
Autoignition Temperature	518F	
Lower Flammability Limit	4.3%	
Upper Flammability Limit	46.0%	
Stability	Stable	
pH in water	3	
Corrosivity	Reacts with metals, plastics, tissues and nerves	
Physical Effects of Hydrogen Sulfide		
Concentration		
Ppm	%	Physical Effects
1	0.00010	Can be smelled (rotten egg odor)
10	0.0010	Obvious & unpleasant odor; Permissible exposure level; safe for 8 hour exposure
20	0.0020	Acceptable ceiling concentration
50	0.0050	Loss of sense of smell in 15 minutes
100	0.0100	Immediately dangerous to life and health(IDLH) loss of sense of smell in 3-15 minutes; stinging in eyes & throat; Altered breathing
200	0.0200	Kills smell rapidly; stinging in eyes & throat

500	0.0500	Dizziness; Unconscious after short exposure; Need artificial respiration
700	0.0700	Unconscious quickly; death will result if not rescued promptly
1000	0.1000	Instant unconsciousness; followed by death within minutes

B. Sulfur Dioxide (SO₂): Sulfur dioxide is produced as a by-product of H₂S combustion at the flare. The flare unit receives the residual hydrogen sulfide and carbon dioxide stream that is routed from the amine unit. It is colorless, transparent, and is non-flammable, with a pungent odor associated with burning sulfur. Sulfur dioxide is heavier than air, but will be picked up by a breeze and carried downwind at elevated temperatures. Sulfur dioxide can be extremely irritating to the eyes and mucous membranes of the upper respiratory tract.

Sulfur Dioxide Properties & Characteristics	
CAS No.	7446-09-5
Molecular Formula	SO ₂
Molecular Weight	64.07 g/mol
PEL	5 ppm(OSHA)
TWA	2 ppm(ACGIH)
STEL	5 ppm(ACGIH)
IDLH	100 ppm
Specific Gravity Relative to Air (Air = 1.0)	2.26
Boiling Point	14°F
Freezing Point	-103.9°F
Vapor Pressure	49.1 psia
Auto ignition Temperature	N/A
Lower Flammability Limit	N/A
Upper Flammability Limit	N/A
Stability	Stable
Corrosivity	Could form an acid rain in aqueous solutions
Physical Effects of Sulfur Dioxide	
Concentration	Effect
1 ppm	Pungent odor, may cause respiratory changes
2 ppm	Permissible exposure limit; Safe for an 8 hour exposure
3-5 ppm	Pungent odor; normally a person can detect sulfur dioxide in this range
5 ppm	Short Term Exposure Limit (STEL); Safe for 15 minutes of exposure
12 ppm	Throat irritation, coughing, chest constriction, eyes tear and burn
100 ppm	Immediately Dangerous To Life & Health (IDLH)
150 ppm	So irritating that it can only be endured for a few minutes
500 ppm	Causes a sense of suffocation, even with first breath
1,000 ppm	Death may result unless rescued promptly.

C. **Carbon Dioxide (CO₂):** The proposed inlet streams into the Plant will contain a maximum of 383,100 ppm (or 38.31 mole percent) of carbon dioxide based on data generated from the sampling of the inlet gas at least daily. Carbon dioxide gas is colorless, odorless and non-flammable and is heavier than air.

Carbon Dioxide Properties & Characteristics	
CAS No.	124-38-9
Molecular Formula	CO ₂
Molecular Weight	44.010 g/mol
TWA	5,000 ppm
STEL	30,000 ppm
IDLH	40,000 ppm
Specific Gravity Relative to Air (Air = 1.0)	1.5197
Boiling Point	-109.12°F
Freezing Point	-69.81°F
Vapor Pressure	830 psia
Autoignition Temperature	N/A
Lower Flammability Limit	N/A
Upper Flammability Limit	N/A
Stability	Stable
pH in Saturated Solution	3.7
Corrosivity	dry gas is relatively inert & not corrosive; can be corrosive to mild steels in aqueous solutions
Physical Effects of Carbon Dioxide	
Concentration	Effect
1.0 %	Breathing rate increases slightly
2.0 %	Breathing rate increases to 50% above normal level. Prolonged exposure can cause headache, tiredness
3.0 %	Breathing rate increases to twice normal rate and becomes labored. Weak narcotic effect. Impaired hearing, headache, increased blood pressure and pulse rate
4 – 5 %	Breathing increases to approximately four times normal rate, symptoms of intoxication become evident, and slight choking may be felt
5 – 10 %	Characteristic sharp odor noticeable. Very labored breathing, headache, visual impairment, and ringing in the ears. Judgment may be impaired, followed within minutes by loss of consciousness
10 – 100 %	Unconsciousness occurs more rapidly above 10% level. Prolonged exposure to high concentrations may eventually result in death from asphyxiation

D. Radii of Exposure (ROE) [NMAC 19.15.11.7.K]

The basis for worst case scenario calculations is as follows:

- The hydrogen sulfide content of the inlet natural gas stream into the Agave Dagger Draw Gas Plant is variable, ranging upwards to 7,600 parts per million (ppm) or 0.76 mole percent. In reality, the actual H₂S concentration that the plant processes will be much less than this.
- The inlet gas H₂S concentration of 0.76 mole percent was determined using a mass-balance approach, an analysis of 60.8 mole percent H₂S in the acid gas stream and a maximum acid gas flow rate of 0.5 MMSCFD. It is assumed that the amine system removes 100% of the H₂S from the inlet gas.
- The plant has a maximum daily (24 hour) processing volume of 40 MMSCF.
- The worst case scenario radius of exposure (ROE) also assumes an uncontrolled instantaneous release from the area around either the Metropolis Disposal #1 Well, the amine still at the facility and/or at any point along the pipeline connecting the two of the above referenced volume and concentration. Because the Plant is a throughput process plant, it is impossible that the entire 24 hour-throughput volume of the Plant could be released instantaneously as is assumed in the worst case scenario calculations of the ROE. However, to comply with NMAC 19.15.11, that assumption is the worst case scenario in the formulas/calculations provided here.

It should further be noted that the reason this rate, used as worst case, could not be released over a 24 hour period is the Plant's emergency shutdown (ESD) systems would be activated. The emergency shutdown (ESD) would prevent the flow of gas into the Plant in the event of an emergency. See Appendix C and Map C-1 for more information.

The formulas for calculating the two radius of exposure (ROE) are as follows:

100 ppm Radius of Exposure Calculation (as per 19 NMAC 15.11.7.K.1):

$$X = [(1.589)(\text{hydrogen sulfide concentration})(Q)]^{(0.6258)}$$

500 ppm Radius of Exposure Calculation (as per 19 NMAC 15.11.7.K.2):

$$X = [(0.4546)(\text{hydrogen sulfide concentration})(Q)]^{(0.6258)}$$

Where:

X = radius of exposure in feet

"hydrogen sulfide concentration" = the decimal equivalent of the mole or volume fraction of hydrogen sulfide in the gaseous mixture

Q = Escape rate expressed in cubic feet per day (corrected for standard conditions of 14.73 psi absolute and 60 degrees Fahrenheit)

Amine Unit (Facility)

500-ppm ROE	1648 feet
100-ppm ROE	3606 feet

Pipeline

500-ppm ROE	1648 feet
100-ppm ROE	3606 feet

Acid Gas Disposal Well

500-ppm ROE	1648 feet
100-ppm ROE	3606 feet

The ROE for the facility, pipeline and well are shown on Map C-1 of Appendix C. This ROE pattern is designed to include the 100 and 500 ppm radii for a potential worst case failure at any point in the system from the facility at the north to the well to the south.

VI. Facility Description, Maps, and Drawings

[NMAC 19.15.11.9.B(2)(c)] [API RP-55 7.4 c.]

A. Dagger Draw Processing Plant Description of Operations- The primary function of the plant is to remove H₂S and CO₂ from sour field gas so that the gas can meet pipeline specifications. The plant has been designated a primary Standard Industrial Classification (SIC) Code of 1311. The operation of the Agave Dagger Draw Gas Plant is intended to process 40 MMSCFD of gas. The facility is authorized to operate continuously (8,760 hr/yr) at design maximum capacity processing rates. The gas will be treated to remove acid gas components, dehydrated to remove water and processed to remove heavy (liquid) hydrocarbons from the gas stream. Several plant systems will be involved to perform these functions.

The amine unit is designed to remove acid gas components (carbon dioxide, hydrogen sulfide and mercaptans) from the natural gas stream. These components are removed from the natural gas because they are corrosive, hazardous to health, and reduce the heating value of the natural gas stream. In addition, the carbon dioxide can freeze in the cryogenic unit forming dry ice and forcing the shutdown of the facility. This is known as the gas sweetening process. The acid gas removed by the amine unit will be disposed of by either acid gas injection into a disposal well or by incinerating in a flare. The preferred method of disposal will be to compress the gas and inject it into the well. Under emergency situations, the gas will be flared to prevent the emission of lethal hydrogen sulfide to atmosphere.

The glycol dehydration unit will receive approximately 40.0 MMSCFD of treated gas (sweet) from the amine unit and reduce the water content of the gas by circulating triethylene glycol (TEG). Molecular sieve dehydration is used upstream of the cryogenic processes to achieve a -150°F dew point. The process uses two molecular sieve vessels with one vessel in service absorbing moisture from the gas stream and the other vessel in the regeneration mode.

The cryogenic unit is designed to liquefy natural gas components from the sweet, dehydrated inlet gas by removing work (heat) from the gas by means of the turbo expander. The cryogenic unit recovers natural gas liquids (NGL) by cooling the gas stream

to extremely cold temperatures (-150°F) and condensing components such as ethane, propane, butanes and heavier hydrocarbons. Once the sweet, dry gas exits the cryogenic unit, it needs to be recompressed to approximately 800 to 1200 psi before the gas is sent to the main transportation pipeline. This is accomplished with two 2500 horsepower electric drive compressors.

The hot oil system in the plant is used to provide heat to certain processes within the facility. The system will circulate approximately 600 GPM of hot oil and deliver 15.5 MMBTU/hr to other processes.

B. Metropolis Disposal #1 Well Description of Operations- The low pressure (< 10 psig), acid gas stream from the amine unit is routed to the acid gas compressor. The stream is then subject to a series of compression and cooling cycles, thus dehydrating and compressing the acid gas stream to a pressure of approximately 1150 psig. The high pressure acid gas stream then flows through a 2" stainless steel pipeline to the injection well site. At this point, the stream is introduced into the well.

There are a number of safeguards designed to prevent leaks or overpressure of the system. The acid gas compressor is equipped with multiple pressure transmitters. These transmitters monitor compressor suction and discharge pressures and are programmed to shut the acid gas system down when the pressures fall outside a pre-programmed operating range. As an additional safeguard, the compressor panel is also equipped with high and low pressure shutdowns for each stage of compression that will shut the compressor down when pressures reach preset high and low pressure set points.

As shown on Map 2, the acid gas pipeline runs from the Agave Dagger Draw Plant in a southwesterly direction, crosses Kincaid Ranch Road at the plant boundary and continues southwesterly along a gravel road for approximately 3680 feet. The pipeline then turns east along the Metropolis Disposal #1 Well access road for an additional 900 feet to the wellhead. South of Kincaid Ranch Road, the pipeline and well are entirely contained within Section 36, Township 18 South, Range 25 East. This land is owned by the State of New Mexico. Agave Energy has the following three Rights-of-Way from the State of New Mexico in this section for the pipeline: R18068, R17745 and R17949. The Metropolis Disposal #1 Well Site is covered under Yates Petroleum Company Oil Leases VO-6141-0000 and E1-0165-0001. The pipeline is buried at a depth of 6-1/2 feet for its entire length and is marked, as required, with permanent surface markers. (See Map 2 and Figure 1)

The acid gas pipeline is constructed from 2" inch 304 stainless steel tubing. The pipeline has been designed with a maximum allowable working pressure of 2350 psig. Historical injection pressures average 1150 psig. For leak detection purposes, the 2" acid gas line has been encased in 6" SDR 11 polyethylene pipe. A "sweet" gas stream flows through the annulus between the 6" and 2" pipelines at a preset pressure and flow rate. This sweet gas stream is monitored continuously for H₂S and over/ under pressure. If any one variable falls outside the predetermined operating range, the acid gas compressor is shut down and the acid gas stream is routed to the flare.

Safeguards for the acid gas injection well consist of a subsurface safety valve. This valve is designed to isolate and shut in the injection well if a leak occurs along the acid gas pipeline or at the surface of the well.

C. Map of Plant and Metropolis Disposal #1 Well

See Appendix A, Map A-1

VII. Training and Drills

[NMAC 19.15.11.9.B(2)(d)] [API RP-55 7.4 d]

A. Responsibilities and Duties of Essential Personnel

1. Personnel responsible for implementing this plan shall be trained on their duties and responsibilities related to this plan during the annual on-site or table top training exercises.
2. Plant Orientation Training - All Plant personnel, visitors, and contractors must attend a Plant overview orientation prior to obtaining permission to enter the Plant. A refresher course on this training is required annually for all persons. This training also complies with the requirements of the Agave Energy Company Process Safety Management Program and Procedures Manual.

B. On-site or Classroom Drills

Agave Energy Company may use table top exercises as well as hands on emergency response training methods. Agave Energy Company shall conduct a table top exercise annually at a minimum.

C. Notification and Training of Others on Protective Measures in Emergency Situations

Affected residents will be invited to participate and/or observe annual drills, as well as being briefed on notification, evacuation, and shelter in place plans.

D. Training and Attendance Documentation

All training and drills will be documented. Documentation shall include sign in sheets, synopsis of the training conducted, and an after action review of the training.

E. Briefing of Public Officials on Evacuation and Shelter in Place Plans

Local law enforcement, first responders, and fire personnel will also be invited to participate and/or observe annual drills, as well as being briefed on notification, evacuation, and shelter in place plans.

VIII. Coordination with State Emergency Plans

[NMAC 19.15.11.9.B(2)(e)]

A. Oil Conservation Division (OCD)

1. Oil Conservation Division (OCD) will be notified with an automatic email to the District II office advising of the activation of the H₂S Contingency Plan if any of the alarms are activated at 10 ppm H₂S or greater. In the event of a power failure, a phone call will be made within four hours. All subsequent paperwork will be filed in a timely fashion.

B. New Mexico State Police/ New Mexico Hazardous Materials Emergency Response Plan

1. The New Mexico State Police are responsible for overall scene management and coordination of all resources. A designated Emergency Response Officer (ERO) will establish the National Interagency Incident Management System (NIIMS) Incident Command System (ICS) as the Incident Commander (IC) and be responsible for management of all response resources on scene. Off-scene coordination of response resources will be handled through designated Headquarters Emergency Response Officers. Law enforcement-related activities will be coordinated by State Police.

IX. Plan Activation

[NMAC 19.15.11.9.C] [API RP-55 7.4 d]

A. Activation Levels

Level 1 – Intermittent alarm sounded and/or flashing amber beacons activated for H₂S greater than or equal to 10 ppm

Level 2 – Intermittent alarm sounded and/or flashing red beacons activated for H₂S greater than or equal to 20 ppm

Level 3 – Catastrophic release; fire; explosion; a continuous release of maximum volume for 24 hours; or NMAC 19.15.11: mandatory activation of indication of 100 ppm in any defined public area; 500 ppm at any public road; or 100 ppm at a distance greater than 3000 feet from the site or the release. Because the 100 ppm radius of impact (ROE) boundary is greater than 3000 feet from the site of release, a Level 3 response would occur before the escape of the 24 hour release volume.

B. Events that Could Lead to a Release of H₂S

- Inlet and plant piping failure
- Amine still failure
- Flange/gasket leaks on inlet and plant piping
- Flange/gasket leaks on the acid gas compressor
- Flange/gasket leaks at metropolis disposal well
- Failure of acid gas pipeline
- Valve packing
- Seal failure on acid gas compressor
- Failure of flare to ignite during Plant emergency blow down

X. Submission of H₂S Contingency Plans

[NMAC 19.15.11.9.D]

A. Submission

1. Agave Energy Company will submit the H₂S Contingency Plan to the Oil Conservation Division (OCD).

B. Retention

1. Agave Energy Company shall maintain a copy of the contingency plan in the Main Office at 105 South 4th Street in Artesia, NM. The plan shall be readily accessible for review by the Oil Conservation Division (OCD) upon request.

C. Inventory


1. Agave Energy Company will file an annual inventory of wells, facilities and operations for which plans are on file with the Oil Conservation Division (OCD), to the Local Emergency Planning Committee (LEPC) and the State Emergency Response Commission as per NMAC 19.15.11.
2. The inventory shall include the name, address, telephone number, and point of contact for all operations in which plans are on file.

MAPS AND FIGURES

MAP 1: Agave Dagger Draw Plant Facilities Locations

MAP 2: General Diagram of Agave Dagger Draw Gas Plant and Location of Pipeline Connecting Plant with Metropolis Disposal #1 Well

FIGURE 1: Photos of Pipeline



NAD 83



AGAVE ENERGY COMPANY			
115 South Eighth Street, Artesia, New Mexico 88202			
AGAVE WATER TREATMENT PLANT			
HYDROGEN SULFIDE CONTINGENCY PLAN			
FACILITY LOCATION			
DRAWING NO.	DATE	SCALE	SHEET
115-001	11/15/11	AS SHOWN	1 OF 1
DATE	11/15/11	SCALE	AS SHOWN
APPROVED BY	DATE	SCALE	SHEET



Map 2: General Diagram of Agave Dagger Draw Gas Plant and Location of Pipeline Connecting the Plant with the Metropolis Disposal #1 Well




Figure 1: Photos of Pipeline Connecting Agave Energy's Dagger Draw Gas Plant With Metropolis Disposal #1 well. A) Acid Gas Compressed at the Gas Plant is Introduced to a 2" Stainless Steel Pipeline Surrounded by a 6" Polyethylene Pipe. Pipeline Integrity is Monitored Using a Stream of Sweet Natural Gas in the Volume Between the Two Pipes. B) Outside of the Fenced in Areas at the Plant and Wellhead, the Pipeline is Buried and Clearly Marked. C) The Pipeline Rises Above Ground and Connects to the Production Tree at the Metropolis Disposal #1 Wellhead

APPENDIX A – Facility Maps

- Map A-1: Facility Map**
- Map A-2: Alarms and Monitors, Dagger Draw Active Equipment**
- Map A-3: Safety and Fire Equipment, Dagger Draw Active Equipment**
- Map A-4: Evacuation Router, Dagger Draw Active Equipment**
- Map A-5: Proposed Perimeter Alarms**
- Map A-6: Metropolis Disposal Well**


PLANT NORTH

MAP A-2



<p>H2S DETECTION</p> <ul style="list-style-type: none"> #1 DEL. VAR. BUILDING #2 #1 DEL. VAR. ANALYZING #4 CHROMATOGRAPH BUILDING #5 ACID GAS COMPRESSOR WEST #13 VAPOR AREA #14 AIR COMPRESSOR BUILDING #15 POWER DISTRIBUTION AREA #16 FLARE PIPERACK 		<p>ESD</p> <ul style="list-style-type: none"> #1 LAB #2 GATE #3 PIPERACK #4 FLARE KNOCKOUT #5 SHIP #7 OFFICE COMPUTER #8 CONTROL ROOM CONVERTER 	
<p>H2S DETECTION VIA ALE AND BILE</p> <ul style="list-style-type: none"> #6 ACID GAS COMPRESSOR NORTH #7 CONDENSATE SKID #8 AMINE AREA #9 AMINE REBOILER #10 AMINE PIPERACK #11 INLET AREA #12 INLET PIPERACK 		<p>GAS DETECTORS</p> <ul style="list-style-type: none"> LEL, 50 COMPRESSOR BUILDING 50% LEL, 50 COMPRESSOR BUILDING 50% 	
<p>PRODUCT PIPERACK</p> <ul style="list-style-type: none"> #17 PRODUCT PUMP G0901A #18 PRODUCT PUMP G0901B #19 PRODUCT PUMP G0901A #20 PRODUCT PUMP G0901B 		<p>PLS/H COMPUTER</p>	
<p>AGAVE ENERGY COMPANY SECURITY BENCE 101 South Fourth Street, Arvada, New Mexico 88210</p>			
<p>AGAVE DAGGER DRAW GAS PROCESSING PLANT</p>			
<p>Alarms & Monitors</p>			


0 0.10 Miles



PROPOSED WELL SITE ● FENCELINE AUDIBLE H2S MONITORS	
BREATHING AIR ● ESCAPE PACK ● SCBA FIRE EXTINGUISHER ● #40 DRY ● #41 DRY	H2S DETECTION ● #1 SOUTHWEST ● #2 SOUTHEAST ● #3 NORTHEAST ● #4 NORTHWEST ● #5 WELLSHEAD
WIND SOCK H2S ALARM LIGHTS	● H2S #1 ● H2S #2 ● H2S #3 ● H2S #4 ● H2S #5 ● H2S #7
SECURITY FENCE AGAVE ENERGY COMPANY 103 South Fourth Street, Arroyo, New Mexico 88210 AGAVE DAGGER DRAW GAS PROCESSING PLANT Metropolis Disposal Well	
DATE: 12/24/24 DATE: 12/24/24 APPROVAL: R DATE: 12/24/24 DATE: 12/24/24 DATE: 12/24/24	STATE AND MARKED LICENSE NO. SECTION 27 TOWN AND 36 RANGE 28 RANGE 28 RANGE 28

APPENDIX B – Response Flow Diagrams

LEVEL I RESPONSE



LEVEL II RESPONSE

CALL 911 for death or injury for emergency assistance

H₂S detected greater than or equal to 20 ppm: intermittent audible alarm and flashing red lights


- Put on Emergency Respirators
- Evacuate to Emergency Assembly Area
- Evacuate visitors from plant to designated Muster Area
- Assign operators to suit up in SCBA
- Check Plant Control System for location of H₂S alarm
- Notify all entities in the 500 ppm ROE if perimeter alarms are activated
- Notify residents in the 100 ppm ROE to shelter in place or evacuate depending on weather and release conditions (IC determines this) if perimeter alarms are activated
- Wearing SCBA attempt to locate and repair leak
- Rotate Operators in 15 minute shifts
- Re-entry will occur for 45 minutes or until the IC determines the ESD must be activated
- Notify LEPC
- If H₂S levels exceed 10 ppm in emergency assembly area relocate to an alternate Muster Area

- If H₂S levels exceed 20 ppm and repair efforts are unsuccessful, worst case scenario and/or catastrophic release have occurred then implement Level 3 response

Once resolved and monitored levels in Plant are less than 10 ppm H₂S: return to plant and continue to monitor

LEVEL III RESPONSE

CALL 911 for death or injury for emergency assistance



APPENDIX C - Radius of Exposure Calculations

Map C-1 Radius of Exposure

APPENDIX C-RADIUS OF EXPOSURE CALCULATIONS

The basis for worst case scenario calculations is as follows:

- The hydrogen sulfide content of the inlet natural gas stream into the Agave Dagger Draw Gas Plant is variable, ranging upwards to 7,600 parts per million (ppm) or 0.76 mole percent. In reality, the actual H₂S concentration that the plant processes will be much less than this.
- The inlet gas H₂S concentration of 0.76 mole percent was determined using a mass-balance approach, an analysis of 60.8 mole percent H₂S in the acid gas stream and a maximum acid gas flow rate of 0.5 MMSCFD. It is assumed that the amine system removes 100% of the H₂S from the inlet gas.

The plant has a maximum daily (24 hour) processing volume of 40 MMSCF.

- The worst case scenario radius of exposure (ROE) also assumes an uncontrolled instantaneous release from the area around either the Metropolis #1 Well, the amine still at the facility and at any point along the pipeline connecting the two of the above referenced volume and concentration. Because the Plant is a throughput process plant, it is impossible that the entire 24 hour-throughput volume of the Plant could be released instantaneously as is assumed in the worst case scenario calculations of the ROE. However, to comply with NMAC 19.15.11, that assumption is the worst case scenario in the formulas/calculations provided here.

It should further be noted that the reason this rate, used as worst case, could not be released over a 24 hour period is the Plant's emergency shutdown (ESD) systems would be activated. The emergency shutdown (ESD) would prevent the flow of gas into the Plant in the event of an emergency. See Appendix C and Map C-1 for more information.

The formulas for calculating the two radius of exposure (ROE) are as follows:

100 ppm Radius of Exposure Calculation (as per 19 NMAC 15.11.7.K.1):

$$X=[(1.589)(\text{hydrogen sulfide concentration})(Q)]^{(0.6258)}$$

500 ppm Radius of Exposure Calculation (as per 19 NMAC 15.11.7.K.2):

$$X=[(0.4546)(\text{hydrogen sulfide concentration})(Q)]^{(0.6258)}$$

Where:

X = radius of exposure in feet

"hydrogen sulfide concentration" = the decimal equivalent of the mole or volume fraction of hydrogen sulfide in the gaseous mixture

Q = Escape rate expressed in cubic feet per day (corrected for standard conditions of 14.73 psi absolute and 60 degrees Fahrenheit)

ROE Inside the Plant

The escape rate (Q) is the maximum daily rate of the gaseous mixture produced or handled or the best estimate thereof. For releases inside the Agave Dagger Draw Gas Plant, the Company is using for contingency planning purposes an "escape rate" equal to the maximum inlet gas volume of 40,000 MCFD. The (actual) inlet gas volume at the Plant will be somewhat variable and is continuously metered. The Plant records daily inlet gas volumes and prepares a daily volume report. The assumed 40,000 MCFD inlet gas volume has been selected as the "escape rate" because it is the highest anticipated inlet volume that the Plant would handle under its proposed operations and is considered worst case interpretation of the volume of gas.

It should be noted that the plan will remain effective as long as the processed volume and H₂S content equate to the same or smaller ROE.

Previous monitoring data indicated variable inlet concentrations of hydrogen sulfide, but concentration will not exceed 7,600 ppm or .76 mole percent. Therefore, 7,600 ppm or .76 mole percent has been used in the worst case scenario operations for contingency planning purposes.

Using:

Q = 40,000,000

H₂S conc = 7,600 ppm or .76 mole%

500-ppm RADIUS OF EXPOSURE CALCULATION

$$X = [(0.4546) * (\text{H}_2\text{S concentration}) * (\text{gas volume (Q)})]^{0.6258}$$

$$X = [(0.4546) * (7,600 * .000001) * (40,000,000)]^{0.6258}$$

X = 1648 feet = 500-ppm ROE

100-ppm RADIUS OF EXPOSURE CALCULATION

$$X = [(1.589) * (\text{H}_2\text{S concentration}) * (\text{gas volume})]^{0.6258}$$

$$X = [(1.589) * (7,600 * .000001) * (40,000,000)]^{0.6258}$$

X = 3606 feet = 100-ppm ROE

ROE Along the Pipeline and At the Injection Well

The escape rate (Q) is the best estimate of the maximum daily flow rate of the acid gas. For releases inside the Agave Dagger Draw Gas Plant, the Company is using for contingency planning purposes an "escape rate" equal to the 500 MCFD. The assumed 500 MCFD acid gas volume has been selected as the "escape rate" because it is the highest anticipated gas volume that the Plant would handle under its proposed operations and is considered the worst case interpretation of the volume of gas.

It should be noted that the plan will remain effective as long as the processed volume and H₂S content equate to the same or smaller ROE.

Previous monitoring data indicated variable inlet concentrations of hydrogen sulfide, but concentration will not exceed 608,000 ppm or 60.8 mole% at the inlet. Therefore, 608,000 ppm or 60.8 mole percent has been used in the worst case scenario operations for contingency planning purposes. Again, Agave does not measure the H₂S concentration in the acid gas stream; rather the concentration is calculated based on the inlet conditions.

Using:

$$Q = 500,000$$

$$\text{H}_2\text{S conc} = 608,000 \text{ ppm or } 60.8 \text{ mole\%}$$

500-ppm RADIUS OF EXPOSURE CALCULATION

$$X = [(0.4546) * (\text{H}_2\text{S concentration}) * (\text{gas volume (Q)})]^{0.6258}$$

$$X = [(0.4546) * (608,000 * .000001) * (500,000)]^{0.6258}$$



$$\underline{X = 1648 \text{ feet} = 500\text{-ppm ROE}}$$

100-ppm RADIUS OF EXPOSURE CALCULATION

$$X = [(1.589) * (\text{H}_2\text{S concentration}) * (\text{gas volume})]^{0.6258}$$

$$X = [(1.589) * (608,000 * .000001) * (500,000)]^{0.6258}$$

$$\underline{X = 3606 \text{ feet} = 100\text{-ppm ROE}}$$



- 1648 Ft (500 ppm)
- 3606 Ft (100 ppm)
- AMINE STILL
- METROPOLIS WELL HEAD
- ACID GAS PIPELINE



AGAVE ENERGY COMPANY
 105 South Fourth Street, Artesia New Mexico 88210

**AGAVE DAGGER GAS DRAW PLANT
 HYDROGEN SULFIDE CONTINGENCY PLAN
 AMINE STILL RADIUS OF EXPOSURE**


DRAFTING: TWH	PRINTED: 11/29/10	SIZE: ANSI B	REV
CHK: JK	DATE: 11/29/10	SCALE: 1"=2000'	0
APPROVED: JK	DATE: 11/29/10	SHEET 1 of 1	

MAP C-1

APPENDIX D – Muster Areas, Evacuation Routes

Map D-1: Evacuation Routes to Muster Areas

Map D-2: Atoka Facility– Safety Trailer Location




MAP D-1

— MUSTER AREA



AGAVE ENERGY COMPANY 105 South Fourth Street, Artesia New Mexico 88210			
AGAVE DAGGER GAS DRAW PLANT HYDROGEN SULFIDE CONTINGENCY PLAN EVACUATION ROUTES			
DRAFTING: TWH	PRINTED: 11/29/10	SIZE: ANSI B	REV
CHK: JK	DATE: 11/29/10	SCALE: 1"=2000'	0
APPROVED: JK	DATE: 11/29/10	SHEET 1 of 1	



Main Street

82

Artesia

Eagle

1048

Cem

1022

13th Street

Radio Tower

Wells

1011

Landing Strip

Spring Lake

1050

Draw

Atoka

3315

1015

1047

Well

3316

ed

Well

4 DINKUS ROAD

Emergency Response Trailer (Atoka Location)

Peñasco

Highway 285

1034

Dayton

3000' 1500' 0' 3000'

MAP D-2



AGAVE ENERGY COMPANY			
105 South Fourth Street, Artesia New Mexico 88210			
AGAVE DAGGER GAS DRAW PLANT			
HYDROGEN SULFIDE CONTINGENCY PLAN			
EMERGENCY TRAILER LOCATION			
DRAFTING: TWH	PRINTED: 11/29/10	SIZE: ANSI B	REV: 0
CHK: JK	DATE: 11/29/10	SCALE: NA	
APPROVED: JK	DATE: 11/29/10	SHEET: 1 of 1	

**APPENDIX E – H₂S Contingency Plan
Distribution List**

TABLE D-1

**OPERATORS WITHIN ONE MILE RADIUS
OF AGAVE METROPOLIS DISPOSAL #1 WELL**

1. Agave Energy Co
105 South Fourth Street
Artesia, NM 88210

2. Yates Petroleum Corporation
105 South Fourth Street
Artesia, NM 88210

TABLE D-2

**SURFACE OWNERS WITHIN ONE MILE RADIUS
OF AGAVE METROPOLIS DISPOSAL #1 WELL**

Section 36, Township 18 South, Range 25 East

State of New Mexico State Land Office
310 Old Santa Fe Trail
P. O. Box 1148
Santa Fe, NM 87504

All

Section 35, Township 18 South, Range 25 East

Thomas & Wanda Wilson
David & Diana Wilson
235 N. Lake Rd.
Artesia, NM 88210

All

Section 26, Township 18 South, Range 25 East

Agave Energy Company
P. O. Box 92108
Austin, TX 78709

Small square in SE/4 on map
.57 acre tract in SE/4

Yates Petroleum Corporation
207 S. 4th Street
Artesia, NM 88210

SE/4 Less & Except a .57 acre tract

Section 25, Township 18 South, Range 25 East

Sharbro Oil Company, LTD
P. O. Box 840
Artesia, NM 88211

E/2 SE/4

Woodward Trust
Jeri & Dale Woodward
4748 Elder Avenue
Seal Beach, CA 90740

W/2 SE/4

Yates Petroleum Corporation
105 S. 4th Street
Artesia, NM 88210

2.17 acre tract in SW/4
Tract 104-25.7 on map

TABLE D-2 SURFACE OWNERS

Agave Energy Company
P. O. Box 92108
Austin, TX 78709

25.38 acre tract in SW /4
Tract 104-25.8 on map

Yates Petroleum Corporation
207 S. 4th Street
Artesia, NM 88210

SW/4 less & except
2 above tracts

Section 30, Township 18 South, Range 26 East

Yates Petroleum Corporation
207 S. 4th Street
Artesia, NM 88210

SW/4

Section 31, Township 18 South, Range 26 East

Efren & Maria Baeza
314 N. 14th
Artesia, NM 88210

N/2 N/2

Thomas & Wanda Wilson
David & Diana Wilson
235 N. Lake Rd.
Artesia, NM 88210

S/2 NW/4; E/2 SW/4

Blanche Widaman
Wells Fargo Bank
Industry Consulting Group Inc.
P. O. Box 810490
Dallas, TX 75381

NW/4 SW/4

H. D. Larsen
% Greta Edington
1715 - 20th Street
Gering, NE 69341

N/2 SW/4 SW/4

Ronald Metcalf
P. O. Box 37
South Valley Road
Palmer Lake, CO 80133

S/2 SW/4 SW/4

TABLE D-2 SURFACE OWNERS

Section 6, Township 19 South, Range 26 East

Jim & Sandra Hazelwood
P. O. Box 507
Troy, MT 59935

10 acre tract in Lot 3

Pitch Energy Corporation &
Yates Petroleum Corporation
P. O. Box 304
Artesia, NM 88211

10 acre tract in Lot 3 &
All Lot 4

Dwight M. Lee
% Cindy McDermid
11177 Captains Cove Drive
Soddy-Daisy, TN 37379

Lot 5

Section 1, Township 19 South, Range 25 East

Thomas & Wanda Wilson
David & Diana Wilson
235 N. Lake Rd.
Artesia, NM 88210

S/2; S/2 NE/4; NE/4 NE/4

Glenn R. Fuller
18495 Starduster Drive
Nevada City, CA 95959

NW/4

Section 1, Township 19 South, Range 25 East (continued)

B. E. Spencer Trust
First National Bank
P. O. Drawer AA
Artesia, NM 88211

Lot 2

Section 2, Township 19 South, Range 25 East

Thomas & Wanda Wilson
David & Diana Wilson
235 N. Lake Rd.
Artesia, NM 88210

All





Figure D-1
Approximate Locations of Surface Owners Within One Mile
of Agave Metropolis Disposal #1 Well



One Mile Circle Around Agave Metropolis Disposal #1 Well

TABLE D-3

**LEASE HOLDERS WITHIN ONE MILE RADIUS OF
AGAVE METROPOLIS DISPOSAL #1 WELL**

**1. Yates Petroleum Corporation
105 S. 4th Street
Artesia, NM 88210
(575) 748-1741**

Section 36-Township 18S-Range 25E
NE/4; SW/4 NW/4; SE/4 NW/4;
NW/4 NW/4; NE/4 NW/4; NE/4 SE/4

Lease #VO-6141-0000
Lease # E1-0165-0001

Section 35-Township 18S-Range 25E
S/2; N/2

Section 26-Township 18S-Range 25E
SE/4

Section 25-Township 18S-Range 25E
SW/4; SE/4

Section 30-Township 18S-Range 26E
SW/4

Section 31-Township 18S-Range 26E
W/2

Section 6-Township 19S-Range 26E
N/2

Section 2-Township 19S-Range 25E
N/2

Section 1-Township 19S-Range 25E
S/2 NE/4; E/2 SE/4

(Yates, Abo, Myco and Marbob all hold leases)

2. Chase Oil Corporation

**P. O. Box 1767
Artesia, NM 88210
(575) 746-9853**

Section 36-Township 18S-Range 25E;
SW/4; NW/4 SE/4; SW/4 SE/4; SE/4 SE/4

Lease #VO-8443-0000

Section 1-Township 19S-Range 25E
NE/4 NE/4; W/2 SW/4;
NW/4; W/2 SE/4; E/2 SW/4

(DMD LLC also has a lease on this tract)

3. Marbob Energy Corporation

**P. O. Box 227
Artesia, NM 88211**

Section 1-Township 19S-Range 25E
S/2 NE/4; E/2 SE/4

(Yates, Abo, Myco and Marbob all hold leases)

4. DMD LLC

**P.O. Box 300
Artesia, NM 88211
(575) 746-2953**

Section 1-Township 19S-Range 25E
NE/4 NE/4; W/2 SW/4

(Chase Oil also has a lease on this tract)

5. Abo Petroleum Corporation

**105 S. 4th Street
Artesia, NM 88210**

Section 1-Township 19S-Range 25E
S/2 NE/4; E/2 SE/4

(Yates, Abo, Myco and Marbob all hold leases)

6. Myco Industries, Inc.

**105 S. 4th Street
Artesia, NM 88210**

Section 1-Township 19S-Range 25E
S/2 NE/4; E/2 SE/4

(Yates, Abo, Myco and Marbob all hold leases)

TABLE D-4

MINERAL OWNERS OF ONLY UNLEASED TRACT
WITHIN ONE MILE RADIUS OF
AGAVE METROPOLIS DISPOSAL #1 WELL

Section 1-Township 18S-Range 25E
NW/4 NE/4

1. B. E. Spencer Trust
First National Bank
P. O. Drawer AA
Artesia, NM 88211
2. Wyatt A. Hartman
% W. B. Hickey
Rt. #1 - Box 181-A
Chattahoochee, FL 32324
3. Roy Hartman
% Letha J. Hartman,
11025 Larkwood
Apt. # 1701
Houston, TX 77096
4. Margaret J. Carter
2032 Medusa Way
Sacramento, CA 95825
5. William Harold Robinson
% Margaret J. Carter
2032 Medusa Way
Sacramento, CA 95825
6. Frances M. Mohr
% Margaret J. Carter
2032 Medusa Way
Sacramento, CA 95825
7. Spitler Family Trust
% Homer Edward Spitler & Mildred
Ilene Spitler
30315 Santa Fe Street
Hemet, CA 92343
8. Martha Jane Ford
3520 Roselawn
Glendale, CA 91208
9. Parrish Family Trust
% James Paul Parrish & Carole D.
Parrish
1702 Paloma Avenue
Glendale, CA 91208

TABLE D-5

**RESIDENCES AND BUSINESS FACILITIES WITHIN ONE MILE RADIUS
OF AGAVE METROPOLIS DISPOSAL #1 WELL**

Section 31, Township 18 South, Range 26 East N/2 N/2; Residences

1. Efren & Maria Baeza, 179 West Kincaid Ranch Road, Artesia, NM (Physical Address)
2. Raul and Delilah Baeza, 193 West Kincaid Ranch Road, Artesia, NM (Physical Address)
3. Christine Baeza, 175 West Kincaid Ranch Road, Artesia, NM (Physical Address)

Mailing Address: 314 N 14th Street, Artesia, NM 88210

Section 25, Township 18 South, Range 25 East

4. Yates Petroleum Corporation 2.17 acre tract in SW/4; (tract 104-25.7 on map)
105 S. 4th Street Office & Warehouse
Artesia, NM 88210
5. Agave Energy Corporation 25.38 acre tract in SW/4
P. O. Box 92108 (tract 104-25.8 on map)
Austin, TX 78709 Gas Processing Plant

Section 26, Township 18 South, Range 25 East

6. Agave Energy Corporation .57 acre tract in SE/4
P. O. Box 92108 (tract 104-26.2 on map)
Austin, TX 78709 Compressor Station
7. Yates Petroleum Corporation SE/4; Four Warehouse Buildings
207 S. 4th Street
Artesia, NM 88210

Section 35, Township 18 South, Range 25 East E/2; Home and Barns

8. David Wilson
80 West Kincaid Ranch Rd., Artesia, NM (Physical Address)
Mailing Address: 235 N. Lake Rd., Artesia, NM 88210

OTHER AGENCIES REQUIRING NOTICE

9. US Bureau of Land Management
Carlsbad Field Office
620 East Greene Street
Carlsbad, NM 88220-6292
10. New Mexico State Land Office (included in notice to surface owners within one mile radius)

APPENDIX E – H₂S Contingency Plan Distribution List

New Mexico Oil Conservation Division

1301 West Grand Avenue
Artesia, NM 88210-1729

New Mexico Department of Public Safety

4207 W 2nd Street
Roswell, NM 88201-8857

Local Emergency Planning Committee

324 S Canyon Street, Suite B
Carlsbad, NM 88210

Artesia Fire Department

309 North 7th Street
Artesia, NM 88210-1913

Atoka Fire Department

2611 South 13th Street
Artesia, NM 88210-9333

Eddy County Sheriff's Department

Eddy County Courthouse
102 N. Canal
Carlsbad, NM 88220

Dagger Draw Plant

278 Pipeline Road
Artesia, NM 88210


Agave Main Office

105 South 4th Street
Artesia, NM 88210

DRAFT

H₂S Contingency Plan

Agave Dagger Draw Processing Plant
and the
Metropolis Disposal #1 Well



Agave Energy Company

105 South 4th Street
Artesia, NM 88210
(575-748-4555)

December 20, 2010

File Dec 10/05 Landa Form @ (GW053)
↳ closed?

GW-185 GP
GW-53 GP
GW-125 CS

DRAFT

TABLE OF CONTENTS

	Page
I. Introduction	
[API RP-55 7.1].....	1
II. Scope	
[API RP-55 7.2].....	1
III. Plan Availability	
[API RP-55 7.3].....	1
IV. Emergency Procedures	1
[NMAC 19.15.11.9.B(2)(a)][API RP-55 7.4 a.]	
A. Responsibilities and Duties of Personnel During an Emergency	
B. Immediate Action Plan	
C. Telephone Numbers and Communication Methods	
D. Location of Residents, Roads, and Medical Facilities	
E. Evacuation Routes, Muster Areas, and Road Block Locations	
F. Monitoring Equipment, Alarm Systems, Safety Equipment, and Supplies	
V. Characteristics of Hydrogen Sulfide (H₂S), Sulfur Dioxide (SO₂), and Carbon Dioxide (CO₂) [NMAC 19.15.11.9.B(2)(b)][API RP-55 7.4 b.].....	10
A. Characteristics of Hydrogen Sulfide (H ₂ S)	
B. Sulfur Dioxide (SO ₂)	
C. Carbon Dioxide (CO ₂)	
D. Radii of Exposure (ROE)	
VI. Facility Description, Maps, and Drawings	
[AC [19.15.11.9.B(2)(c)][API RP-55 7.4 c.].....	14
A. Dagger Draw Processing Plant	
B. Metropolis Disposal #1 Well	
C. Map of Plant and Well	
VII. Training and Drills	
[NMAC 19.15.11.9.B(2)(d)][API RP-55 7.4 d.].....	16
A. Responsibilities and Duties of Essential Personnel	
B. On-site or Classroom Drills	
C. Notification and Training of Residents on Protective Measures in Emergency Situations	
D. Training and Attendance Documentation	
E. Briefing of Public Officials on Evacuation and Shelter in Place Plans	
VIII. Coordination with State Emergency Plans	
[NMAC 19.15.11.9.B(2)(e)].....	16
A. Oil Conservation Division	
B. New Mexico State Police	
IX. Plan Activation	
[NMAC 19.15.11.9.C][API RP-55 7.4 d.].....	17
A. Activation Levels	
B. Events that Could Lead to a Release	

DRAFT

X. Submission of H₂S Contingency Plans	
[NMAC 19.15.11.9.D].....	17
A. Submission	
B. Retention	
C. Inventory	

MAPS AND FIGURES

- Map 1 Agave Dagger Draw Plant Facilities Locations
- Map 2 General Diagram of Agave Dagger Draw Gas Plant and Location of Pipeline Connecting Plant with Metropolis Disposal #1 Well
- Figure 1 Photos of Pipeline

APPENDICES

Appendix A – Facility Maps and Drawings

- Map A-1: Facility Map
- Map A-2: Alarms and Monitors, Dagger Draw Active Equipment
- Map A-3: Safety and Fire Equipment, Dagger Draw Active Equipment
- Map A-4: Evacuation Router, Dagger Draw Active Equipment
- Map A-5: Proposed Perimeter Alarms
- Map A-6: Metropolis Disposal #1 Well

Appendix B – Response Flow Diagram

Appendix C – ROE Calculations

- Map C-1: Facility, Pipeline and Well Site ROE

Appendix D – Muster Areas and Evacuation Routes

- Map D-1: Evacuation Routes to Muster Areas

Appendix E – Distribution List

DRAFT

OPERATOR QUICK REFERENCE GUIDE

Dagger Draw Processing Plant Level 1 Response FOR PLANT OR WELLHEAD ALARMS

H₂S Detected Greater than 10 ppm H₂S
Intermittent Audible Alarm and flashing
amber lights

- Evacuate to Emergency Assembly Area
- Evacuate visitors from plant to designated Muster Area
- Notify Agave Management
- Assign operators to suit up in SCBA
- Check Computer for location of H₂S alarm
- Notify all entities in the 500 ppm ROE when perimeter monitors reach 10 ppm H₂S
- Wearing SCBA - attempt to locate and repair leak
- Rotate Operators in 15 minute shifts
- If H₂S levels exceed 10 ppm H₂S in emergency muster area relocate to alternate muster area

If H₂S levels exceed 20 ppm H₂S proceed
to Level II response

**CALL 911 for
death or injury
for emergency
assistance**

Once resolved and
monitored levels in
plant are less than
10 ppm H₂S -
return to plant and
continue to monitor

DRAFT

Location of Facilities

Agave Dagger Draw Processing Plant (See Map 1)

Go south of Artesia, NM on Hwy 285 approximately 9 miles to County Road 38 (Kincaid Ranch Road). Turn right (west) on Kincaid Ranch Road and go approximately 2.8 miles to Pipeline Road. Turn right (north) and go 0.2 miles to the Dagger Draw Gas Plant Office. Physical address is 278 Pipeline Road, Artesia, NM 88210.

Section 25-Township 18S-Range 25E

Metropolis Disposal #1 Well (See Map 1)

Go south of Artesia, NM on Hwy 285 approximately 9 miles to County Road 38 (Kincaid Ranch Road). Turn right (west) on Kincaid Ranch Road and go 2.6 miles (just past the Agave Field Office). Turn left (south) on dirt lease road and go approximately 0.6 miles then turn left (east) and go 0.2 miles to the Metropolis Disposal #1 Well. **Section 36-Township 18S-Range 25E**

Emergency Trailer – Atoka Facility Location (See Map 1)

From Artesia, drive south on Highway 285 to County Road 39. Turn east and drive approximately 2 miles. The facility is on the south side of the road in NW/NE Sec 14 18S 26 E.

DRAFT

I. Introduction

[API RP-55 7.1]

The Agave Dagger Draw Processing Plant is a natural gas processing plant which handles and/or generates hydrogen sulfide (H₂S) and/or sulfur dioxide (SO₂). This H₂S contingency plan was created to outline procedures that are to be followed in the event of an H₂S release that occurs at the plant, the acid gas well, or on the acid gas pipeline. The response plan is the same regardless of where the release takes place. This plan complies with the New Mexico Oil Conservation Division (OCD) Rule 11. This plan also conforms to API RP-55.

II. Scope

[API RP-55 7.2]

This contingency plan is specific to the Agave Dagger Draw Gas Processing Plant and acid gas injection system. This plan contains procedures to provide an organized response to an unplanned release from the plant, well site and pipeline connecting them.

III. Plan Availability

[API RP-55 7.3]

This contingency plan shall be available to all personnel responsible for implementing any portion of the plan. Copies of the plan will be distributed to the following agencies: New Mexico Oil Conservation Division (OCD), New Mexico Department of Public Safety, Local Emergency Planning Committee (LEPC), Artesia Fire Department, Atoka Fire Department, Artesia Police Department, and Eddy County Sheriff's Department. The Plan will be available at the following Agave Energy Company locations: Dagger Draw Processing Plant, the Artesia Field Office, Emergency Response Trailer at Atoka (Map 1) and the Agave Main Office in Artesia.

IV. Emergency Procedures

[NMAC 19.15.11.9.B(2)(a)] [API RP-55 7.4 a]

A. Responsibilities and Duties of Personnel during an Emergency

1. Plant Manager or designee will serve as the Incident Commander (IC); is responsible for training operators assigned to the plant, contractors and visitors on the implementation of this plan; and will maintain communication with Agave management and residents within the radius of exposure (ROE).
2. Plant Supervisor or designee will serve as the Incident Commander (IC) in the absence of the Plant Manager; is responsible for training and supervising plant operators on the implementation of this plan, will maintain accountability of all contractors and visitors; and will maintain communication with the plant manager and Agave management.
3. Plant Operators will perform operations in accordance with this safety plan; assist in the accountability and evacuation of visitors and contractors to designated muster areas; and keep the plant supervisor and manager informed on the repair progress.
4. Essential Agave Personnel will be familiar with the procedures in this plan and assist plant operators in assisting with the implementation of this plan in a safe manner.
5. Visitors and contractors on site will be familiar with safety alarms and signals at the Dagger Draw Gas Processing Plant and the acid gas injection system; and adhere to instructions of Plant Operators and other Agave personnel in evacuation of the facilities.

DRAFT

B. Immediate Action Plan

1. The following outlines the immediate action Plan that is illustrated by the response flow diagram in Appendix B. This is to be used when responding to an H₂S release. Response levels are the same for a release at the plant or the acid gas well. Additional or long term response actions will be determined on a case-by-case basis, if needed, once the Incident Command Center (ICC) and System (ICS) are established following the immediate response.

Level	Alarms	Actions
I	Intermittent audible alarm sounded and/or flashing yellow lights activated for H ₂ S at 10 ppm or greater.	<p>1. The audible signal for a Plant emergency and evacuation is an intermittent alarm and yellow lights (repeating off/on) activated when levels of H₂S of 10 ppm or greater are detected. In addition, a flashing yellow light or beacon will be activated at 10 ppm or greater of H₂S. A computer in the control room and in the Plant Supervisor office establishes which H₂S monitor has activated the alarm and/or flashing yellow beacon, be it a plant monitor or well monitor. At the initial sound of the intermittent alarm or the flashing yellow beacon, assigned operators will put on a 30 minute self-contained breathing apparatus (SCBA) and all other personnel in the Plant complex or well site shall immediately evacuate the Plant or well site to the Emergency Assembly Area. If H₂S concentrations are 10 ppm or greater, then personnel will evacuate to a designated Muster Area determined by the Incident Commander (IC) (see Appendix D). The operators, upon suit up with the self-contained breathing apparatus (SCBA), will first help any persons in distress evacuate to the Emergency Assembly Area. If deemed necessary by the Plant Manager or Plant Supervisor, local emergency response service providers will be contacted by Plant personnel designated by the Plant Manager or Supervisor.</p> <p>2. All entities within the 500 ppm radius of impact (ROE) will be notified (by telephone) of a release if the <u>perimeter alarms</u> are activated at 10 ppm H₂S or greater. Notification will be done by personnel designated by the Plant Manager or his designee. The nature of the release and status of containment will be conveyed. Businesses will be advised to report the incident to employees working near the Plant and to alert any third party contractors or service companies working in the Plant vicinity or imminently scheduled to work in the vicinity of the release. All should be instructed to leave the area and not to enter/re-enter area until further notice. Operators will put on self-contained breathing apparatus (SCBA).</p> <p>3. Wearing the self-contained breathing apparatus (SCBA), the operator(s) will attempt to fix the cause of the release. The H₂S levels at the Emergency Assembly Area will be monitored with a hand held or personal monitor and with the fixed monitor.</p> <p>4. The Incident Commander (IC) will set up secondary re-entry team(s) with 30 minute self-contained breathing apparatus (SCBA) to re-enter and resolve the situation. Re-entry will occur in 15 minute shifts at the direction of the Incident Commander (IC) until the problem is resolved or the emergency shut down (ESD) is activated. If H₂S levels in the Emergency Assembly Areas exceed 10 ppm H₂S, evacuate to alternate Emergency Assembly Area and continue to monitor Emergency Assembly Area with personal or handheld H₂S monitors. If evacuation to Muster Area occurs, road blocks will be established near the Muster Areas on Kincaid and Pipeline Road. If release is resolved and monitored levels in the Plant are less than 10 ppm H₂S, personnel may re-enter the Plant. The Oil Conservation Division (OCD) shall be notified within four hours of any release that activates the Plan. If the release is not resolved and H₂S levels continue to increase, Level 2 Response is indicated.</p>

DRAFT

Levels	Alarms	Actions
II	Intermittent audible alarm sounded and/or flashing red lights activated for H ₂ S greater than 20 ppm	<p>1. The intermittent alarm and red flashing lights indicate the detection of H₂S greater than or equal to 20 ppm. (Flashing yellow lights indicate a H₂S release of 10 ppm or greater and they will change to red for a release of 20 ppm or greater.) A control panel in the Plant supervisor's office establishes which H₂S monitor has activated the alarm and or flashing red beacon, be it a plant monitor or a well monitor. At the initial sound of the intermittent alarm or observance of the flashing red beacons, the operators will exit to the Muster Area designated by the Plant Manager or his designee. Other personnel in the Plant complex will put on emergency escape packs located throughout the plant, or well location and evacuate along with the operators using the evacuation routes to the Emergency Assembly Area and then to the Muster Area (see Appendix D) designated by the Plant Manager or designee. At the assembly area, the Plant Manager or designee will assign operators to put on a 30 minute self-contained breathing apparatus (SCBA). Local emergency response service providers will be contacted by Plant Manager or designee.</p> <p>2. All other entities within the 100 ppm and 500 ppm radius of impact (ROE) will be contacted by phone and notified of release and asked to evacuate when a <u>perimeter monitor</u> reads 10 ppm H₂S or greater. All entities within the 100 ppm radius of impact (ROE) will be contacted by phone and notified of release. The nature of the release and status of containment will be conveyed. Depending on release status and prevailing wind conditions, some entities within the 100 ppm radius of impact (ROE) may be asked to shelter in place or evacuate. Notifications will include but are not limited to the following:</p> <ul style="list-style-type: none"> a) Other entities within the 100 ppm radius of impact (ROE), depending on release status and prevailing wind conditions, will be asked to shelter in place. Those entities will be instructed to close any windows and shut off any air conditioning/heating until further notice. In addition, they will be instructed to contact other employees/residents not currently present and instruct them not to enter/reenter the area until further instruction. b) If a <u>perimeter monitor</u> is activated, the LEPC and law enforcement will be contacted by phone and notified of the release and status of containment. The Incident Commander (IC) will assign personnel notification responsibility. <p>3. Operator(s) with 30 minute self-contained breathing apparatus (SCBA) will assess the release and attempt to resolve it. If after 45 minutes on scene there is no resolution, the operator(s) will notify the Plant Manager to determine if the emergency shut down (ESD) should be activated.</p> <p>4. If monitored H₂S levels at Muster Area exceed 10 ppm, evacuate to an alternate Muster Area. If deemed necessary, local emergency response service providers will be contacted by the Incident Commander (IC).</p> <ul style="list-style-type: none"> a) Re-entry will occur in full self-contained breathing apparatus (SCBA) and in 15 minute shifts at the direction of the IC until IC determines problem has been resolved or emergency shut downs (ESDs) are activated. b) If release is resolved and monitored levels of H₂S in the Plant are less than 10 ppm, personnel may return to Plant. The Oil Conservation Division (OCD) shall be notified within four hours of any release that activates the Plan. All entities previously notified will be informed that the release has been resolved and advised of the current monitored H₂S levels at the Plant. c) No resolution requires activation of full H₂S Plan with notifications and reporting as per Plan. If the release is not resolved and/or H₂S levels continue to increase, Level 3 Response is indicated. d) Monitoring will continue after problems are abated, at the direction of the Plant Manager.

DRAFT

Level	Alarms	Actions
III	<p>Intermittent audible alarm sounded and/or flashing red lights activated for catastrophic release; fire; or explosion</p> <p>ESD alarm is a continuous siren with red, amber, and blue lights that flash</p>	<ol style="list-style-type: none"> 1. If H₂S is at 20 ppm or greater and repair efforts at Level 2 have been unsuccessful, worst case scenario, and/or catastrophic release have occurred, then implement a Level 3 response. 2. Road blocks will be set up near the Muster Areas on Kincaid Road and Pipeline Road. 3. All personnel shall have evacuated to a designated Muster Areas. Evacuation of all entities within the 500 ppm radius of impact (ROE) will have been confirmed. Implement full H₂S Plan with all notifications and public agency involvement. Notifications to all entities within the 100 ppm radius of impact (ROE) will include the nature of the release and status of containment. Notifications will include but are not limited to the following: <ol style="list-style-type: none"> a) All businesses within the 100 ppm radius of impact (ROE) will be instructed to immediately alert all company personnel, third party contractors and/or services companies working in the area, and those imminently scheduled to work in the area, of the release and evacuation status of the Plant. They will be instructed to immediately leave and/or not enter/reenter the area within the roadblocks until further instruction. b) All other entities (including private residents) within the 100 ppm radius of impact (ROE) will be instructed to immediately shelter in place, if appropriate based on the source of the release and the wind direction. Those entities will be instructed to close any windows and shut off any air conditioning/heating until further notice. In addition, they will be instructed to contact other employees/residents not currently present to not enter/reenter the area until further instruction. c) The Incident Commander (IC) will make the decision based on, but not limited to, H₂S concentration and wind direction, whether a safe evacuation can be implemented, and recommend an evacuation route. 4. If escaping vapors have ignited, the vapors should be allowed to continue to burn unless the fire endangers personnel, other property, or other equipment. 5. When applicable, maintain communication with the Plant Manager, or his designee, to keep him up-to-date of the situation and the action taken prior to his arrival at the location. 6. Initiate and maintain a Chronological Record of Events log. 7. Within one hour after the activation of the H₂S Plan, begin agency notifications by calling Oil Conservation Division (OCD) and National Response Center (NRC). 8. Establish media staging area adjacent to Muster Area 2 and direct all media to it. 9. Once resolved and monitored levels in the Plant and at Muster Area are less than 10 ppm, roadblocks will be removed, and all entities within the 100 ppm radius of impact (ROE) will be allowed to return. All entities previously notified will be informed that the release has been resolved and advised of the current monitored H₂S levels. 10. Monitoring will continue after problems are abated, at the direction of the Plant Manager 11. Agency reports to be submitted as required.

DRAFT

C. Telephone Numbers and Communication Methods

1. Emergency Services

AGENCY	TELEPHONE #
Artesia Fire Department	(575) 946-5050
Atoka Fire Department	(575) 946-5050
Artesia Police Department	(575) 746-5000
Eddy County Sheriff	(575) 887-7551
Carlsbad Police Department	(575) 885-2111
State Police (HMER)	
District 3 Roswell	(575) 827-9312
Sub District 3 Carlsbad	(575) 885-3138
Sub District 3 Hobbs	(575) 827-9320
Ambulance Services	
Artesia	(575) 746-5050
Carlsbad	(575) 885-2111
Hospitals	
Artesia General	(575) 748-3333
Carlsbad Medical Center	(575) 887-4100
<i>Veterinarians</i>	
Artesia Animal Clinic	(575) 748-2042
Livingston Animal Clinic	(575) 746-6167
Helicopter Services	
Lifeguard (Albuquerque)	1-800-633-5438
Southwest Medivac (Hobbs)	1-800-242-6199
AeroCare (Lubbock)	1-800-627-2376
Air Med (El Paso)	(915) 772-1449

2. Government Agencies

AGENCY	TELEPHONE #
Oil Conservation Division (OCD)	(505) 476-3440 (575) 748-1283
US BLM	(575) 887-6544
Local Emergency Planning Committee (LEPC)	(575) 887-9511
National Response Center (NRC)	1-800-424-8802

3. Operators and Contractors

COMPANY	TELEPHONE #
CVE	(575) 746-3571
PVT	(575) 748-1241
DCP Midstream	(800) 435-1679
Chevron/West Texas Pipeline Company	(800) 762-3404
Transwestern Pipeline	(281) 714-2265
Yates Petroleum Corporation	(575) 748-1471

DRAFT

4. Public

Name	Address	TELEPHONE #
David and Diana Wilson	80 West Kincaid Ranch Road	(575) 457-2309
Raul and Delilah Baeza	193 West Kincaid Ranch Road	(575) 308-3195
Efrin and Maria Baeza	179 West Kincaid Ranch Road	(575) 513-0471
Christine Baeza	175 West Kincaid Ranch Road	(575) 457-2585

5. Agave Internal Call List

NAME	TITLE	Office #	Cell #
J.B. Smith	President	(575) 748-4414	(575) 365-8517
Rusty Nasta	Operations Manager	(575) 748-4523	(575) 626-7971
Ivan Villa	Engineering Supervisor	(575) 748-4528	(575) 365-4888
Jennifer Knowlton	Environmental Engineer	(575) 748-4528	(505) 238-3588
Robert Moorhead	Plant Manager/South Mechanical Supervisor	(575) 748-6815	(575) 365-4840
Gary Greenwood	Plant Supervisor	(575) 748-8414	(575) 365-6794
Mark Smith	PSM Coordinator/Plant Operator	(575) 748-8410	(575) 365-5053
Dustin McNeely	Plant Operator	N/A	(575) 703-5493
Justin Troublefield	Plant Operator	N/A	(575) 365-7503
Glen Blake	Regulatory Coordinator	(575) 748-4546	(575) 626-8168
Bill Johnson	South Measurement Supervisor	(575) 748-6816	(575) 365-4615
Jason Fuentes	South Pipeline Supervisor	(575) 748-4518	(575) 365-8939

6. Agave Energy Company will use 2-way radios and telephones to communicate internally. Telephone will be used for external communication.

D. Location of Nearby Residences, Roads, and Medical Facilities

1. The following residences are located within the ROE of the:

- Plant -- None
- Metropolis Disposal #1 Well -- None
- Pipeline -- None

2. The following roads are located within the ROE:

- Kincaid Ranch Road
- Pipeline Road

3. There are no medical facilities located within the ROE.

E. Evacuation Routes, Emergency Assembly Area, Muster Areas, and Road Block Locations

1. Evacuation Routes, Emergency Assembly Area, and Muster Areas are depicted on Map D-1 in Appendix D.

2. Pre-planned road block locations are designated near the muster areas on Pipeline Road and Kincaid Ranch Road and are depicted on Map D-1 in Appendix D. Each location will have pre-positioned, portable road barriers with lights. The locations will have flashing lights and warning signs. If the release is sufficient to require evacuation to muster areas, then roadblocks near the muster areas on Kincaid Ranch Road and Pipeline Road to the west and north of the facility, respectively, will be established. The

Incident Commander (IC) will designate a representative to staff each of the two roadblocks. If deemed necessary by the Incident Commander (IC), the State or Local Police will be asked to assist with maintaining the roadblocks.

3. Emergency lights on the Muster Area signs will be activated by any perimeter alarm of 10 ppm or greater H₂S or Level III activation.

F. Monitoring Equipment, Alarm Systems, Safety Equipment, and Supplies Available

1. EMERGENCY SHUTDOWN SYSTEM: There are (8) ESD manual stations located at various points in the facility. See Maps A-2 and A-3 in Appendix A. The Plant ESD can be activated at any time by any employee or at the direction of the Incident Commander (IC).

When any one of the eight (8) manual stations is activated, the system will be shutdown and the natural gas inlets and outlets will be blocked. The operators are also able to auto close the one (1) main block valve on the incoming gas line to the Plant. Activating these should allow the plant to avoid a Level 3 response. The Incident Commander (IC) can send trained personnel to designated off-site manual block valves. There are also various methods to shut down gas flow at the various wellheads and incoming gathering lines. These can and would be evaluated on a case by case basis.

Designated employees will have remote access to the plant controls including ESD capabilities.

2. PLANT ALARMS, VISIBLE BEACONS & WIND INDICATORS: Colored beacons, horns, and wind direction indicators are located in various locations throughout the Plant and are indicated in Appendix A on Maps A-2, A-3, and A-6.

The audible signal for an emergency response and Plant evacuation is a repeating intermittent alarm that sounds at H₂S concentrations of 10 ppm or greater. The alarm will remain intermittent when the concentration of the H₂S release is 20 ppm or higher. At the initial sound of this intermittent alarm, the plant operators will evacuate to the emergency assembly area put on a self-contained breathing apparatus (SCBA) and all personnel in the plant complex shall immediately proceed in a safe manner to the Emergency Assembly Areas as prescribed by the Emergency Action Plan.

A flashing red beacon signifies an H₂S release of 20 ppm or higher and all personnel in the plant complex shall immediately proceed in a safe manner to the Emergency Assembly Area located outside of the plant office. If this area is not determined to be safe, all will move to designated Muster Area. Evacuation routes and Muster Areas are indicated on the map in Appendix A, on Map A-4 and A-6 as well as Appendix D, on Map D-1.

A routine process alarm will cause a horn to sound. This horn sound is used to alert the plant Operator to return to the Control Room. No emergency response or evacuation is required when this horn sounds.

Wind direction indicators are installed throughout the plant. At least one wind direction indicator can be seen at any location within the Plant complex, as well as from any point on the perimeter of the plant. There are ten (10) windsocks located in the Plant.

3. **GAS DETECTION EQUIPMENT:** The Plant uses a Smart Sensor System fixed plant H₂S Sensors. These sensors are a fixed point monitoring system used to detect the presence of hydrogen sulfide in ambient air. The yellow flashing beacon is activated at H₂S concentrations of 10 ppm or greater. The horn is activated with an intermittent alarm at H₂S concentrations of 10 ppm or greater. The lights change to red at 20 ppm H₂S and the horn remains intermittent. The fixed hydrogen sulfide monitors are strategically located throughout the Plant to detect an uncontrolled released of hydrogen sulfide. The Plant operators are able to monitor the H₂S level of all the Plant sensors on the control monitor located in the control room and the Dagger Draw Plant Field Office. In addition, select employees can access this information remotely. These sensors are located on the plot plan in Appendix A, Maps A-2 and A-3. These sensors all have to be acknowledged and will not clear themselves. This requires immediate action for any occurrence or malfunction. The Plant sensors are calibrated monthly.

Redline wireless H₂S detectors are installed along the perimeter of the plant and the perimeter of the acid gas disposal well. Perimeter H₂S detectors report to the Redline monitor every five minutes to confirm detector functionality. Once H₂S gas is detected, the H₂S detectors report to the monitor every five seconds. The detectors will go into alarm at H₂S values of 10 ppm and above. Redline H₂S head unit locations are depicted on Map A-5 and A-6 in Appendix A.

Handheld gas detection monitors are available to plant personnel to check specific areas and equipment prior to initiating maintenance or work on the process equipment. There are 3 handheld monitors and each individual is assigned a personal H₂S monitor. The handheld gas detection devices are Industrial Scientific ITX 3-gas detectors and BW Gas Alert Micro 5 4-way monitors. The detectors have sensors for oxygen, LEL (explosive hydrocarbon atmospheres), hydrogen sulfide, and carbon dioxide. They indicate the presence of H₂S with a beeping sound at 10 ppm. The beeps change in tone as H₂S increases to 20 ppm. The personal monitors are set to alarm (beep) at 10 ppm with the beeps becoming closer together as the H₂S concentration increases to 20 ppm. Both the handheld and personal monitors have digital readouts of H₂S ppm concentration.

a) The compressor building has two methane sensors; one sends a call out at 30% lower explosive limit (LEL); the second shuts the compressors down at 50% lower explosive limit (LEL). The methane sensors are visual and audible alarms. The compressor building also is equipped with fire eyes that will also shut the units down. The four product pumps also have LEL sensors.

4. **RESPIRATORS:** The Plant has 30 minute self-contained breathing apparatus (SCBA) respirators and 5 minute escape packs strategically located throughout the Plant. The respirator locations are identified in Appendix A on Maps A-3 and A-6. All Plant personnel are certified to use the self-contained breathing apparatus (SCBA) respirators.

5. **FIRE FIGHTING EQUIPMENT:** The Plant personnel are trained only for insipient stage fire fighting. The fire extinguishers located in the Plant process areas, compressor buildings, process buildings, and company vehicles are typically a 20# ABC dry chemical fire extinguisher. See Appendix A, Maps A-3 and A-6 for locations. The Plant does not have a fire water system, only a utility water system that is not designed for fire fighting.

6. EMERGENCY RESPONSE TRAILER AND EQUIPMENT: Agave Energy Company has an Emergency Response Trailer located at the Atoka Facility (Map 1; Map D-2 Appendix D). This is located outside all radii of exposure (ROE) from the facility along the pipeline to the well.

Driving Directions: From Artesia, drive south on Highway 285 to County Road 39. Turn east and drive approximately 2 miles. The facility is on the south side of the road in the NW/NE Sec 14 18S 26 E. See Map D-2 in Appendix D. The trailer can serve as a mobile resource center or Incident Command Center.

a) EMERGENCY RESPONSE TRAILER CONTENTS

- 2 wind socks / wind direction indicators w/poles & spares
- 1 – 110 volt generator, portable w/wheels
- 4 5-gas sensor ambient monitors (O₂, SO₂, LEL, CO, H₂S) with automatic air pumps (15 sec per foot) and data logging capability
- 1 calibration unit for monitors
- 5 intrinsically safe communication radios & chargers, 32 channel with capability to be programmed to fire service and police channels
- 4 20# stored pressure, ABC class Fire Extinguishers
- 4 4500 Grade D breathing air cylinders, regulator, low pressure alarm, and hose reel w/ 300 ft hose (total) and correct quick disconnects.
- 1 stretcher
- 1 20-person First Aid Kit with burn gel packets
- 4 30-minute SCBA's
- 4 work unit SCBA's
- 2 lights, mounted on each rear of trailer for night operations
- 2 hand cleaner for decontamination of petroleum products.
- 3 traffic Control Kits
- 1 emergency flare gun for lighting uncontrollable hazardous gases
- 2 full body harness and 150' X 2 lifelines
- 2 "Hazardous Area" "Do Not Enter" signs / barricades
- 2 burn gel blankets
- 1 set of maps and Emergency Response Plans
- 4 temporary use Nomex Fire retardant clothing (2-LG & 2-XLG)

7. TRAFFIC CONTROL KIT CONTENTS

- 3 electronic road flares
- 1 28" stop sign paddle
- 4 reflective traffic control vests
- 2 emergency signal wands
- 1 emergency Response Guidebook

8. FIRST AID EQUIPMENT LOCATIONS:

a) First Aid Kits are located at the following locations:

- Lab
- Office

b) Eye Wash stations are located at the following locations:

- Lab
- Office

9. PERSONAL H₂S MONITORS: All Agave personnel assigned to the Plant and associated field personnel are issued personal H₂S monitors.

10. SIGNS and MARKERS: The Plant has warning signs indicating the presence of "H₂S/Poisonous Gas" and high pressure gas at the entrance to the Plant. Emergency response phone numbers are posted at the entrance to the Plant. Signs are located at the Plant gate entrance indicating that all visitors are to sign in.

V. Characteristics of Hydrogen Sulfide (H₂S), Sulfur Dioxide (SO₂) and Carbon Dioxide (CO₂) [NMAC 19.15.11.9.B(2)(b)] [API RP-55 7.4 b.]

A. Hydrogen Sulfide (H₂S): Hydrogen Sulfide (H₂S): The proposed inlet gas streams into the Plant will contain a maximum of 7,600 ppm (or 0.76 mole percent) of hydrogen sulfide based on data generated from the sampling of the inlet gas at least daily. Hydrogen sulfide is a colorless, toxic and flammable gas, and has the odor of rotten eggs. Hydrogen sulfide gas is heavier than air. Hydrogen sulfide presents a significant health hazard by paralyzing the respiratory system resulting in serious injury or death.

Hydrogen Sulfide Properties and Characteristics		
CAS No.	7783-06-4	
Molecular Formula	H ₂ S	
Molecular Weight	34.082 g/mol	
Ceiling Concentration	20 ppm (OSHA)	
Ceiling Peak Concentration	50 ppm (OSHA)	
TLV	15 ppm (ACGIH)	
TWA	10 ppm (NIOSH)	
STEL	15 ppm (ACGIH)	
IDLH	100 ppm	
Specific Gravity Relative to Air (Air=1.0)	1.189	
Boiling Point	-76.5F	
Freezing Point	-121.8F	
Vapor Pressure	396 psia	
Autoignition Temperature	518F	
Lower Flammability Limit	4.3%	
Upper Flammability Limit	46.0%	
Stability	Stable	
pH in water	3	
Corrosivity	Reacts with metals, plastics, tissues and nerves	
Physical Effects of Hydrogen Sulfide		
Concentration		
Ppm	%	Physical Effects
1	0.00010	Can be smelled (rotten egg odor)
10	0.0010	Obvious & unpleasant odor; Permissible exposure level; safe for 8 hour exposure
20	0.0020	Acceptable ceiling concentration
50	0.0050	Loss of sense of smell in 15 minutes
100	0.0100	Immediately dangerous to life and health(IDLH) loss of sense of smell in 3-15 minutes; stinging in eyes & throat; Altered breathing
200	0.0200	Kills smell rapidly; stinging in eyes & throat

500	0.0500	Dizziness; Unconscious after short exposure; Need artificial respiration
700	0.0700	Unconscious quickly; death will result if not rescued promptly
1000	0.1000	Instant unconsciousness; followed by death within minutes

B. Sulfur Dioxide (SO₂): Sulfur dioxide is produced as a by-product of H₂S combustion at the flare. The flare unit receives the residual hydrogen sulfide and carbon dioxide stream that is routed from the amine unit. It is colorless, transparent, and is non-flammable, with a pungent odor associated with burning sulfur. Sulfur dioxide is heavier than air, but will be picked up by a breeze and carried downwind at elevated temperatures. Sulfur dioxide can be extremely irritating to the eyes and mucous membranes of the upper respiratory tract.

Sulfur Dioxide Properties & Characteristics	
CAS No.	7446-09-5
Molecular Formula	SO ₂
Molecular Weight	64.07 g/mol
PEL	5 ppm(OSHA)
TWA	2 ppm(ACGIH)
STEL	5 ppm(ACGIH)
IDLH	100 ppm
Specific Gravity Relative to Air (Air = 1.0)	2.26
Boiling Point	14°F
Freezing Point	-103.9°F
Vapor Pressure	49.1 psia
Auto ignition Temperature	N/A
Lower Flammability Limit	N/A
Upper Flammability Limit	N/A
Stability	Stable
Corrosivity	Could form an acid rain in aqueous solutions
Physical Effects of Sulfur Dioxide	
Concentration	Effect
1 ppm	Pungent odor, may cause respiratory changes
2 ppm	Permissible exposure limit; Safe for an 8 hour exposure
3-5 ppm	Pungent odor; normally a person can detect sulfur dioxide in this range
5 ppm	Short Term Exposure Limit (STEL); Safe for 15 minutes of exposure
12 ppm	Throat irritation, coughing, chest constriction, eyes tear and burn
100 ppm	Immediately Dangerous To Life & Health (IDLH)
150 ppm	So irritating that it can only be endured for a few minutes
500 ppm	Causes a sense of suffocation, even with first breath
1,000 ppm	Death may result unless rescued promptly.

C. **Carbon Dioxide (CO₂)**: The proposed inlet streams into the Plant will contain a maximum of 383,100 ppm (or 38.31 mole percent) of carbon dioxide based on data generated from the sampling of the inlet gas at least daily. Carbon dioxide gas is colorless, odorless and non-flammable and is heavier than air.

Carbon Dioxide Properties & Characteristics	
CAS No.	124-38-9
Molecular Formula	CO ₂
Molecular Weight	44.010 g/mol
TWA	5,000 ppm
STEL	30,000 ppm
IDLH	40,000 ppm
Specific Gravity Relative to Air (Air = 1.0)	1.5197
Boiling Point	-109.12°F
Freezing Point	-69.81°F
Vapor Pressure	830 psia
Autoignition Temperature	N/A
Lower Flammability Limit	N/A
Upper Flammability Limit	N/A
Stability	Stable
pH in Saturated Solution	3.7
Corrosivity	dry gas is relatively inert & not corrosive; can be corrosive to mild steels in aqueous solutions
Physical Effects of Carbon Dioxide	
Concentration	Effect
1.0 %	Breathing rate increases slightly
2.0 %	Breathing rate increases to 50% above normal level. Prolonged exposure can cause headache, tiredness
3.0 %	Breathing rate increases to twice normal rate and becomes labored. Weak narcotic effect. Impaired hearing, headache, increased blood pressure and pulse rate
4 – 5 %	Breathing increases to approximately four times normal rate, symptoms of intoxication become evident, and slight choking may be felt
5 – 10 %	Characteristic sharp odor noticeable. Very labored breathing, headache, visual impairment, and ringing in the ears. Judgment may be impaired, followed within minutes by loss of consciousness
10 – 100 %	Unconsciousness occurs more rapidly above 10% level. Prolonged exposure to high concentrations may eventually result in death from asphyxiation

D. Radii of Exposure (ROE) [NMAC 19.15.11.7.K]

The basis for worst case scenario calculations is as follows:

- The hydrogen sulfide content of the inlet natural gas stream into the Agave Dagger Draw Gas Plant is variable, ranging upwards to 7,600 parts per million (ppm) or 0.76 mole percent. In reality, the actual H₂S concentration that the plant processes will be much less than this.
- The inlet gas H₂S concentration of 0.76 mole percent was determined using a mass-balance approach, an analysis of 60.8 mole percent H₂S in the acid gas stream and a maximum acid gas flow rate of 0.5 MMSCFD. It is assumed that the amine system removes 100% of the H₂S from the inlet gas.
- The plant has a maximum daily (24 hour) processing volume of 40 MMSCF.
- The worst case scenario radius of exposure (ROE) also assumes an uncontrolled instantaneous release from the area around either the Metropolis Disposal #1 Well, the amine still at the facility and/or at any point along the pipeline connecting the two of the above referenced volume and concentration. Because the Plant is a throughput process plant, it is impossible that the entire 24 hour-throughput volume of the Plant could be released instantaneously as is assumed in the worst case scenario calculations of the ROE. However, to comply with NMAC 19.15.11, that assumption is the worst case scenario in the formulas/calculations provided here.

It should further be noted that the reason this rate, used as worst case, could not be released over a 24 hour period is the Plant's emergency shutdown (ESD) systems would be activated. The emergency shutdown (ESD) would prevent the flow of gas into the Plant in the event of an emergency. See Appendix C and Map C-1 for more information.

The formulas for calculating the two radius of exposure (ROE) are as follows:

100 ppm Radius of Exposure Calculation (as per 19 NMAC 15.11.7.K.1):

$$X = [(1.589)(\text{hydrogen sulfide concentration})(Q)]^{(0.6258)}$$

500 ppm Radius of Exposure Calculation (as per 19 NMAC 15.11.7.K.2):

$$X = [(0.4546)(\text{hydrogen sulfide concentration})(Q)]^{(0.6258)}$$

Where:

X = radius of exposure in feet

"hydrogen sulfide concentration" = the decimal equivalent of the mole or volume fraction of hydrogen sulfide in the gaseous mixture

Q = Escape rate expressed in cubic feet per day (corrected for standard conditions of 14.73 psi absolute and 60 degrees Fahrenheit)

Amine Unit (Facility)

500-ppm ROE	1648 feet
100-ppm ROE	3606 feet

Pipeline

500-ppm ROE	1648 feet
100-ppm ROE	3606 feet

Acid Gas Disposal Well

500-ppm ROE	1648 feet
100-ppm ROE	3606 feet

The ROE for the facility, pipeline and well are shown on Map C-1 of Appendix C. This ROE pattern is designed to include the 100 and 500 ppm radii for a potential worst case failure at any point in the system from the facility at the north to the well to the south.

VI. Facility Description, Maps, and Drawings

[NMAC 19.15.11.9.B(2)(c)] [API RP-55 7.4 c.]

A. Dagger Draw Processing Plant Description of Operations- The primary function of the plant is to remove H₂S and CO₂ from sour field gas so that the gas can meet pipeline specifications. The plant has been designated a primary Standard Industrial Classification (SIC) Code of 1311. The operation of the Agave Dagger Draw Gas Plant is intended to process 40 MMSCFD of gas. The facility is authorized to operate continuously (8,760 hr/yr) at design maximum capacity processing rates. The gas will be treated to remove acid gas components, dehydrated to remove water and processed to remove heavy (liquid) hydrocarbons from the gas stream. Several plant systems will be involved to perform these functions.

The amine unit is designed to remove acid gas components (carbon dioxide, hydrogen sulfide and mercaptans) from the natural gas stream. These components are removed from the natural gas because they are corrosive, hazardous to health, and reduce the heating value of the natural gas stream. In addition, the carbon dioxide can freeze in the cryogenic unit forming dry ice and forcing the shutdown of the facility. This is known as the gas sweetening process. The acid gas removed by the amine unit will be disposed of by either acid gas injection into a disposal well or by incinerating in a flare. The preferred method of disposal will be to compress the gas and inject it into the well. Under emergency situations, the gas will be flared to prevent the emission of lethal hydrogen sulfide to atmosphere.

The glycol dehydration unit will receive approximately 40.0 MMSCFD of treated gas (sweet) from the amine unit and reduce the water content of the gas by circulating triethylene glycol (TEG). Molecular sieve dehydration is used upstream of the cryogenic processes to achieve a -150°F dew point. The process uses two molecular sieve vessels with one vessel in service absorbing moisture from the gas stream and the other vessel in the regeneration mode.

The cryogenic unit is designed to liquefy natural gas components from the sweet, dehydrated inlet gas by removing work (heat) from the gas by means of the turbo expander. The cryogenic unit recovers natural gas liquids (NGL) by cooling the gas stream

to extremely cold temperatures (-150°F) and condensing components such as ethane, propane, butanes and heavier hydrocarbons. Once the sweet, dry gas exits the cryogenic unit, it needs to be recompressed to approximately 800 to 1200 psi before the gas is sent to the main transportation pipeline. This is accomplished with two 2500 horsepower electric drive compressors.

The hot oil system in the plant is used to provide heat to certain processes within the facility. The system will circulate approximately 600 GPM of hot oil and deliver 15.5 MMBTU/hr to other processes.

B. Metropolis Disposal #1 Well Description of Operations- The low pressure (< 10 psig), acid gas stream from the amine unit is routed to the acid gas compressor. The stream is then subject to a series of compression and cooling cycles, thus dehydrating and compressing the acid gas stream to a pressure of approximately 1150 psig. The high pressure acid gas stream then flows through a 2" stainless steel pipeline to the injection well site. At this point, the stream is introduced into the well.

There are a number of safeguards designed to prevent leaks or overpressure of the system. The acid gas compressor is equipped with multiple pressure transmitters. These transmitters monitor compressor suction and discharge pressures and are programmed to shut the acid gas system down when the pressures fall outside a pre-programmed operating range. As an additional safeguard, the compressor panel is also equipped with high and low pressure shutdowns for each stage of compression that will shut the compressor down when pressures reach preset high and low pressure set points.

As shown on Map 2, the acid gas pipeline runs from the Agave Dagger Draw Plant in a southwesterly direction, crosses Kincaid Ranch Road at the plant boundary and continues southwesterly along a gravel road for approximately 3680 feet. The pipeline then turns east along the Metropolis Disposal #1 Well access road for an additional 900 feet to the wellhead. South of Kincaid Ranch Road, the pipeline and well are entirely contained within Section 36, Township 18 South, Range 25 East. This land is owned by the State of New Mexico. Agave Energy has the following three Rights-of-Way from the State of New Mexico in this section for the pipeline: R18068, R17745 and R17949. The Metropolis Disposal #1 Well Site is covered under Yates Petroleum Company Oil Leases VO-6141-0000 and E1-0165-0001. The pipeline is buried at a depth of 6-1/2 feet for its entire length and is marked, as required, with permanent surface markers. (See Map 2 and Figure 1)

The acid gas pipeline is constructed from 2" inch 304 stainless steel tubing. The pipeline has been designed with a maximum allowable working pressure of 2350 psig. Historical injection pressures average 1150 psig. For leak detection purposes, the 2" acid gas line has been encased in 6" SDR 11 polyethylene pipe. A "sweet" gas stream flows through the annulus between the 6" and 2" pipelines at a preset pressure and flow rate. This sweet gas stream is monitored continuously for H₂S and over/ under pressure. If any one variable falls outside the predetermined operating range, the acid gas compressor is shut down and the acid gas stream is routed to the flare.

Safeguards for the acid gas injection well consist of a subsurface safety valve. This valve is designed to isolate and shut in the injection well if a leak occurs along the acid gas pipeline or at the surface of the well.

C. Map of Plant and Metropolis Disposal #1 Well

See Appendix A, Map A-1

VII. Training and Drills

[NMAC 19.15.11.9.B(2)(d)] [API RP-55 7.4 d]

A. Responsibilities and Duties of Essential Personnel

1. Personnel responsible for implementing this plan shall be trained on their duties and responsibilities related to this plan during the annual on-site or table top training exercises.
2. Plant Orientation Training - All Plant personnel, visitors, and contractors must attend a Plant overview orientation prior to obtaining permission to enter the Plant. A refresher course on this training is required annually for all persons. This training also complies with the requirements of the Agave Energy Company Process Safety Management Program and Procedures Manual.

B. On-site or Classroom Drills

Agave Energy Company may use table top exercises as well as hands on emergency response training methods. Agave Energy Company shall conduct a table top exercise annually at a minimum.

C. Notification and Training of Others on Protective Measures in Emergency Situations

Affected residents will be invited to participate and/or observe annual drills, as well as being briefed on notification, evacuation, and shelter in place plans.

D. Training and Attendance Documentation

All training and drills will be documented. Documentation shall include sign in sheets, synopsis of the training conducted, and an after action review of the training.

E. Briefing of Public Officials on Evacuation and Shelter in Place Plans

Local law enforcement, first responders, and fire personnel will also be invited to participate and/or observe annual drills, as well as being briefed on notification, evacuation, and shelter in place plans.

VIII. Coordination with State Emergency Plans

[NMAC 19.15.11.9.B(2)(e)]

A. Oil Conservation Division (OCD)

1. Oil Conservation Division (OCD) will be notified with an automatic email to the District II office advising of the activation of the H₂S Contingency Plan if any of the alarms are activated at 10 ppm H₂S or greater. In the event of a power failure, a phone call will be made within four hours. All subsequent paperwork will be filed in a timely fashion.

B. New Mexico State Police/ New Mexico Hazardous Materials Emergency Response Plan

1. The New Mexico State Police are responsible for overall scene management and coordination of all resources. A designated Emergency Response Officer (ERO) will establish the National Interagency Incident Management System (NIIMS) Incident Command System (ICS) as the Incident Commander (IC) and be responsible for management of all response resources on scene. Off-scene coordination of response resources will be handled through designated Headquarters Emergency Response Officers. Law enforcement-related activities will be coordinated by State Police.

IX. Plan Activation

[NMAC 19.15.11.9.C] [API RP-55 7.4 d]

A. Activation Levels

Level 1 – Intermittent alarm sounded and/or flashing amber beacons activated for H₂S greater than or equal to 10 ppm

Level 2 – Intermittent alarm sounded and/or flashing red beacons activated for H₂S greater than or equal to 20 ppm

Level 3 –Catastrophic release; fire; explosion; a continuous release of maximum volume for 24 hours; or NMAC 19.15.11: mandatory activation of indication of 100 ppm in any defined public area; 500 ppm at any public road; or 100 ppm at a distance greater than 3000 feet from the site or the release. Because the 100 ppm radius of impact (ROE) boundary is greater than 3000 feet from the site of release, a Level 3 response would occur before the escape of the 24 hour release volume.

B. Events that Could Lead to a Release of H₂S

- Inlet and plant piping failure
- Amine still failure
- Flange/gasket leaks on inlet and plant piping
- Flange/gasket leaks on the acid gas compressor
- Flange/gasket leaks at metropolis disposal well
- Failure of acid gas pipeline
- Valve packing
- Seal failure on acid gas compressor
- Failure of flare to ignite during Plant emergency blow down

X. Submission of H₂S Contingency Plans

[NMAC 19.15.11.9.D]

A. Submission

1. Agave Energy Company will submit the H₂S Contingency Plan to the Oil Conservation Division (OCD).

B. Retention

1. Agave Energy Company shall maintain a copy of the contingency plan in the Main Office at 105 South 4th Street in Artesia, NM. The plan shall be readily accessible for review by the Oil Conservation Division (OCD) upon request.

C. Inventory


1. Agave Energy Company will file an annual inventory of wells, facilities and operations for which plans are on file with the Oil Conservation Division (OCD), to the Local Emergency Planning Committee (LEPC) and the State Emergency Response Commission as per NMAC 19.15.11.
2. The inventory shall include the name, address, telephone number, and point of contact for all operations in which plans are on file.

MAPS AND FIGURES

MAP 1: Agave Dagger Draw Plant Facilities Locations

MAP 2: General Diagram of Agave Dagger Draw Gas Plant and Location of Pipeline Connecting Plant with Metropolis Disposal #1 Well

FIGURE 1: Photos of Pipeline



MAP 1



AGAVE ENERGY COMPANY
 115 South Fourth Street, Artesia, New Mexico 88210
 AGAVE DAGGER GAS DRAW PLANT
 HYDROGEN SULFIDE CONTINGENCY PLAN
 FACILITIES LOCATIONS

DRAWN BY: []	CHECKED BY: []	DATE: 11/10/10	SCALE: 1"=400'
DATE: 11/10/10	SCALE: 1"=400'	DATE: 11/10/10	SCALE: 1"=400'



Map 2: General Diagram of Agave Dagger Draw Gas Plant and Location of Pipeline Connecting the Plant with the Metropolis Disposal #1 Well





Figure 1: Photos of Pipeline Connecting Agave Energy's Dagger Draw Gas Plant With Metropolis Disposal #1 well. A) Acid Gas Compressed at the Gas Plant is Introduced to a 2" Stainless Steel Pipeline Surrounded by a 6" Polyethylene Pipe. Pipeline Integrity is Monitored Using a Stream of Sweet Natural Gas in the Volume Between the Two Pipes. B) Outside of the Fenced in Areas at the Plant and Wellhead, the Pipeline is Buried and Clearly Marked. C) The Pipeline Rises Above Ground and Connects to the Production Tree at the Metropolis Disposal #1 Wellhead

APPENDIX A – Facility Maps

- Map A-1: Facility Map**
- Map A-2: Alarms and Monitors, Dagger Draw Active Equipment**
- Map A-3: Safety and Fire Equipment, Dagger Draw Active Equipment**
- Map A-4: Evacuation Router, Dagger Draw Active Equipment**
- Map A-5: Proposed Perimeter Alarms**
- Map A-6: Metropolis Disposal Well**

MAP A-1



AGAVE ENERGY COMPANY
105 South Fourth Street, Atrium, New Mexico 88710

AGAVE DAGGER DRAW
GAS PROCESSING PLANT


Facility Map &
Metropolis Disposal Well

DATE	10/21/2010
BY	AGAVE
REVISION 1	10/21/2010
REVISION 2	10/21/2010
REVISION 3	10/21/2010
REVISION 4	10/21/2010

SCALE	AS SHOWN
DATE	10/21/2010
BY	AGAVE

0 0.25 Miles

MAP A-2




<p>ALLIANCE</p> <ul style="list-style-type: none"> 101 MAIN BUILDING 102 MAIN ANALYZING 103 PREPACK 104 CHROMATOGRAPHY BUILDING 105 COMPRESSOR WEST 106 AIR COMPRESSOR BUILDING 107 SHOP 108 MAIN AREA 109 FLARE PREPACK 110 CONTROL ROOM COMPUTER 	<p>INSTRUMENTATION</p> <ul style="list-style-type: none"> 111 HALLMETER 112 ACID GAS COMPRESSOR NORTH 113 CONDENSATE SKID 114 MAIN RECEIVER 115 MAIN PREPACK 116 INLET PREPACK 	<p>PRODUCT HANDLING</p> <ul style="list-style-type: none"> 117 PRODUCT PUMP CONTROL 118 PRODUCT PUMP CONTROL B 119 PRODUCT PUMP CONTROL A 120 PRODUCT PUMP CONTROL 	<p>AGAVE ENERGY COMPANY</p> <p>100 South Fourth Street, Arroyo, New Mexico 87102</p> <p>AGAVE DAGGER DRAW</p> <p>GAS PROCESSING PLANT</p> <p>Alarms & Monitors</p>
---	---	---	---

0.10

Miles

0




PLANT NORTH

HELIUM TANKS	
● 41 DRY	● 47 CO2
● 42 DRY	● 48 DRY
● 43 DRY	● 49 DRY
● 44 DRY	● 50 DRY
● 45 DRY	● 51 DRY
● 46 DRY	● 52 DRY
● 47 DRY	● 53 DRY
● 48 DRY	● 54 DRY
● 49 DRY	● 55 DRY
● 50 DRY	● 56 DRY
● 51 DRY	● 57 DRY
● 52 DRY	● 58 DRY
● 53 DRY	● 59 DRY
● 54 DRY	● 60 DRY
● 55 DRY	● 61 DRY
● 56 DRY	● 62 DRY
● 57 DRY	● 63 DRY
● 58 DRY	● 64 DRY
● 59 DRY	● 65 DRY
● 60 DRY	● 66 DRY
● 61 DRY	● 67 DRY
● 62 DRY	● 68 DRY
● 63 DRY	● 69 DRY
● 64 DRY	● 70 DRY
● 65 DRY	● 71 DRY
● 66 DRY	● 72 DRY
● 67 DRY	● 73 DRY
● 68 DRY	● 74 DRY
● 69 DRY	● 75 DRY
● 70 DRY	● 76 DRY
● 71 DRY	● 77 DRY
● 72 DRY	● 78 DRY
● 73 DRY	● 79 DRY
● 74 DRY	● 80 DRY
● 75 DRY	● 81 DRY
● 76 DRY	● 82 DRY
● 77 DRY	● 83 DRY
● 78 DRY	● 84 DRY
● 79 DRY	● 85 DRY
● 80 DRY	● 86 DRY
● 81 DRY	● 87 DRY
● 82 DRY	● 88 DRY
● 83 DRY	● 89 DRY
● 84 DRY	● 90 DRY
● 85 DRY	● 91 DRY
● 86 DRY	● 92 DRY
● 87 DRY	● 93 DRY
● 88 DRY	● 94 DRY
● 89 DRY	● 95 DRY
● 90 DRY	● 96 DRY
● 91 DRY	● 97 DRY
● 92 DRY	● 98 DRY
● 93 DRY	● 99 DRY
● 94 DRY	● 100 DRY
● 95 DRY	● 101 DRY
● 96 DRY	● 102 DRY
● 97 DRY	● 103 DRY
● 98 DRY	● 104 DRY
● 99 DRY	● 105 DRY
● 100 DRY	● 106 DRY
● 101 DRY	● 107 DRY
● 102 DRY	● 108 DRY
● 103 DRY	● 109 DRY
● 104 DRY	● 110 DRY
● 105 DRY	● 111 DRY
● 106 DRY	● 112 DRY
● 107 DRY	● 113 DRY
● 108 DRY	● 114 DRY
● 109 DRY	● 115 DRY
● 110 DRY	● 116 DRY
● 111 DRY	● 117 DRY
● 112 DRY	● 118 DRY
● 113 DRY	● 119 DRY
● 114 DRY	● 120 DRY
● 115 DRY	● 121 DRY
● 116 DRY	● 122 DRY
● 117 DRY	● 123 DRY
● 118 DRY	● 124 DRY
● 119 DRY	● 125 DRY
● 120 DRY	● 126 DRY
● 121 DRY	● 127 DRY
● 122 DRY	● 128 DRY
● 123 DRY	● 129 DRY
● 124 DRY	● 130 DRY
● 125 DRY	● 131 DRY
● 126 DRY	● 132 DRY
● 127 DRY	● 133 DRY
● 128 DRY	● 134 DRY
● 129 DRY	● 135 DRY
● 130 DRY	● 136 DRY
● 131 DRY	● 137 DRY
● 132 DRY	● 138 DRY
● 133 DRY	● 139 DRY
● 134 DRY	● 140 DRY
● 135 DRY	● 141 DRY
● 136 DRY	● 142 DRY
● 137 DRY	● 143 DRY
● 138 DRY	● 144 DRY
● 139 DRY	● 145 DRY
● 140 DRY	● 146 DRY
● 141 DRY	● 147 DRY
● 142 DRY	● 148 DRY
● 143 DRY	● 149 DRY
● 144 DRY	● 150 DRY
● 145 DRY	● 151 DRY
● 146 DRY	● 152 DRY
● 147 DRY	● 153 DRY
● 148 DRY	● 154 DRY
● 149 DRY	● 155 DRY
● 150 DRY	● 156 DRY
● 151 DRY	● 157 DRY
● 152 DRY	● 158 DRY
● 153 DRY	● 159 DRY
● 154 DRY	● 160 DRY
● 155 DRY	● 161 DRY
● 156 DRY	● 162 DRY
● 157 DRY	● 163 DRY
● 158 DRY	● 164 DRY
● 159 DRY	● 165 DRY
● 160 DRY	● 166 DRY
● 161 DRY	● 167 DRY
● 162 DRY	● 168 DRY
● 163 DRY	● 169 DRY
● 164 DRY	● 170 DRY
● 165 DRY	● 171 DRY
● 166 DRY	● 172 DRY
● 167 DRY	● 173 DRY
● 168 DRY	● 174 DRY
● 169 DRY	● 175 DRY
● 170 DRY	● 176 DRY
● 171 DRY	● 177 DRY
● 172 DRY	● 178 DRY
● 173 DRY	● 179 DRY
● 174 DRY	● 180 DRY
● 175 DRY	● 181 DRY
● 176 DRY	● 182 DRY
● 177 DRY	● 183 DRY
● 178 DRY	● 184 DRY
● 179 DRY	● 185 DRY
● 180 DRY	● 186 DRY
● 181 DRY	● 187 DRY
● 182 DRY	● 188 DRY
● 183 DRY	● 189 DRY
● 184 DRY	● 190 DRY
● 185 DRY	● 191 DRY
● 186 DRY	● 192 DRY
● 187 DRY	● 193 DRY
● 188 DRY	● 194 DRY
● 189 DRY	● 195 DRY
● 190 DRY	● 196 DRY
● 191 DRY	● 197 DRY
● 192 DRY	● 198 DRY
● 193 DRY	● 199 DRY
● 194 DRY	● 200 DRY
● 195 DRY	● 201 DRY
● 196 DRY	● 202 DRY
● 197 DRY	● 203 DRY
● 198 DRY	● 204 DRY
● 199 DRY	● 205 DRY
● 200 DRY	● 206 DRY
● 201 DRY	● 207 DRY
● 202 DRY	● 208 DRY
● 203 DRY	● 209 DRY
● 204 DRY	● 210 DRY
● 205 DRY	● 211 DRY
● 206 DRY	● 212 DRY
● 207 DRY	● 213 DRY
● 208 DRY	● 214 DRY
● 209 DRY	● 215 DRY
● 210 DRY	● 216 DRY
● 211 DRY	● 217 DRY
● 212 DRY	● 218 DRY
● 213 DRY	● 219 DRY
● 214 DRY	● 220 DRY
● 215 DRY	● 221 DRY
● 216 DRY	● 222 DRY
● 217 DRY	● 223 DRY
● 218 DRY	● 224 DRY
● 219 DRY	● 225 DRY
● 220 DRY	● 226 DRY
● 221 DRY	● 227 DRY
● 222 DRY	● 228 DRY
● 223 DRY	● 229 DRY
● 224 DRY	● 230 DRY
● 225 DRY	● 231 DRY
● 226 DRY	● 232 DRY
● 227 DRY	● 233 DRY
● 228 DRY	● 234 DRY
● 229 DRY	● 235 DRY
● 230 DRY	● 236 DRY
● 231 DRY	● 237 DRY
● 232 DRY	● 238 DRY
● 233 DRY	● 239 DRY
● 234 DRY	● 240 DRY
● 235 DRY	● 241 DRY
● 236 DRY	● 242 DRY
● 237 DRY	● 243 DRY
● 238 DRY	● 244 DRY
● 239 DRY	● 245 DRY
● 240 DRY	● 246 DRY
● 241 DRY	● 247 DRY
● 242 DRY	● 248 DRY
● 243 DRY	● 249 DRY
● 244 DRY	● 250 DRY
● 245 DRY	● 251 DRY
● 246 DRY	● 252 DRY
● 247 DRY	● 253 DRY
● 248 DRY	● 254 DRY
● 249 DRY	● 255 DRY
● 250 DRY	● 256 DRY
● 251 DRY	● 257 DRY
● 252 DRY	● 258 DRY
● 253 DRY	● 259 DRY
● 254 DRY	● 260 DRY
● 255 DRY	● 261 DRY
● 256 DRY	● 262 DRY
● 257 DRY	● 263 DRY
● 258 DRY	● 264 DRY
● 259 DRY	● 265 DRY
● 260 DRY	● 266 DRY
● 261 DRY	● 267 DRY
● 262 DRY	● 268 DRY
● 263 DRY	● 269 DRY
● 264 DRY	● 270 DRY
● 265 DRY	● 271 DRY
● 266 DRY	● 272 DRY
● 267 DRY	● 273 DRY
● 268 DRY	● 274 DRY
● 269 DRY	● 275 DRY
● 270 DRY	● 276 DRY
● 271 DRY	● 277 DRY
● 272 DRY	● 278 DRY
● 273 DRY	● 279 DRY
● 274 DRY	● 280 DRY
● 275 DRY	● 281 DRY
● 276 DRY	● 282 DRY
● 277 DRY	● 283 DRY
● 278 DRY	● 284 DRY
● 279 DRY	● 285 DRY
● 280 DRY	● 286 DRY
● 281 DRY	● 287 DRY
● 282 DRY	● 288 DRY
● 283 DRY	● 289 DRY
● 284 DRY	● 290 DRY
● 285 DRY	● 291 DRY
● 286 DRY	● 292 DRY
● 287 DRY	● 293 DRY
● 288 DRY	● 294 DRY
● 289 DRY	● 295 DRY
● 290 DRY	● 296 DRY
● 291 DRY	● 297 DRY
● 292 DRY	● 298 DRY
● 293 DRY	● 299 DRY
● 294 DRY	● 300 DRY
● 295 DRY	● 301 DRY
● 296 DRY	● 302 DRY
● 297 DRY	● 303 DRY
● 298 DRY	● 304 DRY
● 299 DRY	● 305 DRY
● 300 DRY	● 306 DRY
● 301 DRY	● 307 DRY
● 302 DRY	● 308 DRY
● 303 DRY	● 309 DRY
● 304 DRY	● 310 DRY
● 305 DRY	● 311 DRY
● 306 DRY	● 312 DRY
● 307 DRY	● 313 DRY
● 308 DRY	● 314 DRY
● 309 DRY	● 315 DRY
● 310 DRY	● 316 DRY
● 311 DRY	● 317 DRY
● 312 DRY	● 318 DRY
● 313 DRY	● 319 DRY
● 314 DRY	● 320 DRY
● 315 DRY	● 321 DRY
● 316 DRY	● 322 DRY
● 317 DRY	● 323 DRY
● 318 DRY	● 324 DRY
● 319 DRY	● 325 DRY
● 320 DRY	● 326 DRY
● 321 DRY	● 327 DRY
● 322 DRY	● 328 DRY
● 323 DRY	● 329 DRY
● 324 DRY	● 330 DRY
● 325 DRY	● 331 DRY
● 326 DRY	● 332 DRY
● 327 DRY	● 333 DRY
● 328 DRY	● 334 DRY
● 329 DRY	● 335 DRY
● 330 DRY	● 336 DRY
● 331 DRY	● 337 DRY
● 332 DRY	● 338 DRY
● 333 DRY	● 339 DRY
● 334 DRY	● 340 DRY
● 335 DRY	● 341 DRY
● 336 DRY	● 342 DRY
● 337 DRY	● 343 DRY
● 338 DRY	● 344 DRY
● 339 DRY	● 345 DRY
● 340 DRY	● 346 DRY
● 341 DRY	● 347 DRY
● 342 DRY	● 348 DRY
● 343 DRY	● 349 DRY
● 344 DRY	● 350 DRY
● 345 DRY	● 351 DRY
● 346 DRY	● 352 DRY
● 347 DRY	● 353 DRY
● 348 DRY	● 354 DRY
● 349 DRY	● 355 DRY
● 350 DRY	● 356 DRY
● 351 DRY	● 357 DRY
● 352 DRY	● 358 DRY
● 353 DRY	● 359 DRY
● 354 DRY	● 360 DRY
● 355 DRY	● 361 DRY
● 356 DRY	● 362 DRY
● 357 DRY	● 363 DRY
● 358 DRY	● 364 DRY
● 359 DRY	● 365 DRY
● 360 DRY	● 366 DRY
● 361 DRY	● 367 DRY
● 362 DRY	● 368 DRY
● 363 DRY	● 369 DRY
● 364 DRY	● 370 DRY
● 365 DRY	● 371 DRY
● 366 DRY	● 372 DRY
● 367 DRY	● 373 DRY
● 368 DRY	● 374 DRY
● 369 DRY	● 375 DRY
● 370 DRY	● 376 DRY
● 371 DRY	● 377 DRY
● 372 DRY	● 378 DRY
● 373 DRY	● 379 DRY
● 374 DRY	● 380 DRY
● 375 DRY	● 381 DRY
● 376 DRY	● 382 DRY
● 377 DRY	● 383 DRY
● 378 DRY	● 384 DRY
● 379 DRY	● 385 DRY
● 380 DRY	● 386 DRY
● 381 DRY	● 387 DRY
● 382 DRY	● 388 DRY
● 383 DRY	● 389 DRY
● 384 DRY	● 390 DRY
● 385 DRY	● 391 DRY
● 386 DRY	● 392 DRY
● 387 DRY	● 393 DRY
● 388 DRY	● 394 DRY
● 389 DRY	● 395 DRY
● 390 DRY	● 396 DRY
● 391 DRY	● 397 DRY
● 392 DRY	● 398 DRY
● 393 DRY	● 399 DRY
● 394 DRY	● 400 DRY
● 395 DRY	● 401 DRY
● 396 DRY	● 402 DRY
● 397 DRY	● 403 DRY
● 398 DRY	● 404 DRY
● 399 DRY	● 405 DRY
● 400 DRY	● 406 DRY
● 401 DRY	● 407 DRY
● 402 DRY	● 408 DRY
● 403 DRY	● 409 DRY
● 404 DRY	● 410 DRY
● 405 DRY	●

APPENDIX B – Response Flow Diagrams

LEVEL I RESPONSE



LEVEL II RESPONSE

CALL 911 for death or injury for emergency assistance

H₂S detected greater than or equal to 20 ppm: intermittent audible alarm and flashing red lights

- Put on Emergency Respirators
- Evacuate to Emergency Assembly Area
- Evacuate visitors from plant to designated Muster Area
- Assign operators to suit up in SCBA
- Check Plant Control System for location of H₂S alarm
- Notify all entities in the 500 ppm ROE if perimeter alarms are activated
- Notify residents in the 100 ppm ROE to shelter in place or evacuate depending on weather and release conditions (IC determines this) if perimeter alarms are activated
- Wearing SCBA attempt to locate and repair leak
- Rotate Operators in 15 minute shifts
- Re-entry will occur for 45 minutes or until the IC determines the ESD must be activated
- Notify LEPC
- If H₂S levels exceed 10 ppm in emergency assembly area relocate to an alternate Muster Area

- If H₂S levels exceed 20 ppm and repair efforts are unsuccessful, worst case scenario and/or catastrophic release have occurred then implement Level 3 response

Once resolved and monitored levels in Plant are less than 10 ppm H₂S: return to plant and continue to monitor

LEVEL III RESPONSE

CALL 911 for death or injury for emergency assistance

H₂S detected greater than 20 ppm: intermittent audible alarm and flashing red lights repair efforts are unsuccessful, worst case scenario and/or catastrophic release have occurred

H₂S detected greater than 50 ppm: plant will automatically go in to ESD. IC determines to proceed with Level III or Level II after ESD

- Set up road blocks on Kincaid and Pipeline Roads near the muster areas
- Confirm all personnel have evacuated the 500 ppm ROE
- Instruct all personnel in the 100 ppm ROE to evacuate to Muster Area as determined by the IC
- If vapors have ignited, continue to let burn unless fires endanger personnel
- Initiate a chronological record of events
- Within one hour of activation of the plan notify NMOCD and the NRC
- Establish a Media staging area in Muster Area 2 or other location as the situation permits
- Submit agency reports as required

Once resolved and monitored levels in Plant are less than 10 ppm H₂S: return to Plant continue to monitor

APPENDIX C - Radius of Exposure Calculations

Map C-1 Radius of Exposure

APPENDIX C-RADIUS OF EXPOSURE CALCULATIONS

The basis for worst case scenario calculations is as follows:

- The hydrogen sulfide content of the inlet natural gas stream into the Agave Dagger Draw Gas Plant is variable, ranging upwards to 7,600 parts per million (ppm) or 0.76 mole percent. In reality, the actual H₂S concentration that the plant processes will be much less than this.
- The inlet gas H₂S concentration of 0.76 mole percent was determined using a mass-balance approach, an analysis of 60.8 mole percent H₂S in the acid gas stream and a maximum acid gas flow rate of 0.5 MMSCFD. It is assumed that the amine system removes 100% of the H₂S from the inlet gas.

The plant has a maximum daily (24 hour) processing volume of 40 MMSCF.

- The worst case scenario radius of exposure (ROE) also assumes an uncontrolled instantaneous release from the area around either the Metropolis #1 Well, the amine still at the facility and at any point along the pipeline connecting the two of the above referenced volume and concentration. Because the Plant is a throughput process plant, it is impossible that the entire 24 hour-throughput volume of the Plant could be released instantaneously as is assumed in the worst case scenario calculations of the ROE. However, to comply with NMAC 19.15.11, that assumption is the worst case scenario in the formulas/calculations provided here.

It should further be noted that the reason this rate, used as worst case, could not be released over a 24 hour period is the Plant's emergency shutdown (ESD) systems would be activated. The emergency shutdown (ESD) would prevent the flow of gas into the Plant in the event of an emergency. See Appendix C and Map C-1 for more information.

The formulas for calculating the two radius of exposure (ROE) are as follows:

100 ppm Radius of Exposure Calculation (as per 19 NMAC 15.11.7.K.1):

$$X=[(1.589)(\text{hydrogen sulfide concentration})(Q)]^{(0.6258)}$$

500 ppm Radius of Exposure Calculation (as per 19 NMAC 15.11.7.K.2):

$$X=[(0.4546)(\text{hydrogen sulfide concentration})(Q)]^{(0.6258)}$$

Where:

X = radius of exposure in feet

"hydrogen sulfide concentration" = the decimal equivalent of the mole or volume fraction of hydrogen sulfide in the gaseous mixture

Q = Escape rate expressed in cubic feet per day (corrected for standard conditions of 14.73 psi absolute and 60 degrees Fahrenheit)

ROE Inside the Plant

The escape rate (Q) is the maximum daily rate of the gaseous mixture produced or handled or the best estimate thereof. For releases inside the Agave Dagger Draw Gas Plant, the Company is using for contingency planning purposes an "escape rate" equal to the maximum inlet gas volume of 40,000 MCFD. The (actual) inlet gas volume at the Plant will be somewhat variable and is continuously metered. The Plant records daily inlet gas volumes and prepares a daily volume report. The assumed 40,000 MCFD inlet gas volume has been selected as the "escape rate" because it is the highest anticipated inlet volume that the Plant would handle under its proposed operations and is considered worst case interpretation of the volume of gas.

It should be noted that the plan will remain effective as long as the processed volume and H₂S content equate to the same or smaller ROE.

Previous monitoring data indicated variable inlet concentrations of hydrogen sulfide, but concentration will not exceed 7,600 ppm or .76 mole percent. Therefore, 7,600 ppm or .76 mole percent has been used in the worst case scenario operations for contingency planning purposes.

Using:

$$Q = 40,000,000$$

$$\text{H}_2\text{S conc} = 7,600 \text{ ppm or } .76 \text{ mole\%}$$

500-ppm RADIUS OF EXPOSURE CALCULATION

$$X = [(0.4546) * (\text{H}_2\text{S concentration}) * (\text{gas volume (Q)})]^{0.6258}$$

$$X = [(0.4546) * (7,600 * .000001) * (40,000,000)]^{0.6258}$$

$$\underline{X = 1648 \text{ feet} = 500\text{-ppm ROE}}$$

100-ppm RADIUS OF EXPOSURE CALCULATION

$$X = [(1.589) * (\text{H}_2\text{S concentration}) * (\text{gas volume})]^{0.6258}$$

$$X = [(1.589) * (7,600 * .000001) * (40,000,000)]^{0.6258}$$

$$\underline{X = 3606 \text{ feet} = 100\text{-ppm ROE}}$$

ROE Along the Pipeline and At the Injection Well

The escape rate (Q) is the best estimate of the maximum daily flow rate of the acid gas. For releases inside the Agave Dagger Draw Gas Plant, the Company is using for contingency planning purposes an "escape rate" equal to the 500 MCFD. The assumed 500 MCFD acid gas volume has been selected as the "escape rate" because it is the highest anticipated gas volume that the Plant would handle under its proposed operations and is considered the worst case interpretation of the volume of gas.

It should be noted that the plan will remain effective as long as the processed volume and H₂S content equate to the same or smaller ROE.

Previous monitoring data indicated variable inlet concentrations of hydrogen sulfide, but concentration will not exceed 608,000 ppm or 60.8 mole% at the inlet. Therefore, 608,000 ppm or 60.8 mole percent has been used in the worst case scenario operations for contingency planning purposes. Again, Agave does not measure the H₂S concentration in the acid gas stream; rather the concentration is calculated based on the inlet conditions.

Using:

Q = 500,000

H₂S conc = 608,000 ppm or 60.8 mole%

500-ppm RADIUS OF EXPOSURE CALCULATION

$$X = [(0.4546) * (\text{H}_2\text{S concentration}) * (\text{gas volume (Q)})]^{0.6258}$$

$$X = [(0.4546) * (608,000 * .000001) * (500,000)]^{0.6258}$$


X = 1648 feet = 500-ppm ROE

100-ppm RADIUS OF EXPOSURE CALCULATION

$$X = [(1.589) * (\text{H}_2\text{S concentration}) * (\text{gas volume})]^{0.6258}$$

$$X = [(1.589) * (608,000 * .000001) * (500,000)]^{0.6258}$$

X = 3606 feet = 100-ppm ROE



- 1648 Ft (500 ppm)
- 3606 Ft (100 ppm)
- AMINE STILL
- METROPOLIS WELL HEAD
- ACID GAS PIPELINE



AGAVE ENERGY COMPANY			
105 South Fourth Street, Artesia New Mexico 88210			
AGAVE DAGGER GAS DRAW PLANT			
HYDROGEN SULFIDE CONTINGENCY PLAN			
AMINE STILL RADIUS OF EXPOSURE			
DRAFTING: TWH	PRINTED: 11/29/10	SIZE: ANSI B	REV: 0
CHK: JK	DATE: 11/29/10	SCALE: 1"=2000'	
APPROVED: JK	DATE: 11/29/10	SHEET: 1	of 1

MAP C-1

APPENDIX D – Muster Areas, Evacuation Routes

Map D-1: Evacuation Routes to Muster Areas

Map D-2: Atoka Facility– Safety Trailer Location




— MUSTER AREA



AGAVE ENERGY COMPANY
 105 South Fourth Street, Artesia New Mexico 88210
 AGAVE DAGGER GAS DRAW PLANT
 HYDROGEN SULFIDE CONTINGENCY PLAN
 EVACUATION ROUTES

DRAFTING: twh	PRINTED: 11/29/10	SIZE: ANS B	REV
CHK: JK	DATE: 11/29/10	SCALE: 1"=2000'	0
APPROVED: JK	DATE: 11/29/10	SHEET: 1 of 1	

MAP D-1



MAP D-2



AGAVE ENERGY COMPANY
 105 South Fourth Street, Artesia New Mexico 88210
AGAVE DAGGER GAS DRAW PLANT
HYDROGEN SULFIDE CONTINGENCY PLAN
EMERGENCY TRAILER LOCATION

DRAFTING: TWB	PRINTED: 11/29/10	SCALE: ANS B	REV
CHK: JK	DATE: 11/29/10	SCALE: NA	0
APPROVED: JK	DATE: 11/29/10	SHEET: 1 of 1	

APPENDIX E – H₂S Contingency Plan Distribution List

APPENDIX E – H₂S Contingency Plan Distribution List

New Mexico Oil Conservation Division

1301 West Grand Avenue
Artesia, NM 88210-1729

New Mexico Department of Public Safety

4207 W 2nd Street
Roswell, NM 88201-8857

Local Emergency Planning Committee

324 S Canyon Street, Suite B
Carlsbad, NM 88210

Artesia Fire Department

309 North 7th Street
Artesia, NM 88210-1913

Atoka Fire Department

2611 South 13th Street
Artesia, NM 88210-9333

Eddy County Sheriff's Department

Eddy County Courthouse
102 N. Canal
Carlsbad, NM 88220

Dagger Draw Plant


278 Pipeline Road
Artesia, NM 88210

Agave Main Office

105 South 4th Street
Artesia, NM 88210

H2S Contingency Plan

Agave Dagger Draw Processing Plant
and the
Metropolis Disposal Well



Agave Energy Company

105 South 4th Street
Artesia, NM 88210
(575-748-4555)

April 5, 2010

TABLE OF CONTENTS

	Page
I. Introduction	
[API RP-55 7.1].....	1
II. Scope	
[API RP-55 7.2].....	1
III. Plan Availability	
[API RP-55 7.3].....	1
IV. Emergency Procedures	
[NMAC 19.15.11.9.B(2)(a)][API RP-55 7.4 a.].....	1
A. Responsibilities and Duties of Personnel During an Emergency	
B. Immediate Action Plan	
C. Telephone Numbers and Communication Methods	
D. Location of Residents, Roads, and Medical Facilities	
E. Evacuation Routes, Muster Areas, and Road Block Locations	
F. Monitoring Equipment, Alarm Systems, Safety Equipment, and Supplies Available	
V. Characteristics of Hydrogen Sulfide (H₂S) and Sulfur Dioxide (SO₂)	
[NMAC 19.15.11.9.B(2)(b)][API RP-55 7.4 b.].....	10
A. Characteristics of Hydrogen Sulfide (H ₂ S), Sulfur Dioxide (SO ₂)	
B. Radii of Exposure (ROE)	
VI. Facility Description, Maps, and Drawings	
[NMAC [19.15.11.9.B(2)(c)][API RP-55 7.4 c.].....	13
A. Dagger Draw Processing Plant	
B. Metropolis Disposal Well	
C. Map of Plant and Well	
VII. Training and Drills	
[NMAC 19.15.11.9.B(2)(d)][API RP-55 7.4 d.].....	14
A. Responsibilities and Duties of Essential Personnel	
B. On-site or Classroom Drills	
C. Notification and Training of Residents on Protective Measures in Emergency Situations	
D. Training and Attendance Documentation	
E. Briefing of Public Officials on Evacuation and Shelter in Place Plans	
VIII. Coordination with State Emergency Plans	
[NMAC 19.15.11.9.B(2)(e)].....	15
A. Oil Conservation Division	
B. New Mexico State Police	
IX. Plan Activation	
[NMAC 19.15.11.9.C][API RP-55 7.4 d.].....	15
A. Activation Levels	
B. Events that Could Lead to a Release	

X. Submission of H₂S Contingency Plans

[NMAC 19.15.11.9.D].....16

- A. Submission
- B. Retention
- C. Inventory

APPENDICES

Appendix A – Facility Maps and Drawings

- Map A-1: Facility Map**
- Map A-2: Alarms and Monitors, Dagger Draw Active Equipment**
- Map A-3: Safety and Fire Equipment, Dagger Draw Active Equipment**
- Map A-4: Evacuation Router, Dagger Draw Active Equipment**
- Map A-5: Proposed Perimeter Alarms**
- Map A-6: Metropolis Disposal Well**

Appendix B – Response Flow Diagram


Appendix C – ROE Calculations

- Map C-1: Amine Still ROE**
- Map C-2: Wellsite ROE**

Appendix D – Muster Areas and Evacuation Routes

- Map D-1: Evacuation Routes to Muster Areas**

Appendix E – Distribution List



OPERATOR QUICK REFERENCE GUIDE

Dagger Draw Processing Plant Level 1 Response FOR PLANT OR WELLHEAD ALARMS

H2S Detected Greater than 10 ppm H2S
Intermittent Audible Alarm and flashing
amber lights

- Evacuate to Emergency Assembly Area
- Evacuate visitors from plant to designated Muster Area
- Notify Agave Management
- Assign operators to suit up in SCBA
- Check Computer for location of H2S alarm
- Notify all entities in the 500 ppm ROE when perimeter monitors reach 10 ppm H2S
- Wearing SCBA - attempt to locate and repair leak
- Rotate Operators in 15 minute shifts
- If H2S levels exceed 10 ppm H2S in emergency muster area relocate to alternate muster area

If H2S levels exceed 20 ppm H2S proceed
to Level II response

**CALL 911 for
death or injury
for emergency
assistance**

Once resolved and
monitored levels in
plant are less than
10 ppm H2S -
return to plant and
continue to monitor

Location of Facilities

Agave Dagger Draw Processing Plant

Go south of Artesia, NM on Hwy 285 approximately 9 miles to County Road 38 (Kincaid Ranch Road). Turn right (west) on Kincaid Ranch Road and go approximately 2.8 miles to Pipeline Road. Turn right (north) and go 0.2 miles to the Dagger Draw Gas Plant Office. Physical address is 278 Pipeline Road.

Section 25-Township 18S-Range 25E


Metropolis Acid Gas Disposal Well

Go south of Artesia, NM on Hwy 285 approximately 9 miles to County Road 38 (Kincaid Ranch Road). Turn right (west) on Kincaid Ranch Road and go 2.6 miles (just past the Agave Field Office). Turn left (south) on dirt lease road and go approximately 0.6 miles then turn left (east) and go 0.2 mile to the Metropolis Disposal Well. **Section 36-Township 18S-Range 25E**

Emergency Trailer – Menefee Location

From intersection of Main Street and 13th Street in Artesia, go south on South 13th Street for approximately 2.3 miles. Turn west and go approximately 0.1 miles to location.

DRAFT



AGAVE ENERGY COMPANY
 105 South Fourth Street, Artesia New Mexico 88210

**AGAVE DAGGER GAS DRAW PLANT
 HYDROGEN SULFIDE CONTINGENCY PLAN
 FACILITIES LOCATIONS**

DRAFTING: TWH	PRINTED: 4/09/10	SIZE: ANSI B	REV
CHK: JK	DATE: 4/09/10	SCALE: NA	0
APPROVED: JK	DATE: 4/09/10	SHEET 1 of 1	

I. Introduction

[API RP-55 7.1]

The Agave Dagger Draw Processing Plant is a natural gas processing plant which handles and/or generates hydrogen sulfide (H₂S) and/or sulfur dioxide (SO₂). This H₂S contingency plan was created to outline procedures that are to be followed in the event of an H₂S release that occurs at the plant, the acid gas well, or on the acid gas pipeline. The response plan is the same regardless of where the release takes place. This plan complies with the New Mexico Oil Conservation Division (OCD) Rule 11. This plan also conforms to API RP-55.

II. Scope

[API RP-55 7.2]

This contingency plan is specific to the Agave Dagger Draw Gas Processing Plant and acid gas injection system. This plan contains procedures to provide an organized response to an unplanned release from the plant or well site.

III. Plan Availability

[API RP-55 7.3]

This contingency plan shall be available to all personnel responsible for implementing any portion of the plan. Copies of the plan will be distributed to the following agencies: New Mexico Oil Conservation Division (OCD), New Mexico Department of Public Safety, Local Emergency Planning Committee (LEPC), Artesia Fire Department, Atoka Fire Department, Artesia Police Department, and Eddy County Sheriff's Department. The Plan will be available at the following Agave Energy Company locations: Dagger Draw Processing Plant, the Artesia Field Office, and the Agave Main Office in Artesia.

IV. Emergency Procedures

[NMAC 19.15.11.9.B(2)(a)] [API RP-55 7.4 a]

A. Responsibilities and Duties of Personnel during an Emergency

1. Plant Manager or designee will serve as the Incident Commander (IC); is responsible for training operators assigned to the plant, contractors and visitors on the implementation of this plan; and will maintain communication with Agave management and residents within the radius of exposure (ROE).
2. Plant Supervisor or designee will serve as the Incident Commander (IC) in the absence of the Plant Manager; is responsible for training and supervising plant operators on the implementation of this plan, will maintain accountability of all contractors and visitors; and will maintain communication with the plant manager and Agave management.
3. Plant Operators will perform operations in accordance with this plan safely; assist in the accountability and evacuation of visitors and contractors to designated muster areas; and keep the plant supervisor and manager informed on the repair progress.
4. Essential Agave Personnel will be familiar with the procedures in this plan and assist plant operators in assisting with the implementation of this plan in a safe manner.
5. Visitors and contractors on site will be familiar with safety alarms and signals at the Dagger Draw Gas Processing Plant and the acid gas injection system; and adhere to instructions of Plant Operators and other Agave personnel in evacuation of the facilities.

B. Immediate Action Plan

1. The following outlines the immediate action Plan that is illustrated by the response flow diagram in Appendix B. This is to be used when responding to an H2S release. Response levels are the same for a release at the plant or the acid gas well. Additional or long term response actions will be determined on a case-by-case basis, if needed, once the Incident Command Center and System is established following the immediate response.

Level	Alarms	Actions
I	Intermittent audible alarm sounded and/or flashing yellow lights activated for H2S at 10 ppm or greater.	<p>1. The audible signal for a Plant emergency and evacuation is an intermittent alarm and yellow lights (repeating off/on) activated when levels of H2S of 10 ppm or greater are detected. In addition, a flashing yellow light or beacon will be activated at 10 ppm or greater of H2S. A computer in the control room and in the Plant Supervisor office establishes which H2S monitor has activated the alarm and/or flashing yellow beacon, be it a plant monitor or well monitor. At the initial sound of the intermittent alarm or the flashing yellow beacon, assigned operators will put on a 30 minute self contained breathing apparatus (SCBA) and all other personnel in the Plant complex or well site shall immediately evacuate the Plant or well site to the Emergency Assembly Area. If H2S concentrations are 10 ppm or greater, then personnel will evacuate to a designated Muster Area determined by the Incident Commander (IC) (see Appendix D). The operators, upon suit up with the self contained breathing apparatus (SCBA), will first help any persons in distress evacuate to the Emergency Assembly Area. If deemed necessary by the Plant Manager or Plant Supervisor, local emergency response service providers will be contacted by Plant personnel designated by the Plant Manager or Supervisor.</p> <p>2. All entities within the 500 ppm radius of impact (ROE) will be notified (by telephone) of a release if the <u>perimeter alarms</u> are activated at 10 ppm H2S or greater. Notification will be done by personnel designated by the Plant Manager or his designee. The nature of the release and status of containment will be conveyed. Businesses will be advised to report the incident to employees working near the Plant and to alert any third party contractors or service companies working in the Plant vicinity or imminently scheduled to work in the vicinity of the release. All should be instructed to leave the area and not to enter/re-enter area until further notice. Operators will put on self contained breathing apparatus (SCBA).</p> <p>3. Wearing the self-contained breathing apparatus (SCBA), the operator(s) will attempt to fix the cause of the release. The H2S levels at the Emergency Assembly Area will be monitored with a hand held or personal monitor and with the fixed monitor.</p> <p>4. The Incident Commander (IC) will set up secondary re-entry team(s) with 30 minutes self contained breathing apparatus (SCBA) to re-enter and resolve the situation. Re-entry will occur in 15 minute shifts at the direction of the Incident Commander (IC) until the problem is resolved or the emergency shut down (ESD) is activated. If H2S levels in the Emergency Assembly Areas exceed 10 ppm H2S, evacuate to alternate Emergency Assembly Area and continue to monitor Emergency Assembly Area with personal or handheld H2S monitors. If evacuation to Muster Area occurs, road blocks will be established near the Muster Areas on Kincaid and Pipeline Road. If release is resolved and monitored levels in the Plant are less than 10 ppm H2S, personnel may re-enter the Plant. The Oil Conservation Division (OCD) shall be notified within four hours of any release that activates the Plan. If the release is not resolved and H2S levels continue to increase, Level 2 Response is indicated.</p>

Levels	Alarms	Actions
II	Intermittent audible alarm sounded and/or flashing red lights activated for H2S greater than 20 ppm	<p>1. The intermittent alarm and red flashing lights indicate the detection of H2S greater than or equal to 20 ppm. (Flashing yellow lights indicate a H2S release of 10 ppm or greater and they will change to red for a release of 20 ppm or greater.) A control panel in the Plant supervisor's office establishes which H2S monitor has activated the alarm and or flashing red beacon, be it a plant monitor or a well monitor. At the initial sound of the intermittent alarm or observance of the flashing red beacons, the operators will exit to the Muster Area designated by the Plant Manager or his designee. Other personnel in the Plant complex will put on emergency escape packs located throughout the plant, or well location and evacuate along with the operators using the evacuation routes to the Emergency Assembly Area and then to the Muster Area (see Appendix D) designated by the Plant Manager or designee. At the assembly area, the Plant Manager or designee will assign operators to put on a 30 minute self contained breathing apparatus (SCBA). Local emergency response service providers will be contacted by Plant Manager or designee.</p> <p>2. All other entities within the 100 ppm and 500 ppm radius of impact (ROE) will be contacted by phone and notified of release and asked to evacuate when a <u>perimeter monitor</u> reads 10 ppm H2S or greater. All entities within the 100 ppm radius of impact (ROE) will be contacted by phone and notified of release. The nature of the release and status of containment will be conveyed. Depending on release status and prevailing wind conditions, some entities within the 100 ppm radius of impact (ROE) may be asked to shelter in place or evacuate. Notifications will include but are not limited to the following:</p> <ul style="list-style-type: none"> a) Other entities within the 100 ppm radius of impact (ROE), depending on release status and prevailing wind conditions, will be asked to shelter in place. Those entities will be instructed to close any windows and shut off any air conditioning/heating until further notice. In addition, they will be instructed to contact other employees/residents not currently present to not enter/reenter the area until further instruction. b) If a <u>perimeter monitor</u> is activated, the LEPC and law enforcement will be contacted by phone and notified of the release and status of containment. The Incident Commander (IC) will assign personnel notification responsibility. <p>3. Operator(s) with 30 minute self contained breathing apparatus (SCBA) will assess the release and attempt to resolve it. If after 45 minutes on scene there is no resolution, the operator(s) will notify the Plant Manager to determine if the emergency shut down (ESD) should be activated.</p> <p>4. If monitored H2S levels at Muster Area exceed 10 ppm, evacuate to an alternate Muster Area. If deemed necessary, local emergency response service providers will be contacted by the Incident Commander (IC).</p> <ul style="list-style-type: none"> a) Re-entry will occur in full self contained breathing apparatus (SCBA) and in 15 minute shifts at the direction of the IC until IC determines problem has been resolved or emergency shut downs (ESDs) are activated. b) If release is resolved and monitored levels of H2S in the Plant are less than 10 ppm, personnel may return to Plant. The Oil Conservation Division (OCD) shall be notified within four hours of any release that activates the Plan. All entities previously notified will be informed that the release has been resolved and advised of the current monitored H2S levels at the Plant. c) No resolution requires activation of full H2S Plan with notifications and reporting as per Plan. If the release is not resolved and/or H2S levels continue to increase, Level 3 Response is indicated. d) Monitoring will continue after problems are abated, at the direction of the Plant Manager.

Level	Alarms	Actions
<p data-bbox="175 265 203 292">III</p>	<p data-bbox="261 265 423 561">Intermittent audible alarm sounded and/or flashing red lights activated for catastrophic release; fire; or explosion</p> <p data-bbox="261 596 423 768">ESD alarm is a continuous siren with red, amber, and blue lights that flash</p>	<ol style="list-style-type: none"> <li data-bbox="467 265 1474 348">1. For H2S at 20 ppm or greater and repair efforts at Level 2 unsuccessful, worst case scenario, and/or catastrophic release have occurred then implement a Level 3 response. <li data-bbox="467 354 1474 410">2. Road blocks will be set up near the Muster Areas on Kincaid Road and Pipeline Road. <li data-bbox="467 416 1474 588">3. All personnel shall have evacuated to a designated Muster Areas. Evacuation of all entities within the 500 ppm radius of impact (ROE) will have been confirmed. Implement full H2S Plan with all notifications and public agency involvement. Notifications to all entities within the 100 ppm radius of impact (ROE) will include the nature of the release and status of containment. Notifications will include but are not limited to the following: <ol style="list-style-type: none"> <li data-bbox="500 594 1474 768">a) All businesses within the 100 ppm radius of impact (ROE) will be instructed to immediately alert all company personnel, third party contractors and/or services companies working in the area and those imminently scheduled to work in the area, of the release and evacuation status of the Plant. They will be instructed to immediately leave and/or not enter/reenter the area within the roadblocks until further instruction. <li data-bbox="500 774 1474 982">b) All other entities (including private residents) within the 100 ppm radius of impact (ROE) will be instructed to immediately shelter in place, if appropriate based on the source of the release and the wind direction. Those entities will be instructed to close any windows and shut off any air conditioning/heating until further notice. In addition, they will be instructed to contact other employees/residents not currently present to not enter/reenter the area until further instruction. <li data-bbox="500 988 1474 1071">c) The Incident Commander (IC) will make a summary judgment, based on but not limited to H2S concentration and wind direction, whether a safe evacuation can be implemented, and recommend an evacuation route. <li data-bbox="467 1077 1474 1133">4. If escaping vapors have ignited, the vapors should be allowed to continue to burn unless the fire endangers personnel, other property, or other equipment. <li data-bbox="467 1139 1474 1222">5. When applicable, maintain communication with the Plant Manager, or his designee, to keep him up-to-date of the situation and the action taken prior to his arrival at the location. <li data-bbox="467 1228 1187 1255">6. Initiate and maintain a Chronological Record of Events log. <li data-bbox="467 1261 1474 1317">7. Within one hour after the activation of the H2S Plan, begin agency notifications by calling Oil Conservation Division (OCD) and National Response Center (NRC). <li data-bbox="467 1324 1446 1350">8. Establish media staging area adjacent to Muster Area 2 and direct all media to it. <li data-bbox="467 1357 1474 1460">9. Once resolved and monitored levels in the Plant and at Muster Area are less than 10 ppm, roadblocks will be removed, and all entities within the 100 ppm radius of impact (ROE) will be allowed to return. All entities previously notified will be informed that the release has been resolved and advised of the current monitored H2S levels. <li data-bbox="467 1466 1474 1522">10. Monitoring will continue after problems are abated, at the direction of the Plant Manager <li data-bbox="467 1529 1024 1556">11. Agency reports to be submitted as required.

C. Telephone Numbers and Communication Methods

1. Emergency Services

AGENCY	TELEPHONE #
Artesia Fire Department	(575) 946-5050
Atoka Fire Department	(575) 946-5050
Artesia Police Department	(575) 746-5000
Eddy County Sheriff	(575) 887-7551
Carlsbad Police Department	(575) 885-2111
State Police (HMER)	
District 3 Roswell	(575) 827-9312
Sub District 3 Carlsbad	(575) 885-3138
Sub District 3 Hobbs	(575) 827-9320
Ambulance Services	
Artesia	(575) 746-5050
Carlsbad	(575) 885-2111
Hospitals	
Artesia General	(575) 748-3333
Carlsbad Medical Center	(575) 887-4100
Veterinarians	
Artesia Animal Clinic	(575) 748-2042
Livingston Animal Clinic	(575) 746-6167
Helicopter Services	
Lifeguard(Albuquerque)	1-800-633-5438
Southwest Medivac(Hobbs)	1-800-242-6199
AeroCare(Lubbock)	1-800-627-2376
Air Med(El Paso)	(915) 772-1449

2. Government Agencies

AGENCY	TELEPHONE #
Oil Conservation Division (OCD)	(505) 476-3440
	(575) 748-1283
US BLM	(575) 887-6544
Local Emergency Planning Committee (LEPC)	(575) 887-9511
National Response Center (NRC)	1-800-424-8802

3. Operators and Contractors

COMPANY	TELEPHONE #
CVE	(575) 746-3571
PVT	(575) 748-1241
DCP Midstream	(800) 435-1679
Chevron/West Texas Pipeline Company	(800) 762-3404
Transwestern Pipeline	(281) 714-2265
Yates Petroleum Corporation	(575) 748-1471

4. Public

Name	Address	TELEPHONE #
David and Diana Wilson	80 West Kincaid Ranch Road	(575) 457-2309
Raul and Delilah Baeza	193 West Kincaid Ranch Road	(575) 308-3195
Efrin and Maria Baeza	179 West Kincaid Ranch Road	(575) 513-0471
Christine Baeza	175 West Kincaid Ranch Road	(575) 457-2585

5. Agave Internal Call List

NAME	TITLE	Office #	Cell #
J.B. Smith	President	(575)748-4414	(575)365-8517
Rusty Nasta	Operations Manager	(575)748-4523	(575)626-7971
Ivan Villa	Engineering Supervisor	(575)748-4528	(575)365-4888
Jennifer Knowlton	Environmental Engineer	(575)748-4528	(505)238-3588
Robert Moorhead	Plant Manager/South Mechanical Supervisor	(575)748-6815	(575)365-4840
Gary Greenwood	Plant Supervisor	(575)748-8414	(575)365-6794
Mark Smith	PSM Coordinator/Plant Operator	(575)748-8410	(575)365-5053
Dustin McNeely	Plant Operator	N/A	(575)703-5493
Justin Troublefield	Plant Operator	N/A	(575)365-7503
Glen Blake	Regulatory Coordinator	(575)748-4546	(575)626-8168
Bill Johnson	South Measurement Supervisor	(575)748-6816	(575)365-4615
Jason Fuentes	South Pipeline Supervisor	(575)748-4518	(575)365-8939

6. Agave Energy Company will use 2-way radios and telephones to communicate internally. Telephone will be used for external communication.

D. Location of Nearby Residences, Roads, and Medical Facilities

1. The following residences are located within the ROE of the:
 - a) Plant — None
 - b) Metropolis Acid Gas Well – None
2. The following roads are located within the ROE:
 - a) Kincaid Ranch Road
 - b) Pipeline Road
3. There are no medical facilities located within the ROE.

E. Evacuation Routes, Emergency Assembly Area, Muster Areas, and Road Block Locations

1. Evacuation Routes, Emergency Assembly Area, and Muster Areas are depicted on Map D-1 in Appendix D.
2. Pre-planned road block locations designated near the muster areas on Pipeline Road and Kincaid Ranch Road and are depicted on Map D-1 in Appendix D. Each location will have pre-positioned, portable road barriers with lights. The locations will have flashing lights and warning signs.
3. Emergency lights on the Muster Area signs will be activated by any perimeter alarm of 10 ppm or greater H₂S or Level III activation.

F. Monitoring Equipment, Alarm Systems, Safety Equipment, and Supplies Available

1. **EMERGENCY SHUTDOWN SYSTEM:** There are (8) ESD manual stations located at various points in the facility. See Maps A-2 and A-3 in Appendix A. The Plant ESD can be activated at any time by any employee or at the direction of the Incident Commander (IC).

When any one of the eight (8) manual stations is activated, the system will be shutdown and the natural gas inlets and outlets will be blocked. The operators are also able to auto close the one (1) main block valve on the incoming gas line to the Plant. Activating these should allow the plant to avoid a Level 3 response. The Incident Commander (IC) can send trained personnel to designated off-site manual block valves. There are also various methods to shut down gas flow at the various wellheads and incoming gathering lines. These can and would be evaluated on a case by case basis.

Designated employees will have remote access to the plant controls including ESD capabilities.

2. **PLANT ALARMS, VISIBLE BEACONS & WIND INDICATORS:** Colored beacons, horns, and wind directions indicators are located in various locations throughout the Plant and are indicated in Appendix A on Maps A-2, A-3, and A-6.

The audible signal for an emergency response and Plant evacuation is a repeating intermittent alarm that sounds at H₂S concentrations of 10 ppm or greater. The alarm will remain intermittent when the concentration of the H₂S release is 20 ppm or higher. At the initial sound of this intermittent alarm, the plant operators will evacuate to the emergency assembly area put on a self contained breathing apparatus (SCBA) and all personnel in the plant complex shall immediately proceed in a safe manner to the Emergency Assembly Areas as prescribed by the Emergency Action Plan.

A flashing red beacon signifies an H₂S release of 20 ppm or higher and all personnel in the plant complex shall immediately proceed in a safe manner to the Emergency Assembly Area located outside of the plant office. If this area is not determined to be safe, all will move to designated Muster Area. Evacuation routes and Muster Areas are indicated on the map in Appendix A, on Map A-4 and A-6 as well as Appendix D, on Map D-1.

A routine process alarm will cause a horn to sound. This horn sound is used to alert the plant Operator to return to the Control Room. No emergency response or evacuation is required when this horn sounds.

Wind direction indicators are installed throughout the plant. At least one wind direction indicator can be seen at any location within the Plant complex, as well as, from any point on the perimeter of the plant. There are ten (10) windsocks located in the Plant.

3. **GAS DETECTION EQUIPMENT:** The Plant uses a Smart Sensor System fixed plant H₂S Sensors. These sensors are a fixed point monitoring system used to detect the presence of hydrogen sulfide in ambient air. The yellow flashing beacon is activated at H₂S concentrations of 10 ppm or greater. The horn is activated with an intermittent alarm at H₂S concentrations of 10 ppm or greater. The lights change to red at 20 ppm H₂S and the horn remains intermittent. The fixed hydrogen sulfide monitors are strategically located throughout the Plant to detect an uncontrolled released of hydrogen

sulfide. The Plant operators are able to monitor the H₂S level of all the Plant sensors on the control monitor located in the control room and the Dagger Draw Plant Field Office. In addition, select employees can access this information remotely. These sensors are located on the plot plan in Appendix A Maps A-2 and A-3. These sensors all have to be acknowledged and will not clear themselves. This requires immediate action for any occurrence or malfunction. The Plant sensors are calibrated monthly.

Redline wireless H₂S detectors are installed along the perimeter of the plant and the perimeter of the acid gas disposal well. Perimeter H₂S detectors report to the Redline monitor every five minutes to confirm detector functionality. Once H₂S gas is detected, the H₂S detectors report to the monitor every five seconds. The detectors will go into alarm at H₂S values of 10 ppm and above. Redline H₂S head unit locations are depicted on Map A-5 and A-6 Appendix A.

Hand held gas detection monitors are available to plant personnel to check specific areas and equipment prior to initiating maintenance or work on the process equipment. There are 3 handheld monitors and each individual is assigned a personal H₂S monitor. The hand held gas detection devices are Industrial Scientific ITX 3-gas detectors and BW Gas Alert Micro 5 4- way monitors. The detectors have sensors for oxygen, LEL (explosive hydrocarbon atmospheres), hydrogen sulfide, and carbon dioxide. They indicate the presence H₂S with a beeping sound at 10 ppm. The beeps change in tone as H₂S increases to 20 ppm. The personal monitors are set to alarm (beep) at 10 ppm with the beeps becoming closer together as the H₂S concentration increases to 20 ppm. Both the hand held and personal monitors have digital readouts of H₂S ppm concentration.

a) The compressor building has two methane sensors; one sends a call out at 30% lower explosive limit (LEL); the second shuts the compressors down at 50% lower explosive limit (LEL). The methane sensors are visual and audible alarms. The compressor building also is equipped with fire eyes that will also shut the units down. The four product pumps also have LEL sensors.

4. RESPIRATORS: The Plant has 30 minute self contained breathing apparatus (SCBA) respirators and 5 minute escape packs strategically located throughout the Plant. The respirator locations are identified in Appendix A on Maps A-3 and A-6. All Plant personnel are certified to use the self contained breathing apparatus (SCBA) respirators.

5. FIRE FIGHTING EQUIPMENT: The Plant personnel are trained only for insipient stage fire fighting. The fire extinguishers located in the Plant process areas, compressor buildings, process buildings, and company vehicles are typically a 20# ABC dry chemical fire extinguisher. See Appendix A Maps A-3 and A-6 for locations. The Plant does not have a fire water system, only a utility water system that is not designed for fire fighting.

6. EMERGENCY RESPONSE TRAILER AND EQUIPMENT: Agave Energy Company has an Emergency Response Trailer located at the Menefee location. This is located outside all radii of exposure (ROE).

Driving Directions: From intersection of Main Street and 13th Street in Artesia, go south on South 13th Street for approximately 2.3 miles. Turn west and go approximately 0.1

miles to location. See Map D-2 in Appendix D. The trailer can serve as a mobile resource center or Incident Command Center.

a) EMERGENCY RESPONSE TRAILER CONTENTS

- 2 wind socks / wind direction indicators w/poles & spares
- 1 – 110 volt generator, portable w/wheels
- 4 5-gas sensor ambient monitors (O₂, SO₂, LEL, CO, H₂S) with automatic air pumps (15 sec per foot) and data logging capability
- 1 calibration unit for monitors
- 5 intrinsically safe communication radios & chargers, 32 channel with capability to be programmed to fire service and police channels
- 4 20# stored pressure, ABC class Fire Extinguishers
- 4 4500 Grade D breathing air cylinders, regulator, low pressure alarm, and hose reel w/ 300 ft hose (total) and correct quick disconnects.
- 1 stretcher
- 1 20-person First Aid Kit with burn gel packets
- 4 30-minute SCBA's
- 4 work unit SCBA's
- 2 lights, mounted on each rear of trailer for night operations
- 2 hand cleaner for decontamination of petroleum products.
- 3 traffic Control Kits
- 1 emergency flare gun for lighting uncontrollable hazardous gases
- 2 full body harness and 150' X 2' lifelines
- 2 "Hazardous Area" "Do Not Enter" signs / barricades
- 2 burn gel blankets
- 1 set of maps and Emergency Response Plans
- 4 temporary use Nomex Fire retardant clothing (2-LG & 2-XLG)

7. TRAFFIC CONTROL KIT CONTENTS

- 3 electronic road flares
- 1 28" stop sign paddle
- 4 reflective traffic control vests
- 2 emergency signal wands
- 1 emergency Response Guidebook

8. FIRST AID EQUIPMENT LOCATIONS:

a) First Aid Kits are located at the following locations:

- Lab
- Office

b) Eye Wash stations are located at the following locations:

- Lab
- Office

9. PERSONAL H₂S MONITORS: All Agave personnel assigned to the Plant and associated field personnel are issued personal H₂S monitors.

10. SIGNS and MARKERS: The Plant has warning signs indicating the presence of "H₂S/Poisonous Gas" and high pressure gas at the entrance to the Plant. Emergency

response phone numbers are posted at the entrance to the Plant. Signs are located at the Plant gate entrance indicating that all visitors are to sign in.

V. Characteristics of Hydrogen Sulfide (H₂S) and Sulfur Dioxide(SO₂)

[NMAC 19.15.11.9.B(2)(b)] [API RP-55 7.4 b.]

A. Characteristics of Hydrogen Sulfide (H₂S), Sulfur Dioxide (SO₂)

1. Hydrogen Sulfide (H₂S): The proposed inlet gas streams into the Plant will contain a maximum of 10,000 ppm (or 1.0 mole percent) of hydrogen sulfide based on data generated from the sampling of the inlet gas at least daily. Hydrogen sulfide is a colorless, toxic and flammable gas, and has the odor of rotten eggs. Hydrogen sulfide gas is heavier than air. Hydrogen sulfide presents a significant health hazard by paralyzing the respiratory system resulting in serious injury or death.

Hydrogen Sulfide Properties and Characteristics		
CAS No.	7783-06-4	
Molecular Formula	H ₂ S	
Molecular Weight	34.082	
Ceiling Concentration	20 ppm (OSHA)	
Ceiling Peak Concentration	50 ppm (OSHA)	
TLV	15 ppm (ACGIH)	
TWA	10 ppm (NIOSH)	
STEL	15 ppm (ACGIH)	
IDLH	100 ppm	
Specific Gravity(air=1.0)	1.189	
Boiling Point	-76.5F	
Freezing Point	-121.8F	
Vapor Pressure	396 psia	
Autoignition Temperature	518F	
Lower Flammability Limit	4.3%	
Upper Flammability Limit	46.0%	
Stability	Stable	
pH in water	3	
Corrosivity	Reacts with metals, plastics, tissues and nerves	
Physical Effects of Hydrogen Sulfide		
Concentration		
ppm	%	Physical Effects
1	0.0010	Can be smelled (rotten egg odor)
10	0.0010	Obvious & unpleasant odor; Permissible exposure level; safe for 8 hour exposure
20	0.0020	Acceptable ceiling concentration
50	0.0050	Loss of sense of smell in 15 minutes
100	0.0100	Immediately dangerous to life and health(IDLH) loss of sense of smell in 3-15 minutes; stinging in eyes & throat; Altered breathing
200	0.0200	Kills smell rapidly; stinging in eyes & throat
500	0.0500	Dizziness; Unconscious after short exposure; Need artificial respiration
700	0.0700	Unconscious quickly; death will result if not rescued promptly
1000	0.1000	Instant unconsciousness; followed by death within minutes

2. Sulfur Dioxide (SO₂): Sulfur dioxide is produced as a by-product of H₂S combustion at the flare. The flare unit receives the residual hydrogen sulfide and carbon dioxide stream that is routed from the amine unit. It is colorless, transparent, and is non-flammable, with a pungent odor associated with burning sulfur. Sulfur dioxide is heavier than air, but will be picked up by a breeze and carried downwind at elevated temperatures. Sulfur dioxide can be extremely irritating to the eyes and mucous membranes of the upper respiratory tract.

Sulfur Dioxide Properties & Characteristics	
CAS No.	7446-09-5
Molecular Formula	SO ₂
Molecular Weight	64.07
PEL	5 ppm(OSHA)
TWA	2 ppm(ACGIH)
STEL	5 ppm(ACGIH)
IDLH	100 ppm
Specific Gravity (air = 1.0)	2.26
Boiling Point	14°F
Freezing Point	-103.9°F
Vapor Pressure	49.1 psia
Auto ignition Temperature	N/A
Lower Flammability Limit	N/A
Upper Flammability Limit	N/A
Stability	Stable
Corrosivity	Could form an acid rain in aqueous solutions
Physical Effects of Sulfur Dioxide	
Concentration	Effect
1 ppm	Pungent odor, may cause respiratory changes
2 ppm	Permissible exposure limit; Safe for an 8 hour exposure
3-5 ppm	Pungent odor; normally a person can detect sulfur dioxide in this range
5 ppm	Short Term Exposure Limit (STEL); Safe for 15 minutes of exposure
12 ppm	Throat irritation, coughing, chest constriction, eyes tear and burn
100 ppm	Immediately Dangerous To Life & Health (IDLH)
150 ppm	So irritating that it can only be endured for a few minutes
500 ppm	Causes a sense of suffocation, even with first breath
1,000 ppm	Death may result unless rescued promptly.

B. Radii of Exposure (ROE)
[NMAC 19.15.11.7.K]

The basis for worst case scenario calculations is as follows:

- 10,000 parts per million (ppm) or 1.0 mole percent of hydrogen sulfide in the inlet natural gas stream into the Agave Dagger Draw Gas Plant. In reality, the actual H₂S concentration that the plant processes will be much less than this. However, this is the design basis for the plant and associated equipment.
- A maximum daily (24 hour) processing volume of 40 MMCF.
- The worst case scenario radius of exposure (ROE) also assumes an uncontrolled instantaneous release from the area around either the Metropolis Well or the amine still of the above referenced volume and concentration. Because the Plant is a throughput process plant there is no actual way that the entire throughput volume of the Plant could be released instantaneously as is assumed in the worst case scenario calculations of the ROE; however, to comply with NMAC 19.15.11, that assumption is the worst case scenario in the formulas/calculations provided here.
- The amine system will remove 100% of the H₂S from the inlet gas. Agave does not measure the acid gas stream; rather using a mass-balance approach, Agave calculates that the resulting acid gas stream will be 40% or 0.4 mole percent H₂S and 0.5 MMscfd.

It should further be noted that the reason this rate, used as worst case, could not be released over a 24-hour period is the Plant's emergency shutdown (ESD) systems would be activated. The emergency shutdown (ESD) would prevent the flow of gas into the Plant in the event of an emergency. See Appendix C and Maps C-1 and C-2 for more information.

The formulas for calculating the two radius of exposure (ROE) are as follows:

100 ppm Radius of Exposure Calculation (as per 19 NMAC 15.11.7.K.1):

$$X = [(1.589)(\text{hydrogen sulfide concentration})(Q)]^{(0.6258)}$$

500 ppm Radius of Exposure Calculation (as per 19 NMAC 15.11.7.K.2):

$$X = [(0.4546)(\text{hydrogen sulfide concentration})(Q)]^{(0.6258)}$$

Where:

X = radius of exposure in feet

"hydrogen sulfide concentration" = the decimal equivalent of the mole or volume fraction of hydrogen sulfide in the gaseous mixture

Q = Escape rate expressed in cubic feet per day (corrected for standard conditions of 14.73 psi absolute and 60 degrees Fahrenheit)

Amine Unit

500-ppm ROE	1957 feet
100-ppm ROE	4282 feet

Acid Gas Disposal Well

500-ppm ROE	1268 feet
100-ppm ROE	2775 feet

VI. Facility Description, Maps, and Drawings [NMAC 19.15.11.9.B(2)(c)] [API RP-55 7.4 c.]

A. Dagger Draw Processing Plant Description of Operations- The primary function of the plant is to remove H₂S and CO₂ from sour field gas so that the gas can meet pipeline specifications. The plant has been designated a primary Standard Industrial Classification (SIC) Code of 1311. The operation of the Agave Dagger Draw Gas Plant is intended to process 40 MMscfd of gas. The facility is authorized to operate continuously (8,760 hr/yr) at design maximum capacity processing rates. The gas will be treated to remove acid gas components, dehydrated to remove water and processed to remove heavy (liquid) hydrocarbons from the gas stream. Several plant systems will be involved to perform these functions.

The amine unit is designed to remove acid gas components (carbon dioxide, hydrogen sulfide and mercaptans) from the natural gas stream. These components are removed from the natural gas because they are corrosive, hazardous to health, and reduce the heating value of the natural gas stream. In addition, the carbon dioxide can freeze in the cryogenic unit forming dry ice and forcing the shut down of the facility. This is known as the gas sweetening process. The acid gas removed by the amine unit will be disposed of by either acid gas injection into a disposal well or by incinerating in a flare. The preferred method of disposal will be to compress the gas and inject it into the well. Under emergency situations, the gas will be flared to prevent the emission of lethal hydrogen sulfide to atmosphere.

The glycol dehydration unit will receive approximately 40.0 MMSCFD of treated gas (sweet) from the amine unit and reduce the water content of the gas by circulating triethylene glycol (TEG). Molecular sieve dehydration is used upstream of the cryogenic processes to achieve a -150°F dew point. The process uses two molecular sieve vessels with one vessel in service absorbing moisture from the gas stream and the other vessel in the regeneration mode.

The cryogenic unit is designed to liquefy natural gas components from the sweet, dehydrated inlet gas by removing work (heat) from the gas by means of the turbo expander. The cryogenic unit recovers natural gas liquids (NGL) by cooling the gas stream to extremely cold temperatures (-150°F) and condensing components such as ethane, propane, butanes and heavier. Once the sweet, dry gas exits the cryogenic unit, it needs to be recompressed to approximately 800 to 1200 psi before the gas is sent to the main transportation pipeline. This is accomplished with two 2500 horsepower electric drive compressors.

The hot oil system in the plant is used to provide heat to certain processes within the facility. The system will circulate approximately 600 GPM of hot oil and deliver 15.5 MMBTU/hr to other processes.

B. Metropolis Disposal Well Description of Operations- The low pressure (< 10 psig), acid gas stream from the amine unit is routed to the acid gas compressor. The stream is then subject to a series of compression and cooling cycles, thus dehydrating and compressing the acid gas stream to a pressure of approximately 1150 psig. The high pressure acid gas stream then flows through a 2" stainless steel pipeline to the injection well site. At this point, the stream is introduced into the well.

There are number of safe guards designed to prevent leaks or overpressure of the system. The acid gas compressor is equipped with multiple pressure transmitters. These transmitters monitor compressor suction and discharge pressures and are programmed to shut the acid gas system down when the pressures fall outside a pre-programmed operating range. As an additional safeguard, the compressor panel is also equipped with high and low pressure shutdowns for each stage of compression that will shut the compressor down when pressures reach preset high and low pressure set points.

The acid gas pipeline is constructed from 2" inch 304 stainless steel tubing. The pipeline has been designed with a maximum allowable working pressure of 2350 psig. Historical injection pressures average 1150 psig. For leak detection purposes, the 2" acid gas line has been encased in 6" SDR 11 polyethylene pipe. A "sweet" gas stream flows through the annulus between the 6" and 2" pipelines at a preset pressure and flow rate. This sweet gas stream is monitored continuously for H₂S and over/ under pressure. If any one variable falls outside the predetermined operating range, the acid gas compressor is shut down and the acid gas stream is routed to the flare.

Safeguards for the acid gas injection well consist of a subsurface safety valve. This valve is designed to isolate and shut in the injection well if a leak occurs along the acid gas pipeline or at the surface of the well.

C. Map of Plant and Metropolis Well

See Appendix A, Map A-1

VII. Training and Drills

[NMAC 19.15.11.9.B(2)(d)] [API RP-55 7.4 d]

A. Responsibilities and Duties of Essential Personnel

1. Personnel responsible for implementing this plan shall be trained on their duties and responsibilities related to this plan during the annual on-site or table top training exercises.
2. Plant Orientation Training - All Plant personnel, visitors, and contractors must attend a Plant overview orientation prior to obtaining permission to enter the Plant. A refresher course on this training is required annually for all persons. This training also complies with the requirements of the Agave Energy Company Process Safety Management Program and Procedures Manual.

B. On-site or Classroom Drills

1. Agave Energy Company may use table top exercises as well as hands on emergency response training methods. Agave Energy Company shall conduct a table top exercise annually at a minimum.

C. Notification and Training of Others on Protective Measures in Emergency Situations

1. Affected residents will be invited to participate and/or observe annual drills, as well as being briefed on notification, evacuation, and shelter in place plans.

D. Training and Attendance Documentation

1. All training and drills will be documented. Documentation shall include sign in sheets, synopsis of the training conducted, and an after action review of the training.

E. Briefing of Public Officials on Evacuation and Shelter in Place Plans

1. Local law enforcement, first responders, and fire personnel will also be invited to participate and/or observe annual drills, as well as being briefed on notification, evacuation, and shelter in place plans.

VIII. Coordination with State Emergency Plans [NMAC 19.15.11.9.B(2)(e)]

A. Oil Conservation Division (OCD)

1. Oil Conservation Division (OCD) will be notified with an automatic email to the District II office advising of the activation of the H₂S Contingency Plan if any of the alarms are activated at 10 ppm H₂S or greater. In the event of a power failure, a phone call will be made within four hours. All subsequent paperwork will be filed in a timely fashion.

B. New Mexico State Police/ New Mexico Hazardous Materials Emergency Response Plan

1. The New Mexico State Police are responsible for overall scene management and coordination of all resources. A designated Emergency Response Officer (ERO) will establish the National Interagency Incident Management System (NIIMS) Incident Command System (ICS) as the Incident Commander (IC) and be responsible for management of all response resources on scene. Off-scene coordination of response resources will be handled through designated Headquarters Emergency Response Officers. Law enforcement-related activities will be coordinated by State Police.

IX. Plan Activation

[NMAC 19.15.11.9.C] [API RP-55 7.4 d]

A. Activation Levels

Level 1 – Intermittent alarm sounded and/or flashing amber beacons activated for H₂S greater than or equal to 10 ppm

Level 2 – Intermittent alarm sounded and/or flashing red beacons activated for H₂S greater than or equal to 20 ppm

Level 3 – Catastrophic release; fire; explosion; a continuous release of maximum volume for 24 hours; or NMAC 19.15.11: mandatory activation of indication of 100 ppm in any defined public area; 500 ppm at any public road; or 100 ppm at a distance greater than 3000 feet from the site or the release. Because the 100 ppm radius of impact (ROE) boundary is greater than 3000 feet from the site of release, a Level 3 response would occur before the escape of the 24 hour release volume.

B. Events that Could Lead to a Release of H2S

- Inlet and plant piping failure
- Amine still failure
- Flange/gasket leaks on inlet and plant piping
- Flange/gasket leaks on the acid gas compressor
- Flange/gasket leaks at metropolis disposal well
- Failure of acid gas pipeline
- Valve packing
- Seal failure on acid gas compressor
- Failure of flare to ignite during Plant emergency blow down

X. Submission of H2S Contingency Plans
[NMAC 19.15.11.9.D]

A. Submission

1. Agave Energy Company will submit the H2S Contingency Plan to the Oil Conservation Division (OCD).

B. Retention

1. Agave Energy Company shall maintain a copy of the contingency plan in the Main Office at 105 South 4th Street in Artesia, NM. The plan shall be readily accessible for review by the Oil Conservation Division (OCD) upon request.

C. Inventory

1. Agave Energy Company will file an annual inventory of wells, facilities and operations for which plans are on file with the Oil Conservation Division (OCD), to the Local Emergency Planning Committee (LEPC) and the State Emergency Response Commission as per NMAC 19.15.11.
2. The inventory shall include the name, address, telephone number, and point of contact for all operations in which plans are on file.



APPENDIX A – Facility Maps

Map A-1: Facility Map


Map A-2: Alarms and Monitors, Dagger Draw Active Equipment

Map A-3: Safety and Fire Equipment, Dagger Draw Active Equipment

Map A-4: Evacuation Router, Dagger Draw Active Equipment

Map A-5: Proposed Perimeter Alarms

Map A-6: Metropolis Disposal Well



AGAVE ENERGY COMPANY		STATE: NEW MEXICO
105 South Fourth Street, Artesia, New Mexico 86210		COUNTY: EDDY
AGAVE DAGGER DRAW		SECTION: 23
GAS PROCESSING PLANT		TOWNSHIP: 18S
Facility Map & Metropolis Disposal Well		RANGE: 23E
DRAFTING: TWH	DATE: 11/24/09	SCALE: N/A
CHEK: JK	DATE: 4/09/10	
APPROVED: JK	DATE: 4/09/10	
GPS: TWH-SF	DATE: 11/24/09	
SIZE: ANSI A		

LEVEL I RESPONSE

**CALL 911 for death or
Injury for emergency
assistance**

H2S detected at levels greater than or
equal to 10 ppm:
intermittent audible alarm and
flashing amber lights


- Evacuate to Emergency Assembly Area
- Evacuate visitors from plant to appropriate Muster Area
- Notify Agave Management
- Assign operators to suit up in SCBA
- Check PLC Computer for location of H2S alarm
- Notify all entities in the 500 ppm ROE if perimeter alarms are activated
- Wearing SCBA will attempt to locate and repair leak
- Rotate Operators in 15 minute shifts
- If H2S levels exceed 10 ppm in emergency assembly area relocate to an alternate assembly area

- If H2S levels exceed 20 ppm proceed to Level II response

Once resolved and
monitored levels in Plant
are less than 10 ppm H2S:
return to plant and
continue to monitor

LEVEL II RESPONSE

**CALL 911 for death or
Injury for emergency
assistance**



LEVEL III RESPONSE

**CALL 911 for death or
Injury for emergency
assistance**

**H2S detected greater than 20 ppm:
intermittent audible alarm and
flashing red lights
repair efforts are unsuccessful, worst
case scenario and/or catastrophic
release have occurred**

**H2S detected greater than 50 ppm:
plant will automatically go in to ESD. IC
determines to proceed with Level III or
Level II after ESD**

- Set up road blocks on Kincaid and Pipeline Roads near the muster areas
- Confirm all personnel have evacuated the 500 ppm ROE
- Instruct all personnel in the 100 ppm to evacuate to Muster Area as determined by the IC
- If vapors have ignited, continue to let burn unless fires endanger personnel
- Initiate a chronological record of events
- Within one hour of activation of the plan notify NMOCD and the NRC
- Establish a Media staging area in Muster Area 2 or other location as the situation permits
- Submit agency reports as required

**Once resolved and
monitored levels in Plant
are less than 10 ppm H2S:
return to Plant
continue to monitor**

APPENDIX C-RADIUS OF EXPOSURE CALCULATIONS

The basis for worst case scenario calculations is as follows:

- 10,000 parts per million (ppm) or 1.0 mole percent of hydrogen sulfide in the inlet natural gas stream into the Agave Dagger Draw Gas Plant. In reality, the actual H₂S concentration that the plant sees will be much less than this. However, this is the design basis for the plant and associated equipment.
- A maximum daily (24 hour) processing volume of 40 MMCF.
- The worst case scenario radius of exposure (ROE) also assumes an uncontrolled instantaneous release from the area around either the Metropolis Well or the amine still of the above referenced volume and concentration. Because the Plant is a throughput process plant there is no actual way that the entire throughput volume of the Plant could be released instantaneously as is assumed in the worst case scenario calculations of the ROE; however, to comply with NMAC 19.15.11, that assumption is the worst case scenario in the formulas/calculations provided here.
- The amine system will remove 100% of the H₂S from the inlet gas. Agave does not measure the acid gas stream; rather using a mass-balance approach, Agave estimates that the resulting acid gas stream will be 40% or 0.4 mole percent H₂S and 0.5 MMscfd.

It should further be noted that the reason this rate, used as worst case, could not be released over a 24 hour period is the Plant's emergency shutdown (ESD) systems that would be activated. The ESD would prevent the flow of gas into the Plant in the event of an emergency.

The formulas for calculating the two ROEs are as follows:

100 ppm Radius of Exposure Calculation (as per 19 NMAC 15.11.7.K.1):

$$X = [(1.589)(\text{hydrogen sulfide concentration})(Q)]^{(0.6258)}$$

500 ppm Radius of Exposure Calculation (as per 19 NMAC 15.11.7.K.2):

$$X = [(0.4546)(\text{hydrogen sulfide concentration})(Q)]^{(0.6258)}$$

Where:

X = radius of exposure in feet

"hydrogen sulfide concentration" = the decimal equivalent of the mole or volume fraction of hydrogen sulfide in the gaseous mixture

Q = Escape rate expressed in cubic feet per day (corrected for standard conditions of 14.73 psi absolute and 60 degrees Fahrenheit)

ROE Inside the Plant

The escape rate (Q) is the maximum daily rate of the gaseous mixture produced or handled or the best estimate thereof. For releases inside the Agave Dagger Draw Gas Plant, the Company is using for contingency planning purposes an "escape rate" equal to the maximum inlet gas volume of 40,000 MCFD. The (actual) inlet gas volume at the Plant will be somewhat variable and is continuously metered. The Plant records daily inlet gas volumes and prepares a daily volume report. The assumed 40,000 MCFD inlet gas volume has been selected as the "escape rate" because it is the highest anticipated inlet volume that the Plant would handle under its proposed operations and is considered worst case interpretation of the volume of gas.

It should be noted that the plan will remain effective as long as the processed volume and H₂S content equate to the same or smaller ROE.

Previous monitoring data indicated variable inlet concentrations of hydrogen sulfide, but concentration will not exceed 10,000 ppm or 1.0 mole percent. Therefore, 10,000 ppm or 1.0 mole percent has been used in the worst case scenario operations for contingency planning purposes.

Using:

$$Q = 40,000,000$$

$$\text{H}_2\text{S conc} \approx 10,000 \text{ ppm or } 1.0 \text{ mole\%}$$

500-ppm RADIUS OF EXPOSURE CALCULATION

$$X = [(0.4546) * (\text{H}_2\text{S concentration}) * (\text{gas volume (Q)})]^{0.6258}$$

$$X = [(0.4546) * (10,000 * .000001) * (40,000,000)]^{0.6258}$$

$$\underline{X = 1957 \text{ feet} = 500\text{-ppm ROE}}$$

100-ppm RADIUS OF EXPOSURE CALCULATION

$$X = [(1.589) * (\text{H}_2\text{S concentration}) * (\text{gas volume})]^{0.6258}$$

$$X = [(1.589) * (10,000 * .000001) * (40,000,000)]^{0.6258}$$

$$\underline{X = 4282 \text{ feet} = 100\text{-ppm ROE}}$$

ROE At the Injection Well

The escape rate (Q) is the best estimate of the maximum daily rate of the acid gas. For releases inside the Agave Dagger Draw Gas Plant, the Company is using for contingency planning purposes an "escape rate" equal to the 500 MCFD. The actual acid gas rate is not metered. However, using a mass-balance approach, Agave calculates the daily volume of the acid gas stream based on the inlet gas stream which is continuously metered. The assumed 500 MCFD acid gas volume has been selected as the "escape rate" because it is the highest anticipated gas volume that the Plant would handle under its proposed operations and is considered worst case interpretation of the volume of gas.

It should be noted that the plan will remain effective as long as the processed volume and H₂S content equate to the same or smaller ROE.

Previous monitoring data indicated variable inlet concentrations of hydrogen sulfide, but concentration will not exceed 400,000 ppm or 40 mole% at the inlet. Therefore, 400,000 ppm or 40 mole% has been used in the worst case scenario operations for contingency planning purposes. Again, Agave does not measure the H₂S concentration in the acid gas stream; rather the concentration is calculated based on the inlet conditions.

Using:

$$Q = 500,000$$

$$\text{H}_2\text{S conc} = 400,000 \text{ ppm or } 40 \text{ mole\%}$$

500-ppm RADIUS OF EXPOSURE CALCULATION

$$X = [(0.4546) * (\text{H}_2\text{S concentration}) * (\text{gas volume (Q)})]^{0.6258}$$

$$X = [(0.4546) * (400,000 * .000001) * (500,000)]^{0.6258}$$


$$\underline{X = 1268 \text{ feet} = 500\text{-ppm ROE}}$$

100-ppm RADIUS OF EXPOSURE CALCULATION

$$X = [(1.589) * (\text{H}_2\text{S concentration}) * (\text{gas volume})]^{0.6258}$$

$$X = [(1.589) * (400,000 * .000001) * (500,000)]^{0.6258}$$

$$\underline{X = 2775 \text{ feet} = 100\text{-ppm ROE}}$$



- 1957 Ft (500 ppm)
- 4282 Ft (100 ppm)
- AMINE STILL



AGAVE ENERGY COMPANY
 105 South Fourth Street, Artesia New Mexico 88210

**AGAVE DAGGER GAS DRAW PLANT
 HYDROGEN SULFIDE CONTINGENCY PLAN
 AMINE STILL RADIUS OF EXPOSURE**

DRAFTING: TWH	PRINTED: 4/09/10	SIZE: ANSI B	REV
CHK: JK	DATE: 4/09/10	SCALE: 1"=2000'	0
APPROVED: JK	DATE: 4/09/10	SHEET 1 of 1	

MAP C-1



- 1268 Ft (500 ppm)
- 2775 Ft (100 ppm)
- METROPOLIS WELLHEAD



AGAVE ENERGY COMPANY			
105 South Fourth Street, Artesia New Mexico 88210			
AGAVE DAGGER GAS DRAW PLANT			
HYDROGEN SULFIDE CONTINGENCY PLAN			
METROPOLIS WELLHEAD RADIUS OF EXPOSURE			
DRAFTING: TWH	PRINTED: 4/09/10	SIZE: ANSI B	REV
CHK: JK	DATE: 4/09/10	SCALE: 1"=2000'	0
APPROVED: JK	DATE: 4/09/10	SHEET 1 of 1	

APPENDIX D – Muster Areas, Evacuation Routes

Map D-1: Evacuation Routes to Muster Areas

Map D-2: Menefee – Safety Trailer Location



4 Dinkus Rd (CR 39)

MUSTER AREA 2
ROAD BLOCK LOCATION

Highway 285

Pipeline Rd (CR 40)

EVACUATION ROUTE

EMERGENCY ASSEMBLY AREA 1

Kincaid Rd (CR 38)

MUSTER AREA 1
ROAD BLOCK LOCATION

EVACUATION ROUTE

EMERGENCY ASSEMBLY AREA 2




— MUSTER AREA



AGAVE ENERGY COMPANY 105 South Fourth Street, Artesia New Mexico 88210			
AGAVE DAGGER GAS DRAW PLANT HYDROGEN SULFIDE CONTINGENCY PLAN EVACUATION ROUTES			
DRAFTING: TWH	PRINTED: 4/09/10	SIZE: ANSI B	REV 0
CHK: JK	DATE: 4/09/10	SCALE: 1"=2000'	
APPROVED: JK	DATE: 4/09/10	SHEET 1 of 1	

MAP D-1



MAP D-2



AGAVE ENERGY COMPANY 105 South Fourth Street, Artesia New Mexico 88210			
AGAVE DAGGER GAS DRAW PLANT HYDROGEN SULFIDE CONTINGENCY PLAN EMERGENCY TRAILER LOCATION			
DRAFTING: TWH	PRINTED: 4/09/10	SIZE: ANSI B	REV 0
CHK: JK	DATE: 4/09/10	SCALE: NA	
APPROVED: JK	DATE: 4/09/10	SHEET 1 of 1	

APPENDIX E – H2S Contingency Plan Distribution List

New Mexico Oil Conservation Division

New Mexico Department of Public Safety

Local Emergency Planning Committee

Artesia Fire Department

Atoka Fire Department

Artesia Fire Department

Eddy County Sheriff's Department

Dagger Draw Plant

Agave Main Office