

GW - 266

**INSPECTIONS &
DATA**

OCD ENVIRONMENTAL BUREAU

SITE INSPECTION SHEET

DATE: 5-15-02 Time: 2:45 PM

Type of Facility: Refinery Gas Plant Compressor St. Brine St. Oilfield Service Co.
Surface Waste Mgt. Facility E&P Site Crude Oil Pump Station
Other _____

Discharge Plan No Yes GW# 266

FACILITY NAME: EUNICE CRUDE OIL STATION

PHYSICAL LOCATION: 32° 30' 46.2" N / 103° 15' 39.9" W

Legal: QTR QTR Sec TS R R County LEA

OWNER/OPERATOR (NAME) _____

Contact Person: KIRBY SHIP Tele:# _____

MAILING ADDRESS: _____ State _____ ZIP _____

Owner/Operator Rep's: _____

OCD INSPECTORS: W PRICE, E MARTIN

1. **Drum Storage:** All drums containing materials other than fresh water must be stored on an impermeable pad with curbing. All empty drums will be stored on their sides with the bungs in and lined up on a horizontal plane. Chemicals in other containers such as sacks or buckets will also be stored on an impermeable pad and curb type containment.

OK

2. **Process Areas:** All process and maintenance areas which show evidence that leaks and spills are reaching the ground surface must be either paved and curbed or have some type of spill collection device incorporated into the design.

OK

3. Above Ground Tanks: All above ground tanks which contain fluids other than fresh water must be bermed to contain a volume of one-third more than the total volume of the largest tank or of all interconnected tanks. All new tanks or existing tanks that undergo a major modification, as determined by the Division, must be placed within an impermeable bermed enclosure.

OK

4. Above Ground Saddle Tanks: Above ground saddle tanks must have impermeable pad and curb type containment unless they contain fresh water or fluids that are gases at atmospheric temperature and pressure.

OK

5. Labeling: All tanks, drums and containers will be clearly labeled to identify their contents and other emergency notification information.

OK

6. Below Grade Tanks/Sumps: All below grade tanks, sumps, and pits must be approved by the OCD prior to installation or upon modification and must incorporate secondary containment and leak-detection into the design. All pre-existing sumps and below-grade tanks must demonstrate integrity on an annual basis. Integrity tests include pressure testing to 3 pounds per square inch above normal operating pressure and/or visual inspection of cleaned out tanks and/or sumps, or other OCD approved methods. The OCD will be notified at least 72 hours prior to all testing.

NA

7. Underground Process/Wastewater Lines: All underground process/wastewater pipelines must be tested to demonstrate their mechanical integrity at present and then every 5 years thereafter, or prior to discharge plan renewal. The permittee may propose various methods for testing such as pressure testing to 3 pounds per square inch above normal operating pressure or other means acceptable to the OCD. The OCD will be notified at least 72 hours prior to all testing.

OK

12. Does the facility have any other potential environmental concerns/issues?

NONE

13. Does the facility have any other environmental permits - i.e. SPCC, Stormwater Plan, etc.?

—

14. ANY WATER WELLS ON SITE? NO YES IF YES, HOW IS IT BEING USED ?

15. Documents reviewed:

Miscellaneous Comments:

Photos taken: 0

Documents Reviewed/Collected: _____

