

District I  
1625 N. French Dr., Hobbs, NM 88240  
District II  
811 S. First St., Artesia, NM 88210  
District III  
1000 Rio Brazos Road, Aztec, NM 87410  
District IV  
1220 S. St. Francis Dr., Santa Fe, NM 87505

State of New Mexico  
Energy Minerals and Natural Resources

Oil Conservation Division  
1220 South St. Francis Dr.  
Santa Fe, NM 87505

Form C-141  
Revised August 8, 2011

Submit 1 Copy to appropriate District Office in  
accordance with 19.15.29 NMAC.

**Release Notification and Corrective Action**

**OPERATOR**

☒ Initial Report ☐ Final Report

Name of Company – Energy Transfer Partners	Contact – Dean D. Ericson	
Address 600 N. Marienfeld Street Ste.700	Telephone No. 432-238-2142(cell)	
Facility Name James Ranch Compressor Station	Facility Type Compressor Station	
Surface Owner: NMSLO	Mineral Owner N/A	API No.

**LOCATION OF RELEASE**

Unit Letter E	Section 16	Township 23S	Range 31E	Feet from the 2236'	North/South Line North	Feet from the 2284'	East/West Line West	County: Eddy
------------------	---------------	-----------------	--------------	------------------------	---------------------------	------------------------	------------------------	-----------------

Latitude 32.30538 Longitude -103.78808

**NATURE OF RELEASE**

Type of Release: Water/Condensate	Volume of Release: 13.7bbls	Volume Recovered: 0
Source of Release: Pipeline – PRV	Date and Hour of Occurrence: 12/15/17 at 8:11am	Date and Hour of Discovery: 12/15n/17 at 8:11am
Was Immediate Notice Given? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Not Required	If YES, To Whom? Phone message left with Olivia Yu 12/15/17 @7:49pm Email to Olivia Yu – 12/15/17	
By Whom? Dean D. Ericson	Date and Hour 12/15/17	
Was a Watercourse Reached? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	If YES, Volume Impacting the Watercourse. N/A	

If a Watercourse was Impacted, Describe Fully.\*

N/A


Describe Cause of Problem and Remedial Action Taken.\*

Pipeline Relief Valve (PRV) relieved due to low fuel header pressure. Compressor Station fuel froze (ie JT Effect) causing the compressors to go off-line. Compressors placed back on-line.

Describe Area Affected and Cleanup Action Taken.\*

Affected area is approximately 412' x 47'. No Cleanup Action has taken place. ETC has not received permission from NMSLO to proceed.

I hereby certify that the information given above is true and complete to the best of my knowledge and understand that pursuant to NMOCD rules and regulations all operators are required to report and/or file certain release notifications and perform corrective actions for releases which may endanger public health or the environment. The acceptance of a C-141 report by the NMOCD marked as "Final Report" does not relieve the operator of liability should their operations have failed to adequately investigate and remediate contamination that pose a threat to ground water, surface water, human health or the environment. In addition, NMOCD acceptance of a C-141 report does not relieve the operator of responsibility for compliance with any other federal, state, or local laws and/or regulations.

Signature: 	<b>OIL CONSERVATION DIVISION</b>		
Printed Name: Dean D. Ericson	Approved by Environmental Specialist:		
Title: Sr. Environmental Specialist	Approval Date:	Expiration Date:	
E-mail Address: dean.ericson@energytransfer.com	Conditions of Approval:		Attached <input type="checkbox"/>
Date: 12/18/17 Phone: 432-238-2142(cell)			

\* Attach additional Sheets If Necessary/