

District I  
1625 N. French Dr., Hobbs, NM 88240  
District II  
1301 W. Grand Avenue, Artesia, NM 88210  
District III  
1000 Rio Brazos Road, Aztec, NM 87410  
District IV  
1220 S. St. Francis Dr., Santa Fe, NM 87505

State of New Mexico  
Energy Minerals and Natural Resources

Form C-144  
June 1, 2004

Oil Conservation Division  
1220 South St. Francis Dr.  
Santa Fe, NM 87505

For drilling and production facilities, submit to appropriate NMOCD District Office.  
For downstream facilities, submit to Santa Fe office

**Pit or Below-Grade Tank Registration or Closure**

Is pit or below-grade tank covered by a "general plan"? Yes ☒ No ☐  
Type of action: Registration of a pit or below-grade tank ☐ Closure of a pit or below-grade tank ☒

Operator: Burlington Resources Telephone: (505) 326-9841 e-mail address: LHasely@br-inc.com  
Address: 3401 East 30<sup>th</sup> Street, Farmington, New Mexico, 87402  
Facility or well name: Reuter No. 1 API #: 30039067980000 U/L or Qtr/Qtr L Sec 34 T 27N R 6W  
County: Rio Arriba Latitude 36.52597 Longitude -107.4618 NAD: 1927 ☒ 1983 ☐  
Surface Owner: Federal ☒ State ☐ Private ☐ Indian ☐

Pit	Below-grade tank	
Type: Drilling <input type="checkbox"/> Production <input type="checkbox"/> Disposal <input type="checkbox"/> Workover <input type="checkbox"/> Emergency <input type="checkbox"/> Lined <input type="checkbox"/> Unlined <input type="checkbox"/> Liner type: Synthetic <input type="checkbox"/> Thickness _____ mil Clay <input type="checkbox"/> Pit Volume _____ bbl	Volume: <u>95</u> bbl Type of fluid: <u>Produced Water and Incidental Oil</u> Construction material: <u>Fiberglass</u> Double-walled, with leak detection? Yes <input type="checkbox"/> If not, explain why not. <u>No. Tank in place prior to Rule 50.</u>	
Depth to ground water (vertical distance from bottom of pit to seasonal high water elevation of ground water.)	Less than 50 feet	(20 points)
	50 feet or more, but less than 100 feet	(10 points)
	100 feet or more	( 0 points) 20
Wellhead protection area: (Less than 200 feet from a private domestic water source, or less than 1000 feet from all other water sources.)	Yes	(20 points)
	No	( 0 points) 0
Distance to surface water: (horizontal distance to all wetlands, playas, irrigation canals, ditches, and perennial and ephemeral watercourses.)	Less than 200 feet	(20 points)
	200 feet or more, but less than 1000 feet	(10 points)
	1000 feet or more	( 0 points) 20
<b>Ranking Score (Total Points)</b>		<b>40</b>

If this is a pit closure: (1) Attach a diagram of the facility showing the pit's relationship to other equipment and tanks. (2) Indicate disposal location: (check the onsite box if you are burying in place) onsite ☐ offsite ☐ If offsite, name of facility \_\_\_\_\_. (3) Attach a general description of remedial action taken including remediation start date and end date. (4) Groundwater encountered: No ☐ Yes ☐ If yes, show depth below ground surface \_\_\_\_\_ ft. and attach sample results. (5) Attach soil sample results and a diagram of sample locations and excavations.

Additional Comments:

\*The soils tested clean and no soil remediation was required.

I hereby certify that the information above is true and complete to the best of my knowledge and belief. I further certify that the above-described pit or below-grade tank has been/will be constructed or closed according to NMOCD guidelines ☒, a general permit ☐, or an (attached) alternative OCD-approved plan ☐.

Date: 4/12/05

Printed Name/Title Ed Hasely, Env. Advisor Signature [Signature]

Your certification and NMOCD approval of this application/closure does not relieve the operator of liability should the contents of the pit or tank contaminate ground water or otherwise endanger public health or the environment. Nor does it relieve the operator of its responsibility for compliance with any other federal, state, or local laws and/or regulations.

Approval: [Signature] DEPUTY OIL & GAS INSPECTOR, DIST. # 10 APR 14 2005  
Printed Name/Title Mr. Ed Hasely, Environmental Advisor Signature \_\_\_\_\_ Date: \_\_\_\_\_

ENVIRONMENTAL SCIENTISTS & ENGINEERS  
5796 U.S. HIGHWAY 64-3014  
FARMINGTON NEW MEXICO 87401  
PHONE (505) 634-0615

0041 NAME Renter WELL # 1 PIT \_\_\_\_\_ DATE STARTED 4/6/05  
QUAD/UNIT L SEC 34 TWP 27N RNG 04W PM NMPM CNTY ARRIBA NM <sup>R10</sup> DATE FINISHED 4/6/05  
DTP FUDRAGE \_\_\_\_\_ CONTRACTOR LJR EMPLOYMENT SPECIALIST NPM

EXCAVATION APPROX. \_\_\_\_\_ FT. x \_\_\_\_\_ FT. x \_\_\_\_\_ FT. DEEP CUBIC YARDAGE: \_\_\_\_\_  
DISPOSAL FACILITY: \_\_\_\_\_ N/A \_\_\_\_\_ REMEDIATION METHOD: \_\_\_\_\_  
LAND USE: \_\_\_\_\_ LEASE: \_\_\_\_\_ SF 079210 \_\_\_\_\_ FORMATION: \_\_\_\_\_

FIELD NOTES & REMARKS: PIT LOCATED APPROXIMATELY 63' FT 260° FROM WELLHEAD

DEPTH TO GROUNDWATER 20 NEAREST WATER SOURCE 0 NEAREST SURFACE WATER 20

NMDD BANKING SCORE: 40 NMDD TPH CLOSURE STD: 100 PPM

SOIL AND EXCAVATION DESCRIPTION:

CHECK ONE

✓ PIT ABANDONED

\_\_\_\_ STEEL TANK INSTALLED

After below grade tank removed, no visible signs of contamination. No secondary liner present. At 3' below tank, no visible signs or odors of contamination. No soil removed from excavation.

TIME	SAMPLE I.D.	LAB No:	WEIGHT (g)	mL FREON	DILUTION	READING	CALC. ppm
1500	3' Below	1	5	20	1	0.0042	29.1

SCALE





0 FT'

PIT PERIMETER

## OVM RESULTS

PIT PROFILE

[illegible]

$x = 3'$  Below Pit

TRAVEL NOTES

# ENVIROTECH INC.

PRACTICAL SOLUTIONS FOR A BETTER TOMORROW

## EPA METHOD 418.1 TOTAL PETROLEUM HYDROCARBONS

Client:	Burlington Resources	Project #:	92115-021-032
Sample No.:	1	Date Reported:	3/23/2005
Sample ID:	Discrete, 3' Below BG Tank	Date Sampled:	3/17/2005
Sample Matrix:	Soil	Date Analyzed:	3/17/2005
Preservative:	Cool	Analysis Needed:	TPH-418.1
Condition:	Cool and Intact		

Parameter	Concentration (mg/kg)	Det. Limit (mg/kg)
-----------	--------------------------	--------------------------

Total Petroleum Hydrocarbons	29.1	5.0
------------------------------	------	-----

ND = Parameter not detected at the stated detection limit.

References: Method 418.1, Petroleum Hydrocarbons, Total Recoverable, Chemical Analysis of Water and Waste, USEPA Storet No. 4551, 1978.

Comments: Reuter No. 1

Michael P. Marquez  
Analyst

Audrey Pessopal-Parker  
Review