

WASTE WATER INJECTION LOG

Dates: From 12-8 to 12-10

		Obtained from Rustrak Recorder			P-670 DISCHARGED TOTALIZER READING	OILERS LEVEL	CRANKCASE LEVEL	CHART CHANGED	TIME	OPERATOR INITIALS
		P-670 FLOW RATE	P-670 PRESSURE	ANNULAR PRESSURE						
Monday	1									
	2									
Tuesday	1									
	2									
Wednesday	1									
	2									
Thursday	1									
	2									
Friday	1	100.2	732.0	36.3	20469	✓	✓	Yes	15:30	
	2	101.9	760.5	1.4	205028	✓	✓	Yes	19:30	AK
Saturday	1	99.1	766.0	3.0	205640	✓	✓		11:30	ML
	2	101.1	747.0	5.2	206226	✓	✓	Yes	23:00	Pick.
Sunday	1									
	2									

NOTES: (valve lineup at ponds, unusual conditions, etc.) started back up @

Larry worked on level switches

Found Pond Pump tripped 04:00 PM

* Shut down pump @ Approx. Noon 12/10, switch not working properly.