

WASTE WATER INJECTION LOG

Dates: From 1/29/96 to 2/4/96

		Obtained from Rustrak Recorder			P-670 DISCHARGED TOTALIZER READING	OILERS LEVEL	CRANKCASE LEVEL	CHART CHANGED	TIME	OPERATOR INITIALS
		P-670 FLOW RATE	P-670 PRESSURE	ANNULAR PRESSURE						
Monday	1	119.0	866.0	0.1	253825	✓	✓		11:00	Ra
	2	119.5	871.9	-0.1	254615	✓	✓	yes	midnite	ML
Tuesday	1	117.8	870.5	-0.2	255385	-	-	-	12 ⁴⁵ /p	3H
	2	116.0	870.1	-0.2	256063	✓	✓	yes	23:50	ML
Wednesday	1	117.2	876.2	-0.2	256806	✓	✓		12 ¹⁵	Rick
	2	119.7	882.6	-0.2	257459	✓	✓	yes	23:00	Rick
Thursday	1	112.5	889.4	0.2	258163	✓	✓	-	11:00	Ra
	2	108.0	881.3	-0.2	258884	✓	✓	yes	23 30	ML
Friday	1	110.9	917.6	-0.2	259662	✓	✓	-	12 ¹⁵	Rick
	2	111.8	918.4	-0.1	260219	✓	✓	yes	23:15	ML
Saturday	1	111.0	911.4	-0.1	260908	✓	-	-	11:10	AL
	2	119.5	941.5	-0.1	261660	-	-	yes	23 ⁴⁵ /p	3H
Sunday	1	114.5	916.3	-0.1	262379	-	-	-	11:45	AL
	2	117.7	929.8	-0.1	263117	-	-	yes	23 ³⁰ /p	3H

NOTES: (valve lineup at ponds, unusual conditions, etc.) Ops - maintain just less than 950^{psi} on the 2" disch. pressure by adjusting flow rate 2-2-96