

WASTE WATER INJECTION LOG

Dates: From 5/20 to 5/26

Obtained from Rustak Recorder				P-670	OILERS	CRANKCASE	CHART	TIME	OPERAT INITIAL	
	P-670 FLOW RATE	P-670 PRESSURE	ANNULAR PRESSURE	DISCHARGED TOTALIZER READING	LEVEL	LEVEL	CHANGED			
Monday	1	106.7	942.9	126.3	016863	—	—		14:30	AL
	2	97.3	909.3	169.4	017528	—	—	Yes	23:50	BA
Tuesday	1	100.2	950.3	116.6	018563	Added 1.5 qts.	—		12:10	ll
	2	76.4	924.1	176.1	019278	✓	✓	Yes	23:10	Rick
Wednesday	1	105.0	944.5	160.8	020739	✓	✓		11:30	ll
	2	105.4	945.4	180.6	020996	✓	✓	Yes	23:00	Rick
Thursday	1	106.8	944.5	161.6	022162	Added	✓		12:05	ll
	2	103.3	932.1	173.6	023351	✓	✓	Yes	23:10	Rick
Friday	1	108.9	955.8	77.5	024745	Added 1 qt	—	—	14:10	BA
	2	109.7	958.3	130.0	025657	✓	Added	Yes	23:00	BA
Saturday	1	91.3	884.0	136.9	026891	—	—	—	13:00	BA
	2	95.0	890.8	125.7	027779	✓	—	Yes	23:50	ll
Sunday	1	99.9	913.5	164.5	029094	—	—	—	12:30	BA
	2	100.4	918.9	184.5	030289	—	—	Yes	00:25	ll

NOTES: (valve lineup at ponds, unusual conditions, etc.)