

| ITEM | DESCRIPTION | A. B. CHANCE NO. | JOSLYN NO. | OTHER REFS. NO. | NO SUB. |
|------|---|------------------|------------|--------------------|------------|
| AA | Primary Cutout - 100 amp, 15 KV, 16000 amp Int. cap. | F2XX1015G | | | X |
| BB | General Purpose "up" bolt Clamp | UC310AGP | | | |
| CC | Lightning arrester, 10 KV | | | MSDA/EDSON KNA62 | |
| DD | Single phase oil switch, 14.4 KV | | | BLACKBURN F381E5 | |
| EE | split bolt connector, size req'd | | | | |
| FF | rounding spec. see dwg No. ES-11 & ES-1A, Note 3 | | | | |
| GG | 35' class 4 creosoted pine pole | | | | |
| HH | Aluminum deadend Performa for ACSB, size req'd | | | | |
| II | 30' class 6 creosoted pine pole | | | | |
| JJ | OVERHEAD GND, #4 ACSB - 11 Req'd - Ref. Dwg ES-11, | | | | |
| KK | ES-1A - Note 3 | | | | |
| LL | ground connector, motor | | | BURNDY K-2-22 | X |
| MM | 600 V. secondary lightning arrester single phase | | | | |
| NN | Greenfield Type EF liquid-tight flexible steel conduit, size req'd, w/ necessary liquid-tight connectors. | | | | |
| OO | req'd size LB fitting & cover & gasket | GW575 | | | |
| PP | transformer tank grounding terminal | | | | |
| QQ | Bird Guards (insulating boots on transformer bushings) | | | MSDA/EDSON KNA62 | |

| | | | |
|-------------|-----------|------------------|----------------------|
| DATE | 12-27-71 | TITLE | DESCRIPTION MATERIAL |
| DRAWN BY | E. WINTER | PRODUCTION DEPT. | CONOCO |
| DESIGN BY | | JOB | REC SPECS |
| CHECKED BY | | DRAWING NO. | ES-1 |
| APPROVED BY | | SCALE | NONE |
| | | | SHEET 2 OF 3 |

