



P.O. Box 1653
Durango, Colorado 81302
(970) 764-7356
www.cottonwoodconsulting.com

September 5, 2025

Jerrid Brann
Simcoe LLC
1199 Main Ave Suite 101
Durango, CO 81301

**RE: Atlantic A LS #009A
Biannual 2025 Monitoring Report**

Dear Mr. Brann,

Cottonwood Consulting LLC (Cottonwood) is pleased to provide Simcoe LLC (Simcoe) with the results of the soil vapor extraction (SVE) monitoring conducted at the Atlantic A LS #009A well site (API 30-045-22492). Details regarding the methodology and associated results are summarized below.

Background

In May 2012, approximately 13 barrels (bbls) of condensate was released from a split load line at the Atlantic A LS #009A well site. Soil boring results determined the lateral and vertical extent of the impacts. The SVE system was installed to perform in-situ remediation of these soils. The SVE system was installed in March 2015 and two additional SVE points were installed in February 2018 (Figure 1).

Methodology

The SVE system commenced operation in March 2015. Monitoring is conducted on a regular schedule. During the monitoring, observations are made about the SVE system operation and general condition, organic vapor meter (OVM) readings are collected from the exhaust of the SVE unit, vacuum pressure on the unit is noted, and the quantity of water within the drum located on the unit is noted and the drum drained, if required.

The system was initially extracting from SVE point VH-5. When OVM readings were significantly reduced in VH-5 in February 2018 and following the installation of two additional SVE points, the system was switched to SVE point VH-6, where it has remained.

Monitoring Results

It appears that the SVE system significantly reduced OVM readings in SVE point VH-5 from 2015 to 2018. OVM readings have been on a general downward trend since the system began extraction

Cottonwood Consulting LLC

Brann, J.
Page 2 of 2

from SVE point VH-6, with the exception of an elevated reading collected in October 2021. Since that elevated reading, OVM readings have continued their downward trend. See Figure 2 for OVM reading results in VH-5 and VH-6 and Attachment 1 for a summary of the SVE System Monitoring Data.

The system was operational upon arrival at all the 2025 monitoring events, indicating that the system has been operational 100 percent of the year to date.

Conclusion

OVM readings have trended downward since the system began extraction. Simcoe will continue to conduct regular monitoring at the Atlantic A LS #009A SVE system. In the future, Simcoe may advance subsurface soil borings to verify closure standards are met.

Should you have any questions, please do not hesitate to contact me at 970-764-7356. Cottonwood appreciates the opportunity to provide services to Simcoe.

Sincerely,



Kyle Siesser, P.G.
Cottonwood Consulting LLC

Attachments: Figure 1 – Site Map
Figure 2 – OVM Reading Results
Attachment 1 – SVE System Monitoring Data

Cottonwood Consulting LLC



FIGURE 1

Atlantic A LS 009A

SVE Operation and Performance
API# 30-045-22492
(C) S27, T31N, R10W
SVE GPS:
36.873389°, -107.873024°

Legend

- Atlantic ALS 9A Wellhead
- Existing SVE Point
- SVE Point Installed 2018
- SVE Unit

Atlantic A LS 9A

VH-3

SVE Unit

VH-4


VH-5

VH-6

VH-7

VH-1

Google Earth





80 ft



FIGURE 2



**Atlantic A LS #009A
OVM Reading Results
Simcoe LLC**





ATTACHMENT 1



**Atlantic A LS #009A
SVE Monitoring Results
Simcoe LLC**

Date	SVE Point	Exhaust OVM (ppm)	Vacuum Pressure upstream of drum (inHG)	Vacuum Pressure downstream of drum (inHG)	Exhaust Rate (cfm)	System Operational at Arrival	Water Drained	Water Drained (gal)	Comments
3/9/2015	VH-5	1,264	1.47	-	80	-	-	-	Initial Startup at SVE VH-5
3/10/2015	VH-5	1,008	1.47	-	80	YES	NO	-	
3/11/2015	VH-5	929	1.47	-	80	YES	YES	1.00	
3/12/2015	VH-5	920	1.40	-	80	YES	YES	1.00	
3/13/2015	VH-5	681	1.47	-	80	YES	YES	1.00	
3/17/2015	VH-5	469	1.40	-	80	YES	YES	4.00	
3/19/2015	VH-5	341	1.32	-	80	YES	YES	2.00	
3/23/2015	VH-5	358	1.40	-	80	YES	YES	4.00	
3/30/2015	VH-5	189	1.40	-	80	YES	YES	7.00	
4/1/2015	VH-5	195	1.40	-	80	YES	YES	3.00	
4/6/2015	VH-5	192	1.40	-	80	YES	YES	3.00	
4/15/2015	VH-5	140	1.47	-	80	YES	YES	6.00	
4/21/2015	VH-5	111	1.47	-	80	YES	YES	6.00	
4/27/2015	VH-5	102	1.47	-	80	YES	YES	3.00	
5/7/2015	VH-5	82	1.40	-	80	YES	YES	2.00	
5/11/2015	VH-5	72	1.40	-	80	YES	YES	2.00	
5/20/2015	VH-5	64	1.40	-	80	YES	YES	3.00	
5/26/2015	VH-5	57	1.40	-	80	YES	YES	1.00	
6/2/2015	VH-5	55	1.40	-	80	YES	YES	1.00	
6/8/2015	VH-5	48	1.40	-	80	YES	NO	-	
6/15/2015	VH-5	44	1.40	-	80	YES	NO	-	
6/22/2015	VH-5	48	1.40	-	80	YES	NO	-	
6/29/2015	VH-5	42	1.40	-	80	YES	NO	-	
7/6/2015	VH-5	40	1.40	-	80	YES	NO	-	
7/13/2015	VH-5	35	1.40	-	80	YES	NO	-	
7/20/2015	VH-5	37	1.40	-	80	YES	NO	-	
7/26/2015	VH-5	32	1.40	-	80	YES	NO	-	
8/5/2015	VH-5	32	1.40	-	80	YES	NO	-	
8/12/2015	VH-5	26	1.40	-	80	YES	NO	-	
8/19/2015	VH-5	26	1.40	-	80	YES	NO	-	
8/24/2015	VH-5	24	1.40	-	80	YES	NO	-	
8/26/2015	VH-2	1.1	1.62	-	75	YES	NO	-	Switched to VH-2. OVM reading after 10-min operation
8/31/2015	VH-2	1.0	1.47	-	80	YES	NO	-	Collected reading then switched to VH-4
9/3/2015	VH-4	2.2	1.47	-	80	YES	NO	-	Collected reading then switched to VH-3
9/8/2015	VH-3	2.6	1.47	-	80	YES	NO	-	Collected reading then switched to VH-5
9/17/2015	VH-5	16	1.40	-	80	YES	NO	-	
9/22/2015	VH-5	10	1.40	-	80	YES	NO	-	Collected reading then switched to VH-1
9/23/2015	VH-1	2	1.69	-	75	YES	NO	-	Collected reading then switched to VH-2
9/24/2015	VH-2	2	1.47	-	80	YES	NO	-	Collected reading then switched to VH-3
9/25/2015	VH-3	4	1.40	-	80	YES	NO	-	Collected reading then switched to VH-4
9/28/2015	VH-4	4	1.40	-	80	YES	NO	-	Collected readings then switched to VH-5
9/29/2015	VH-5	30	1.40	-	80	YES	NO	-	
10/8/2015	VH-5	26	1.47	-	80	YES	NO	-	
10/15/2015	VH-5	26	1.47	-	80	YES	YES	5.50	
10/23/2015	VH-5	44	1.47	-	80	YES	YES	12.00	
10/28/2015	VH-5	37	1.40	-	80	YES	NO	-	Did not check water level in drum
11/6/2015	VH-5	38.6	1.47	-	80	NO	YES	29.00	
11/13/2015	VH-5	38.6	1.47	-	80	YES	YES	17.00	
11/20/2015	VH-5	33.3	1.47	-	80	YES	YES	19.00	



**Atlantic A LS #009A
SVE Monitoring Results
Simcoe LLC**

Date	SVE Point	Exhaust OVM (ppm)	Vacuum Pressure upstream of drum (inHG)	Vacuum Pressure downstream of drum (inHG)	Exhaust Rate (cfm)	System Operational at Arrival	Water Drained	Water Drained (gal)	Comments
11/27/2015	VH-5	31.1	1.47	-	80	YES	YES	17.00	
12/4/2015	VH-5	22	1.47	-	80	YES	YES	22.00	
12/11/2015	VH-5	38	1.47	-	80	YES	YES	17.00	
12/18/2015	VH-5	27	1.47	-	80	YES	YES	24.50	
12/24/2015	VH-5	23	1.47	-	80	YES	YES	16.50	
12/31/2015	VH-5	20	1.40	-	80	NO	YES	29.00	Collected readings after draining & restarting
1/7/2016	VH-5	16	1.47	-	80	YES	YES	21.00	
1/14/2016	VH-5	16	1.47	-	80	YES	YES	23.00	
1/21/2016	VH-5	20	1.47	-	80	YES	YES	21.00	
1/28/2016	VH-5	20	1.47	-	80	YES	YES	19.00	
2/5/2016	VH-5	18	1.54	-	80	YES	YES	21.00	
2/13/2016	VH-5	17	1.47	-	80	YES	YES	16.50	
2/19/2016	VH-5	14	1.54	-	80	YES	YES	10.00	
2/26/2016	VH-5	14	1.54	-	80	YES	YES	11.00	
3/3/2016	VH-5	14	1.47	-	80	YES	YES	7.00	
3/10/2016	VH-5	-	-	-	-	YES	YES	7.00	
3/17/2016	VH-5	17	1.54	-	80	YES	YES	7.00	
3/24/2016	VH-5	-	-	-	-	YES	NO	-	Measured ~ 3.0" H2O in drum
3/31/2016	VH-5	13	1.54	-	80	YES	YES	14.00	
4/8/2016	VH-5	-	-	-	-	YES	NO	-	Measured ~ 3.0" H2O in drum
4/15/2016	VH-5	13	1.54	-	80	YES	YES	7.00	
4/22/2016	VH-5	10	1.54	-	80	YES	YES	4.00	
4/29/2016	VH-5	10	1.54	-	80	YES	YES	5.50	
5/14/2016	VH-5	10	1.62	-	80	YES	NO	-	Measured ~ 1.5" H2O in drum
5/26/2016	VH-5	8	1.54	-	80	YES	NO	-	Measured ~ 1.0" H2O in drum
6/10/2016	VH-5	8	1.47	-	80	YES	NO	-	
6/24/2016	VH-5	8	1.62	-	80	YES	NO	-	
7/21/2016	VH-5	8	1.62	-	80	YES	NO	-	
8/19/2016	VH-5	5	1.62	-	80	YES	NO	-	
9/26/2016	VH-5	8	1.62	-	80	YES	YES	2.50	
10/25/2016	VH-5	5	1.69	-	80	YES	YES	22.00	
11/8/2016	VH-5	-	-	-	-	YES	YES	15.50	
11/21/2016	VH-5	22	1.77	-	80	NO	YES	23.00	Collected readings after draining & restarting
12/6/2016	VH-5	-	-	-	-	YES	YES	26.00	Restarted later in the day
12/14/2016	VH-5	17	1.54	-	80	YES	YES	27.00	
12/20/2016	VH-5	33	1.62	-	80	YES	YES	17.00	
12/28/2016	VH-5	21	1.54	-	80	YES	YES	23.00	
1/5/2017	VH-5	28	1.62	-	80	YES	YES	19.00	
1/11/2017	VH-5	23	1.54	-	80	YES	YES	15.50	
1/19/2017	VH-5	-	1.47	-	80	YES	YES	15.50	
1/25/2017	VH-5	22	1.47	-	80	YES	YES	15.50	
2/2/2017	VH-5	23	1.40	-	80	YES	YES	22.00	
2/9/2017	VH-5	16	1.40	-	80	YES	YES	11.50	
2/15/2017	VH-5	23	1.40	-	80	YES	YES	9.00	
2/22/2017	VH-5	21	1.40	-	80	YES	YES	9.00	
3/3/2017	VH-5	21	1.40	-	80	YES	YES	17.00	
3/9/2017	VH-5	19	1.40	-	80	YES	YES	9.00	
3/16/2017	VH-5	26	1.32	-	80	YES	YES	5.50	
3/31/2017	VH-5	24	1.32	-	80	YES	YES	8.00	



**Atlantic A LS #009A
SVE Monitoring Results
Simcoe LLC**

Date	SVE Point	Exhaust OVM (ppm)	Vacuum Pressure upstream of drum (inHG)	Vacuum Pressure downstream of drum (inHG)	Exhaust Rate (cfm)	System Operational at Arrival	Water Drained	Water Drained (gal)	Comments
4/13/2017	VH-5	28	1.32	-	80	YES	YES	12.00	
4/26/2017	VH-5	19	1.32	-	80	YES	YES	5.00	
5/12/2017	VH-5	16	1.32	-	80	YES	YES	4.00	
6/12/2017	VH-5	22	1.40	-	80	YES	NO	-	Water in drum below drain port
7/11/2017	VH-5	15	1.32	-	80	YES	NO	-	Dry drum
8/14/2017	VH-5	24	1.32	-	80	YES	NO	-	Dry drum
9/15/2017	VH-5	83	1.40	-	80	YES	NO	-	Dry drum
10/13/2017	VH-5	21	1.40	-	80	YES	YES	14.00	
10/25/2017	VH-5	20	1.40	-	80	YES	YES	14.50	
11/10/2017	VH-5	17	1.32	-	80	YES	YES	23.50	
11/22/2017	VH-5	19	1.40	-	80	YES	YES	23.00	
12/8/2017	VH-5	18	1.40	-	80	NO	YES	27.00	High water level shut off unit, drained, restarted, then collected data
12/15/2017	VH-5	14	1.47	-	80	YES	YES	25.50	
12/20/2017	VH-5	16	1.40	-	80	YES	YES	15.50	
1/5/2018	VH-5	16	0.81	-	80	YES	YES	25.50	
1/15/2018	VH-5	16	0.88	-	80	YES	YES	22.00	
1/25/2018	VH-5	8	0.51	-	80	YES	YES	25.50	
2/6/2018	VH-5	10	0.59	-	80	YES	YES	23.00	Collected data, shut down, drained, could not restart
2/26/2018	VH-6	NA	-	-	NA	NO	NO	0.00	Start up initiated, no data collected
3/5/2018	VH-6	182	2.57	-	NA	YES	YES	15.50	Collected data, shut down, drained, could not restart
3/16/2018	VH-6	NA	-	-	NA	NO	NO	-	SVE not operational upon arrival, could not restart
3/24/2018	VH-6	NA	-	-	NA	NO	NO	-	SVE not operational upon arrival, could not restart
4/12/2018	VH-6	242	2.21	-	NA	YES	NO	-	Water in drum below drain port
4/28/2018	VH-6	177	2.28	-	NA	YES	NO	-	Water in drum below drain port
5/14/2018	VH-6	171	2.28	-	NA	YES	NO	-	Dry drum
6/21/2018	VH-6	143	2.28	-	NA	YES	NO	-	Dry drum
7/25/2018	VH-6	114	2.35	-	NA	YES	NO	-	Dry drum
8/21/2018	VH-6	NA	2.35	-	NA	YES	NO	-	Dry drum, PID inoperable
8/30/2018	VH-6	35.6	2.35	-	NA	YES	NO	-	Water in drum below drain port
9/26/2018	VH-6	23.7	2.35	-	NA	YES	NO	-	Dry drum
10/24/2018	VH-6	67	2.50	-	NA	YES	YES	2.50	Collected data, shut down, drained, restarted
11/16/2018	VH-6	72	2.50	-	NA	YES	YES	20.50	Collected data, shut down, drained, restarted
12/4/2018	VH-6	61	2.57	-	NA	YES	NO	0.00	Did not drain drum (ice build up at drain plug)
12/10/2018	VH-6	68	2.65	-	NA	YES	YES	19.00	
12/17/2018	VH-6	71	2.50	-	NA	YES	YES	9.00	
12/24/2018	VH-6	46	2.50	-	NA	YES	NO	0.00	Did not drain drum
12/31/2018	VH-6	51	1.91	-	NA	YES	YES	18.50	
1/14/2019	VH-6	65	2.57	-	NA	YES	YES	21.00	
1/28/2019	VH-6	62	2.57	-	NA	YES	YES	17.00	
2/12/2019	VH-6	63	2.57	-	NA	YES	YES	17.00	
2/27/2019	VH-6	56	2.50	-	NA	YES	YES	20.00	
3/11/2019	VH-6	56	2.50	-	NA	YES	YES	7.00	
3/26/2019	VH-6	48	2.50	-	NA	YES	YES	9.50	
4/17/2019	VH-6	52	2.50	-	NA	YES	YES	5.00	
5/3/2019	VH-6	50	2.50	-	NA	YES	NO	-	Water in drum below drain port, restarted
6/5/2019	VH-6	49	2.43	-	NA	YES	NO	-	Water in drum below drain port, restarted
7/23/2019	VH-6	40	2.50	-	NA	YES	NO	-	Dry drum
8/19/2019	VH-6	30	2.43	-	NA	YES	NO	-	Dry drum
9/17/2019	VH-6	57	2.50	-	NA	YES	NO	-	Dry drum



**Atlantic A LS #009A
SVE Monitoring Results
Simcoe LLC**

Date	SVE Point	Exhaust OVM (ppm)	Vacuum Pressure upstream of drum (inHG)	Vacuum Pressure downstream of drum (inHG)	Exhaust Rate (cfm)	System Operational at Arrival	Water Drained	Water Drained (gal)	Comments
10/8/2019	VH-6	57	2.65	-	NA	NO	NO	-	Switch found in "Off" position, restarted, collected data, dry drum
10/21/2019	VH-6	40	2.57	-	NA	YES	NO	-	Water in drum 1" above drain plug
10/30/2019	VH-6	31	2.65	-	NA	YES	YES	8.00	
11/12/2019	VH-6	NA	2.72	-	NA	YES	YES	-	
12/4/2019	VH-6	34	2.65	-	NA	YES	YES	23.50	
12/20/2019	VH-6	37	2.65	-	NA	YES	YES	19.50	Drained, restarted
1/6/2020	VH-6	NA	-	-	NA	NO	YES	24.50	
1/9/2020	VH-6	NA	2.80	-	NA	YES	NO	-	
1/25/2020	VH-6	44	2.80	-	NA	NO	YES	25.50	Drained, restarted, then collected data
2/14/2020	VH-6	NA	2.50	-	NA	YES	YES	25.50	
2/26/2020	VH-6	37	2.65	-	NA	YES	YES	9.00	
3/13/2020	VH-6	NA	1.69	-	NA	YES	YES	17.00	
3/26/2020	VH-6	35	1.69	-	NA	YES	YES	15.50	
4/20/2020	VH-6	28	2.35	-	NA	YES	NO	-	Dry drum
5/20/2020	VH-6	24	2.50	-	NA	YES	NO	-	Dry drum
6/24/2020	VH-6	14	2.35	-	NA	YES	NO	-	Dry drum
7/29/2020	VH-6	11	2.43	-	NA	YES	NO	-	Dry drum
8/25/2020	VH-6	24	2.50	-	NA	YES	NO	-	Dry drum
9/15/2020	VH-6	21	2.50	-	NA	YES	NO	-	Water in drum below drain port
10/20/2020	VH-6	28	2.50	-	NA	YES	NO	-	Water in drum below drain port
11/3/2020	VH-6	29	2.50	-	NA	YES	YES	7.00	
11/12/2020	VH-6	NA	1.91	-	NA	YES	YES	7.00	
11/16/2020	VH-6	24	2.57	-	NA	YES	NO	-	Water in drum below drain port
11/23/2020	VH-6	NA	2.50	-	NA	YES	YES	7.00	
12/4/2020	VH-6	NA	2.65	-	NA	YES	YES	15.50	
12/14/2020	VH-6	NA	2.72	-	NA	YES	YES	16.00	
1/14/2021	VH-6	26.7	-	-	-	YES	-	-	
2/5/2021	VH-6	11.67	-	-	-	YES	-	-	
3/29/2021	VH-6	12.14	-	-	-	YES	-	-	
4/14/2021	VH-6	194	-	-	-	YES	-	-	
5/7/2021	VH-6	6.52	-	-	-	YES	-	-	
6/8/2021	VH-6	6.48	-	-	-	YES	-	-	
7/13/2021	VH-6	5.17	-	-	-	YES	-	-	
9/29/2021	VH-6	12.0	2.57	3.16	-	YES	NO	-	Dry drum
10/11/2021	VH-6	1,732	2.50	3.16	-	YES	NO	-	Water in drum below drain port
11/6/2021	VH-6	191.2	2.57	3.16	-	YES	YES	9.05	
12/13/2021	VH-6	254	2.80	3.38	-	NO	YES	25.50	Drained, restarted, then collected data
1/4/2022	VH-6	14.8	2.87	3.38	-	NO	YES	24.68	Frozen, restarted system, returned later to drain drum
2/8/2022	VH-6	7.8	2.72	3.24	-	YES	NO	-	Water in drum below drain port
3/7/2022	VH-6	7.7	2.72	3.31	-	YES	NO	-	Drum frozen; Simcoe staff on site to thaw and drain drum.
4/7/2022	VH-6	21.6	2.50	3.09	-	YES	YES	1.65	
5/2/2022	VH-6	42.2	2.50	3.16	-	YES	NO	-	Water in drum below drain port
6/8/2022	VH-6	124.1	2.50	3.09	-	YES	NO	-	
7/5/2022	VH-6	40.3	2.50	3.16	-	YES	NO	-	
8/17/2022	VH-6	9.6	2.50	3.16	-	YES	NO	-	
9/14/2022	VH-6	19.8	2.57	3.16	-	YES	NO	-	
10/12/2022	VH-6	5.0	2.57	3.24	-	YES	NO	-	Water in drum below drain port
11/10/2022	VH-6	7.3	2.72	3.09	-	YES	YES	1.65	
12/14/2022	VH-6	59	2.80	3.38	-	YES	NO	-	Valve on drum was frozen



**Atlantic A LS #009A
SVE Monitoring Results
Simcoe LLC**

Date	SVE Point	Exhaust OVM (ppm)	Vacuum Pressure upstream of drum (inHG)	Vacuum Pressure downstream of drum (inHG)	Exhaust Rate (cfm)	System Operational at Arrival	Water Drained	Water Drained (gal)	Comments
1/10/2023	VH-6	11.1	3.38	2.72	-	YES	YES	6.58	
2/7/2023	VH-6	5.4	2.80	3.46	-	YES	YES	9.05	
3/9/2023	VH-6	5.9	2.65	3.38	-	YES	YES	1.23	
4/6/2023	VH-6	5.1	3.24	2.65	-	YES	NO	-	Drum frozen
5/3/2023	VH-6	38.4	2.57	3.31	-	YES	NO	-	Water in drum below drain port
6/6/2023	VH-6	5.5	3.24	0.0	-	YES	NO	-	
7/7/2023	VH-6	8.0	2.50	3.24	-	YES	NO	-	
8/9/2023	VH-6	7.8	2.57	3.38	-	YES	NO	-	
9/7/2023	VH-6	1.1	2.57	3.38	-	YES	NO	-	
10/18/2023	VH-6	201.5	2.65	3.38	-	YES	NO	-	Water in drum below drain port
11/15/2023	VH-6	2.7	2.65	3.38	-	YES	NO	-	
12/15/2023	VH-6	19.3	2.94	3.68	-	YES	YES	9.87	
1/15/2024	VH-6	6.4	2.80	3.53	-	YES	NO	-	Drum frozen
2/5/2024	VH-6	6.2	-3.75	-3.75	-	YES	YES	13.99	
3/11/2024	VH-6	0.6	3.75	3.75	-	YES	YES	4.11	
4/8/2024	VH-6	66.1	3.75	3.75	-	YES	YES	4.11	
5/6/2024	VH-6	1.3	3.75	3.75	-	YES	NO	-	Water in drum below drain port
6/12/2024	VH-6	3.4	4.0	3.75	-	YES	NO	-	
7/5/2024	VH-6	48.3	3.75	3.75	-	YES	NO	-	
8/7/2024	VH-6	0.2	3.75	3.75	-	YES	NO	-	
9/16/2024	VH-6	12.1	4.5	4.5	-	YES	NO	-	
10/3/2024	VH-6	0.9	3.75	3.75	-	YES	NO	-	
11/11/2024	VH-6	0.8	3.75	3.75	-	YES	YES	49.37	
12/11/2024	VH-6	1.9	4.0	4.0	-	YES	YES	9.87	
1/7/2025	VH-6	0.3	4.0	4.0	-	YES	YES	9.05	
2/19/2025	VH-6	80.6	4.0	4.0	-	YES	YES	14.81	
3/26/2025	VH-6	10.3	3.75	3.75	-	YES	YES	7.41	
4/8/2025	VH-6	7.3	3.75	3.75	-	YES	YES	12.34	
5/13/2025	VH-6	8.5	3.75	3.75	-	YES	NO	-	
6/18/2025	VH-6	3.5	3.75	3.75	-	YES	NO	-	
7/21/2025	VH-6	0.7	3.75	3.75	-	YES	NO	-	
8/11/2025	VH-6	6.8	3.75	3.75	-	YES	NO	-	

Notes:

SVE - soil vapor extraction
OVM - organic vapor meter
ppm - parts per million
in - inches
cfm - cubic feet per minute
gal - gallons
NA - Not Applicable

Sante Fe Main Office
Phone: (505) 476-3441

General Information
Phone: (505) 629-6116

Online Phone Directory
<https://www.emnrd.nm.gov/oed/contact-us>

State of New Mexico
Energy, Minerals and Natural Resources
Oil Conservation Division
1220 S. St Francis Dr.
Santa Fe, NM 87505

CONDITIONS

Action 507292

CONDITIONS

Operator: SIMCOE LLC 1199 Main Ave., Suite 101 Durango, CO 81301	OGRID: 329736
	Action Number: 507292
	Action Type: [REPORT] Alternative Remediation Report (C-141AR)

CONDITIONS

Created By	Condition	Condition Date
michael.buchanan	Biannual SVE Monitoring Report for Atlantic A LS #009A S is approved and placed in the incident file for record.	9/19/2025