

District I  
1625 N. French Dr., Hobbs, NM 88240  
District II  
1301 W. Grand Avenue, Artesia, NM 88210  
District III  
1000 Rio Brazos Road, Aztec, NM 87410  
District IV  
1220 S. St. Francis Dr., Santa Fe, NM 87505

State of New Mexico  
HOBBS OGD  
Energy Minerals and Natural Resources

Oil Conservation Division  
1220 South St. Francis Dr.  
Santa Fe, NM 87505

Form C-141  
Revised October 10, 2003

Submit 2 Copies to appropriate  
District Office in accordance  
with Rule 116 on back  
side of form

RELEASED  
Release Notification and Corrective Action

OPERATOR

Initial Report ☐ Final Report ☒

Name of Company	Southern Union Gas Services, Ltd.	Contact	Crystal Callaway
Address	801 S. Loop 464, Monahans, TX, 79756	Telephone No.	817-302-9407
Facility Name:	West Eunice Compressor Station (RP-2724)	Facility Type	Natural Gas Gathering
Surface Owner	Southern Union Gas Services	Mineral Owner:	API No 30-025-28822

LOCATION OF RELEASE

Unit Letter	Section	Township	Range	Feet from the	North/South Line	Feet from the	East/West Line	County
P	36	21S	36E					Lea

Latitude 32 degrees 25' 45.29" Longitude 103 degrees 12' 38.84"

NATURE OF RELEASE

Type of Release:	Lubricating Oil and Wash Water	Volume of Release	12 BBLS	Volume Recovered	9.5 BBLS
Source of Release:	Sump Tank	Date and Hour of Occurrence	June 12, 2011 -0200 hours	Date and Hour of Discovery	July 13, 2011 - 1000 hours
Was Immediate Notice Given?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Not Required	If YES, To Whom?	NA		
By Whom?	NA	Date and Hour:	NA		
Was a Watercourse Reached?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	If YES, Volume Impacting the Watercourse.			

If a Watercourse was Impacted, Describe Fully.\*

Describe Cause of Problem and Remedial Action Taken:

An overhead bulk lubricating oil tank valve was left open, which resulted in the overfilling of a tank located on the compressor unit. The oil flowed into the compressor unit curbing and into the north sump tank. A pump located on the sump, which should activate and transfer the contents of the sump to the wastewater tank, failed. Due to the failure of the sump pump, the sump overfilled and allowed a mixture of approximately 12 barrels of oil and wash water to impact the ground. A vacuum truck was utilized to recover approximately 9.5 barrels.

Describe Area Affected and Cleanup Action Taken.\*



An area measuring approximately 15 feet in width and 150 feet in length was affected by the release. A backhoe was utilized to scrape up the heavily saturated soil. In sensitive areas of the facility, the saturated soil was "hand dug". Following initial excavation activities the impacted soil was transported to Sundance for disposal.

Confirmation soil samples collected from the West Eunice Compressor Historical Remediation site indicate concentrations of BTEX, TPH and chloride are less than NMOCD Regulatory Statndards.

Please reference the attached Basin Environmental Services Technologies Remediation Summary and Site Closure Request for details of remediation activities.

I hereby certify that the information given above is true and complete to the best of my knowledge and understand that pursuant to NMOCD rules and regulations all operators are required to report and/or file certain release notifications and perform corrective actions for releases, which may endanger public health or the environment. The acceptance of a C-141 report by the NMOCD marked as "Final Report" does not relieve the operator of liability should their operations have failed to adequately investigate and remediate contamination that pose a threat to ground water, surface water, human health or the environment. In addition, NMOCD acceptance of a C-141 report does not relieve the operator of responsibility for compliance with any other federal, state, or local laws and/or regulations.

OIL CONSERVATION DIVISION

Signature:		Approved by District Supervisor:	
Printed Name:	Crystal Callaway		
Title:	Senior Environmental Remediation Specialist	Approval Date:	11-03-14
E-mail Address:	Crystal.Callaway@Regencygas.com	Expiration Date:	
Date:	10/13/2014	Conditions of Approval:	
Phone:	817-302-9407	1RP-2724	

NOV 04 2014

298299  
N701430753798  
P70143075