

GW-063

REPORT

YEAR(S):

2007

RECEIVED

FEB 14 2007



Williams Energy Services-Enve
188 CR 4900
Bloomfield, NM 87413
505/632-4606
505/632-4781 Fax

Oil Conservation Division
1220 S. St. Francis Drive
Santa Fe, NM 87505

February 12, 2007

Mr. Wayne Price
Oil Conservation Division
1220 South St Francis Dr
Santa Fe NM 87505

Re: Drain Line Testing Results at Various Williams Facilities

Dear Mr. Price:

Williams Four Corners, LLC conducted a facility review and drain line testing in accordance with the Oil Conservation Division Discharge Plan requirements. Subsurface, non-pressurized process and wastewater lines were tested. The facility drain line testing reports are enclosed with this letter. A review and testing summary is provided in the table below.

| Facility | Permit # | Completion Date | Results | Comments |
|--------------------|----------|-----------------|---------|-------------------------------|
| 29-6 #3 CDP | | 7/10/2006 | Passed | |
| 29-7 CDP | | 6/26/2006 | Passed | |
| 32-8 #2 CDP | | 9/13/2006 | Passed | Tested site in two sections |
| Coyote Springs | | 6/5/2006 | Passed | |
| Five Points | | 7/20/2006 | Passed | |
| Horse Canyon | | 6/1/2006 | Passed | |
| La Cosa | | 6/7/2006 | Passed | |
| Laguna Seca | | 7/13/2006 | Passed | |
| Lateral N-30 | | 8/4/2006 | Passed | Tested site in two sections |
| Martinez Draw | | 7/18/2006 | Passed | |
| Middle Mesa | | 7/25/2006 | Passed | Tested site in two sections |
| Milagro Plant | | 6/15/2006 | Passed | Tested site in three sections |
| Pritchard Straddle | | 5/24/2006 | Passed | |
| Pump Mesa | | 8/21/2006 | Passed | Tested site in two sections |
| Trunk B | | 8/17/2006 | Passed | |
| Trunk M | | 6/12/2006 | Passed | |
| Wild Horse | | 7/19/2006 | Passed | Visual inspection |

If you have any questions or require additional information, please contact me at (505) 632-4606.

Respectfully Submitted,

Clara M. Cardoza
Environmental Compliance

Attachments: Drain Line Testing Reports

xc: FCA Environmental 220 File
Brandon Powell, OCD Aztec

**Environmental Waste Water Line
Test Report**



| |
|---|
| LOCATION: 29-6 #3 CDP |
| DATE: 7/10/06 |
| Sec, Range Sec. 14 Range 6W and Township T 29 N |

| | | |
|-----------------------|---------------|----------------|
| START OF WATER FILL: | DATE: 7-10-06 | TIME: 10:00 AM |
| START OF TEST PERIOD: | DATE: 7-10-06 | TIME: 2:30 PM |
| END OF TEST PERIOD: | DATE: 7-10-06 | TIME: 3:30 PM |

- TEST DATA:
1. Water height by manual measurement at the datum.
 2. Test to commence when maximum fill is reached and first manual measurement is recorded.
 3. Test time 1 hour at 3lbs

| No. | Time | Water Height | Remarks: |
|-----|--------|--------------|-----------|
| 1 | 2:30pm | 7'6" | Holding |
| 2 | 2:35pm | 7'6" | Holding |
| 3 | 2:40pm | 7'6" | Holding |
| 4 | 2:45pm | 7'6" | Holding |
| 5 | 2:50pm | 7'6" | Holding |
| 6 | 2:55pm | 7'6" | Holding |
| 7 | 3:05pm | 7'6" | Holding |
| 8 | 3:15pm | 7'6" | Holding |
| 9 | 3:25pm | 7'6" | Holding |
| 10 | 3:30pm | 7'6" | Test Held |

Additional Remarks:
 Repaired 3 leaks all on Broken fittings

TEST IS: ACCEPTED REJECTED

RECORDED BY: Ly Cole SUKLANI
(TEST Contractor)

VERIFIED BY: [Signature]
(LOCATION SUPERVISOR)

APPROVED BY: Dwayne Kelly
(Test Inspector)

**Environmental Waste Water Line
Test Report**



| |
|--|
| LOCATION: <u>29-7 CDP</u> |
| DATE: <u>6-26-06</u> |
| Sec, Range <u>Sec 15 Range 7W</u> and Township <u>T 29 N</u> |

| | | |
|-----------------------|----------------------|-----------------------|
| START OF WATER FILL: | DATE: <u>6-22-06</u> | TIME: <u>2:30 PM</u> |
| START OF TEST PERIOD: | DATE: <u>6-26-06</u> | TIME: <u>9:30 AM</u> |
| END OF TEST PERIOD: | DATE: <u>6-26-06</u> | TIME: <u>10:30 AM</u> |

- TEST DATA:
1. Water height by manual measurement at the datum.
 2. Test to commence when maximum fill is reached and first manual measurement is recorded.
 3. Test time 1 hour at 3lbs

| No. | Time | Water Height | Remarks: |
|-----|----------|--------------|-----------|
| 1 | 9:30 AM | 6' 8" | Holding |
| 2 | 9:35 AM | 6' 8" | Holding |
| 3 | 9:40 AM | 6' 8" | Holding |
| 4 | 9:50 AM | 6' 8" | Holding |
| 5 | 10:00 AM | 6' 8" | Holding |
| 6 | 10:10 AM | 6' 8" | Holding |
| 7 | 10:15 AM | 6' 8" | Holding |
| 8 | 10:20 AM | 6' 8" | Holding |
| 9 | 10:25 AM | 6' 8" | Holding |
| 10 | 10:30 AM | 6' 8" | Test Held |

Additional Remarks:

Removed existing isolation valve & installed new 4" brass gate valve at tank.

No leaks were found or fixed

TEST IS: ACCEPTED REJECTED

RECORDED BY: Lyale Sunland
(TEST Contractor)

VERIFIED BY: _____
(LOCATION SUPERVISOR)

APPROVED BY: Dwayne Valdez
(Test Inspector)

Environmental Waste Water Line
Test Report



13 compressors

| |
|--|
| LOCATION: 32-8 #2 COP |
| DATE: 9-13-06 |
| Sec, Range Sec 27 R 8W and Township 32 N |

| | | |
|-----------------------|---------------|----------------|
| START OF WATER FILL: | DATE: 9-12-06 | TIME: 2:00 PM |
| START OF TEST PERIOD: | DATE: 9-13-06 | TIME: 10:50 AM |
| END OF TEST PERIOD: | DATE: 9-13-06 | TIME: 11:50 AM |

TEST DATA:

1. Water height by manual measurement at the datum.
2. Test to commence when maximum fill is reached and first manual measurement is recorded.
3. Test time 1 hour at 3lbs

| No. | Time | Water Height | Remarks: |
|-----|----------|--------------|-----------|
| 1 | 10:50 Am | 6' 2" | Holding |
| 2 | 10:55 Am | 6' 2" | Holding |
| 3 | 11:00 Am | 6' 2" | Holding |
| 4 | 11:05 Am | 6' 2" | Holding |
| 5 | 11:10 Am | 6' 2" | Holding |
| 6 | 11:15 Am | 6' 2" | Holding |
| 7 | 11:25 Am | 6' 2" | Holding |
| 8 | 11:35 Am | 6' 2" | Holding |
| 9 | 11:45 Am | 6' 2" | Holding |
| 10 | 11:50 Am | 6' 2" | Test Held |

Additional Remarks:

4 leaks were found & repaired on the 4" PVC Header

TEST IS: ACCEPTED REJECTED

RECORDED BY:

(TEST Contractor)

VERIFIED BY:

CD H

(LOCATION SUPERVISOR)

APPROVED BY:

Dwayne Valdez

(Test Inspector)

**Environmental Waste Water Line
Test Report**



5 dehydrators

| |
|---|
| LOCATION: 32-8#2 CDP |
| DATE: 8-31-06 |
| Sec, Range Sec 27 R 8 W and Township T 32 N |

| | | |
|-----------------------|---------------|----------------|
| START OF WATER FILL: | DATE: 8-31-06 | TIME: 7:30 AM |
| START OF TEST PERIOD: | DATE: 8-31-06 | TIME: 10:30 AM |
| END OF TEST PERIOD: | DATE: 8-31-06 | TIME: 11:30 AM |

- TEST DATA:
1. Water height by manual measurement at the datum.
 2. Test to commence when maximum fill is reached and first manual measurement is recorded.
 3. Test time 1 hour at 3lbs

| No. | Time | Water Height | Remarks: |
|-----|----------|--------------|------------|
| 1 | 10:30 AM | 6' 8" | Holding |
| 2 | 10:35 AM | 6' 8" | Holding |
| 3 | 10:40 AM | 6' 8" | Holding |
| 4 | 10:45 AM | 6' 8" | Holding |
| 5 | 10:50 AM | 6' 8" | Holding |
| 6 | 10:55 AM | 6' 8" | Holding |
| 7 | 11:00 AM | 6' 8" | Holding |
| 8 | 11:10 AM | 6' 8" | Holding |
| 9 | 11:20 AM | 6' 8" | Holding |
| 10 | 11:30 AM | 6' 8" | Test field |

Additional Remarks:
 5 leaks were found & repaired on 4" Header & 2" laterals

TEST IS: ACCEPTED REJECTED

RECORDED BY: Lynd Sunland
(TEST Contractor)

VERIFIED BY: Ed Hoban
(LOCATION SUPERVISOR)

APPROVED BY: Dwayne Voldez
(Test Inspector)

**Environmental Waste Water Line
Test Report**



| |
|--|
| LOCATION: <i>Coyote Springs Compressor</i> |
| DATE: <i>6-5-06</i> |
| Sec, Range <i>Sec 30 R 11 W</i> and Township <i>T 32 N</i> |

| | | |
|-----------------------|---------------------|-----------------------|
| START OF WATER FILL: | DATE: <i>6-5-06</i> | TIME: <i>9:30 AM</i> |
| START OF TEST PERIOD: | DATE: <i>6-5-06</i> | TIME: <i>10:45 AM</i> |
| END OF TEST PERIOD: | DATE: <i>6-5-06</i> | TIME: <i>11:45 AM</i> |

- TEST DATA:
1. Water height by manual measurement at the datum.
 2. Test to commence when maximum fill is reached and first manual measurement is recorded.
 3. Test time 1 hour at 3lbs

| No. | Time | Water Height | Remarks: |
|-----|-----------------|--------------|------------------|
| 1 | <i>10:45 AM</i> | <i>6' 4"</i> | <i>Holding</i> |
| 2 | <i>10:50 AM</i> | <i>6' 4"</i> | <i>Holding</i> |
| 3 | <i>10:55 AM</i> | <i>6' 4"</i> | <i>Holding</i> |
| 4 | <i>11:05 AM</i> | <i>6' 4"</i> | <i>Holding</i> |
| 5 | <i>11:15 AM</i> | <i>6' 4"</i> | <i>Holding</i> |
| 6 | <i>11:20 AM</i> | <i>6' 4"</i> | <i>Holding</i> |
| 7 | <i>11:30 AM</i> | <i>6' 4"</i> | <i>Holding</i> |
| 8 | <i>11:35 AM</i> | <i>6' 4"</i> | <i>Holding</i> |
| 9 | <i>11:40 AM</i> | <i>6' 4"</i> | <i>Holding</i> |
| 10 | <i>11:45 AM</i> | <i>6' 4"</i> | <i>Test Held</i> |

Additional Remarks:

NO leaks were found or repaired
Good steel system

TEST IS: ACCEPTED REJECTED

RECORDED BY: *Ly Cole* *SUNLAND*
(TEST Contractor)

VERIFIED BY: _____
(LOCATION SUPERVISOR)

APPROVED BY: *Dwayne Valdez*
(Test Inspector)

**Environmental Waste Water Line
Test Report**



| | |
|-------------------------------|-------------------------------|
| LOCATION: | <i>Five Points Compressor</i> |
| DATE: | <i>7-20-06</i> |
| Sec, Range and Township | <i>Sec 8 R 8 W T 25 N</i> |

| | | |
|-----------------------|-----------------------------|------------------------------|
| START OF WATER FILL: | DATE: <u><i>7-20-06</i></u> | TIME: <u><i>9:45 Am</i></u> |
| START OF TEST PERIOD: | DATE: <u><i>7-20-06</i></u> | TIME: <u><i>10:30 Am</i></u> |
| END OF TEST PERIOD: | DATE: <u><i>7-20-06</i></u> | TIME: <u><i>11:30 Am</i></u> |

- TEST DATA:
1. Water height by manual measurement at the datum.
 2. Test to commence when maximum fill is reached and first manual measurement is recorded.
 3. Test time 1 hour at 3lbs

| No. | Time | Water Height | Remarks: |
|-----|-----------------|--------------|------------------|
| 1 | <i>10:30 Am</i> | <i>6' 0"</i> | <i>Holding</i> |
| 2 | <i>10:35 Am</i> | <i>6' 0"</i> | <i>Holding</i> |
| 3 | <i>10:40 Am</i> | <i>6' 0"</i> | <i>Holding</i> |
| 4 | <i>10:45 Am</i> | <i>6' 0"</i> | <i>Holding</i> |
| 5 | <i>10:55 Am</i> | <i>6' 0"</i> | <i>Holding</i> |
| 6 | <i>11:05 Am</i> | <i>6' 0"</i> | <i>Holding</i> |
| 7 | <i>11:15 Am</i> | <i>6' 0"</i> | <i>Holding</i> |
| 8 | <i>11:20 Am</i> | <i>6' 0"</i> | <i>Holding</i> |
| 9 | <i>11:25 Am</i> | <i>6' 0"</i> | <i>Holding</i> |
| 10 | <i>11:30 Am</i> | <i>6' 0"</i> | <i>Test Held</i> |

Additional Remarks:

Installed 2" brass gate valve at tank to isolate piping from tank

NO Leaks found or repaired

Good steel system

TEST IS: ACCEPTED REJECTED

RECORDED BY: *Ly Cole Santani*
(TEST Contractor)

VERIFIED BY: _____
(LOCATION SUPERVISOR)

APPROVED BY: *Dwayne Valdez*
(Test Inspector)

**Environmental Waste Water Line
Test Report**



| |
|---|
| LOCATION: <i>Horse Canyon CDP</i> |
| DATE: <i>6-1-06</i> |
| Sec, Range <i>Sec 27 R 9 W</i> and Township <i>T 30 N</i> |

| | | |
|-----------------------|----------------------|----------------------|
| START OF WATER FILL: | DATE: <i>5/31/06</i> | TIME: <i>9:15 AM</i> |
| START OF TEST PERIOD: | DATE: <i>6/1/06</i> | TIME: <i>1:30 PM</i> |
| END OF TEST PERIOD: | DATE: <i>6/1/06</i> | TIME: <i>2:30 PM</i> |

- TEST DATA:
1. Water height by manual measurement at the datum.
 2. Test to commence when maximum fill is reached and first manual measurement is recorded.
 3. Test time 1 hour at 3lbs

| No. | Time | Water Height | Remarks: |
|-----|--------|--------------|-----------|
| 1 | 1:30pm | 6' 0" | Holding |
| 2 | 1:35pm | 6' 0" | Holding |
| 3 | 1:40pm | 6' 0" | Holding |
| 4 | 1:50pm | 6' 0" | Holding |
| 5 | 2:00pm | 6' 0" | Holding |
| 6 | 2:10pm | 6' 0" | Holding |
| 7 | 2:15pm | 6' 0" | Holding |
| 8 | 2:20pm | 6' 0" | Holding |
| 9 | 2:25pm | 6' 0" | Holding |
| 10 | 2:30pm | 6' 0" | Test Held |

Additional Remarks:

*Repaired 8 leaks on 2" Header & Laterals to Dehydrators
Repaired 4 leaks on 4" Header & laterals to Compressors*

TEST IS: ACCEPTED REJECTED

RECORDED BY: *Suzanne* *SUNAND*
(TEST Contractor)

VERIFIED BY: _____
(LOCATION SUPERVISOR)

APPROVED BY: *Dwayne Valdez*
(Test Inspector)

**Environmental Waste Water Line
Test Report**



| |
|--|
| LOCATION: <u>La Crosse CDP</u> |
| DATE: <u>6-7-06</u> |
| Sec, Range <u>Sec 34 R 11 W</u> and |
| Township <u>T 29 N</u> |

| | | |
|-----------------------|---------------------|-----------------------|
| START OF WATER FILL: | DATE: <u>6-7-06</u> | TIME: <u>7:00 AM</u> |
| START OF TEST PERIOD: | DATE: <u>6-7-06</u> | TIME: <u>10:00 AM</u> |
| END OF TEST PERIOD: | DATE: <u>6-7-06</u> | TIME: <u>11:00 AM</u> |

- TEST DATA:
1. Water height by manual measurement at the datum.
 2. Test to commence when maximum fill is reached and first manual measurement is recorded.
 3. Test time 1 hour at 3lbs

| No. | Time | Water Height | Remarks: |
|-----|----------|--------------|-----------|
| 1 | 10:00 Am | 9' 8" | Holding |
| 2 | 10:05 Am | 9' 8" | Holding |
| 3 | 10:10 Am | 9' 8" | Holding |
| 4 | 10:20 Am | 9' 8" | Holding |
| 5 | 10:30 Am | 9' 8" | Holding |
| 6 | 10:40 Am | 9' 8" | Holding |
| 7 | 10:45 Am | 9' 8" | Holding |
| 8 | 10:50 Am | 9' 8" | Holding |
| 9 | 10:55 Am | 9' 8" | Holding |
| 10 | 11:00 Am | 9' 8" | Test Held |

Additional Remarks:

NO leaks or repairs made to system

4" brass gate valve was installed to isolate piping from tank

TEST IS: ACCEPTED REJECTED

RECORDED BY: Ly Cole Sullivan
(TEST Contractor)

VERIFIED BY: _____
(LOCATION SUPERVISOR)

APPROVED BY: Dwayne Valdez
(Test Inspector)

**Environmental Waste Water Line
Test Report**



| |
|---|
| LOCATION: <u>Laguna Seca Compressor site</u> |
| DATE: <u>7-13-06</u> |
| Sec, Range <u>Sec 19 R 5 W</u> and Township <u>T 31 N</u> |

| | | |
|-----------------------|----------------------|-----------------------|
| START OF WATER FILL: | DATE: <u>7-13-06</u> | TIME: <u>11:00 Am</u> |
| START OF TEST PERIOD: | DATE: <u>7-13-06</u> | TIME: <u>1:30 Pm</u> |
| END OF TEST PERIOD: | DATE: <u>7-13-06</u> | TIME: <u>2:30 Pm</u> |

- TEST DATA:
1. Water height by manual measurement at the datum.
 2. Test to commence when maximum fill is reached and first manual measurement is recorded.
 3. Test time 1 hour at 3lbs

| No. | Time | Water Height | Remarks: |
|-----|---------|--------------|-----------|
| 1 | 1:30 Pm | 10' 0" | Holding |
| 2 | 1:35 Pm | 10' 0" | Holding |
| 3 | 1:40 Pm | 10' 0" | Holding |
| 4 | 1:45 Pm | 10' 0" | Holding |
| 5 | 1:50 Pm | 10' 0" | Holding |
| 6 | 1:55 Pm | 10' 0" | Holding |
| 7 | 2:10 Pm | 10' 0" | Holding |
| 8 | 2:15 Pm | 10' 0" | Holding |
| 9 | 2:25 Pm | 10' 0" | Holding |
| 10 | 2:30 Pm | 10' 0" | Test Held |

Additional Remarks:

Installed 4" brass gate valve at tank to isolate piping from tank

NO leaks found or repaired

Good steel system

TEST IS: ACCEPTED REJECTED

RECORDED BY: Ag. Ch. SUIANO
(TEST CONTRACTOR)

VERIFIED BY: _____
(LOCATION SUPERVISOR)

APPROVED BY: Dwayne Valdez
(TEST INSPECTOR)

**Environmental Waste Water Line
Test Report**



Compressor #6

| |
|--|
| LOCATION: <i>Lateral N-30 Compressor station</i> |
| DATE: <i>8-4-06</i> |
| Sec, Range <i>Sec 25 R 9W</i> and Township <i>T 32 N</i> |

| | | |
|-----------------------|---------------------|-----------------------|
| START OF WATER FILL: | DATE: <i>8-4-06</i> | TIME: <i>8:00 Am</i> |
| START OF TEST PERIOD: | DATE: <i>8-4-06</i> | TIME: <i>10:00 Am</i> |
| END OF TEST PERIOD: | DATE: <i>8-4-06</i> | TIME: <i>11:00 Am</i> |

- TEST DATA:
1. Water height by manual measurement at the datum.
 2. Test to commence when maximum fill is reached and first manual measurement is recorded.
 3. Test time 1 hour at 3lbs

| No. | Time | Water Height | Remarks: |
|-----|-----------------|--------------|------------------|
| 1 | <i>10:00 Am</i> | <i>6' 0"</i> | <i>Holding</i> |
| 2 | <i>10:05 Am</i> | <i>6' 0"</i> | <i>Holding</i> |
| 3 | <i>10:10 Am</i> | <i>6' 0"</i> | <i>Holding</i> |
| 4 | <i>10:15 Am</i> | <i>6' 0"</i> | <i>Holding</i> |
| 5 | <i>10:20 Am</i> | <i>6' 0"</i> | <i>Holding</i> |
| 6 | <i>10:25 Am</i> | <i>6' 0"</i> | <i>Holding</i> |
| 7 | <i>10:30 Am</i> | <i>6' 0"</i> | <i>Holding</i> |
| 8 | <i>10:40 Am</i> | <i>6' 0"</i> | <i>Holding</i> |
| 9 | <i>10:50 Am</i> | <i>6' 0"</i> | <i>Holding</i> |
| 10 | <i>11:00 Am</i> | <i>6' 0"</i> | <i>Test Held</i> |

Additional Remarks:

No leaks were found or repaired

Good steel system

TEST IS: ACCEPTED REJECTED

RECORDED BY: *Ly Cole* *Susano*
(TEST Contractor)

VERIFIED BY: _____
(LOCATION SUPERVISOR)

APPROVED BY: *Dwayne Valde*
(Test Inspector)

**Environmental Waste Water Line
Test Report**



Compressors 1-5 & 3 dehydrators

| | |
|-------------------------------|-------------------------------|
| LOCATION: | <i>Lateral N-30</i> |
| DATE: | <i>8-11-06</i> |
| Sec, Range and Township | <i>Sec 25 R 9W T 32 N</i> |

| | | |
|-----------------------|----------------------|-----------------------|
| START OF WATER FILL: | DATE: <i>8-10-06</i> | TIME: <i>11:00 AM</i> |
| START OF TEST PERIOD: | DATE: <i>8-11-06</i> | TIME: <i>10:30 AM</i> |
| END OF TEST PERIOD: | DATE: <i>8-11-06</i> | TIME: <i>11:30 AM</i> |

- TEST DATA:
1. Water height by manual measurement at the datum.
 2. Test to commence when maximum fill is reached and first manual measurement is recorded.
 3. Test time 1 hour at 3lbs

| No. | Time | Water Height | Remarks: |
|-----|-----------------|--------------|------------------|
| 1 | <i>10:30 AM</i> | <i>6' 4"</i> | <i>Holding</i> |
| 2 | <i>10:35 AM</i> | <i>6' 4"</i> | <i>Holding</i> |
| 3 | <i>10:40 AM</i> | <i>6' 4"</i> | <i>Holding</i> |
| 4 | <i>10:45 AM</i> | <i>6' 4"</i> | <i>Holding</i> |
| 5 | <i>10:50 AM</i> | <i>6' 4"</i> | <i>Holding</i> |
| 6 | <i>10:55 AM</i> | <i>6' 4"</i> | <i>Holding</i> |
| 7 | <i>11:00 AM</i> | <i>6' 4"</i> | <i>Holding</i> |
| 8 | <i>11:10 AM</i> | <i>6' 4"</i> | <i>Holding</i> |
| 9 | <i>11:20 AM</i> | <i>6' 4"</i> | <i>Holding</i> |
| 10 | <i>11:30 AM</i> | <i>6' 4"</i> | <i>Test Held</i> |

Additional Remarks:

*Repaired 6 leaks, all on PVC piping
No leaks on steel portion of system*

TEST IS: ACCEPTED REJECTED

RECORDED BY: *Lg Cole Sunland*
(TEST Contractor)

VERIFIED BY: _____
(LOCATION SUPERVISOR)

APPROVED BY: *Dwayne Valdez*
(Test Inspector)

**Environmental Waste Water Line
Test Report**



| |
|---|
| LOCATION: <i>Martinez Draw</i> |
| DATE: <i>7-18-06</i> |
| Sec, Range <i>Sec 17 R 5 W</i> and Township <i>T 31 N</i> |

| | | |
|-----------------------|----------------------|-----------------------|
| START OF WATER FILL: | DATE: <i>7-17-06</i> | TIME: <i>1:45 PM</i> |
| START OF TEST PERIOD: | DATE: <i>7-18-06</i> | TIME: <i>9:30 AM</i> |
| END OF TEST PERIOD: | DATE: <i>7-18-06</i> | TIME: <i>10:30 AM</i> |

- TEST DATA:
1. Water height by manual measurement at the datum.
 2. Test to commence when maximum fill is reached and first manual measurement is recorded.
 3. Test time 1 hour at 3lbs

| No. | Time | Water Height | Remarks: |
|-----|----------|--------------|-----------|
| 1 | 9:30 AM | 6' 11" | Holding |
| 2 | 9:35 AM | 6' 11" | Holding |
| 3 | 9:40 AM | 6' 11" | Holding |
| 4 | 9:45 AM | 6' 11" | Holding |
| 5 | 9:50 AM | 6' 11" | Holding |
| 6 | 9:55 AM | 6' 11" | Holding |
| 7 | 10:05 AM | 6' 11" | Holding |
| 8 | 10:15 AM | 6' 11" | Holding |
| 9 | 10:25 AM | 6' 11" | Holding |
| 10 | 10:30 AM | 6' 11" | Test Held |

Additional Remarks:

*Repaired 1 leak above ground
Good steel system*

*Installed a 4" brass gate valve at tank to isolate
system from tank*

TEST IS: ACCEPTED REJECTED

RECORDED BY: *Lyndal Sunland*
(TEST Contractor)

VERIFIED BY: _____
(LOCATION SUPERVISOR)

APPROVED BY: *Dwayne Valdez*
(Test Inspector)

**Environmental Waste Water Line
Test Report**



Compressors 1 thru 9 & 6 Dehydrators

| |
|---------------------------------------|
| LOCATION: <i>Middle Mesa CDP</i> |
| DATE: <i>7-25-06</i> |
| Sec, Range <i>Sec. 10 R 7W</i> and |
| Township <i>T 31 N</i> |

| | | |
|-----------------------|----------------------|-----------------------|
| START OF WATER FILL: | DATE: <i>7-24-06</i> | TIME: <i>11:30 AM</i> |
| START OF TEST PERIOD: | DATE: <i>7-25-06</i> | TIME: <i>9:30 AM</i> |
| END OF TEST PERIOD: | DATE: <i>7-25-06</i> | TIME: <i>10:30 AM</i> |

- TEST DATA:
1. Water height by manual measurement at the datum.
 2. Test to commence when maximum fill is reached and first manual measurement is recorded.
 3. Test time 1 hour at 3lbs

| No. | Time | Water Height | Remarks: |
|-----|-----------------|--------------|------------------|
| 1 | <i>9:30 AM</i> | <i>8' 3"</i> | <i>Holding</i> |
| 2 | <i>9:35 AM</i> | <i>8' 3"</i> | <i>Holding</i> |
| 3 | <i>9:40 AM</i> | <i>8' 3"</i> | <i>Holding</i> |
| 4 | <i>9:45 AM</i> | <i>8' 3"</i> | <i>Holding</i> |
| 5 | <i>9:50 AM</i> | <i>8' 3"</i> | <i>Holding</i> |
| 6 | <i>10:00 AM</i> | <i>8' 3"</i> | <i>Holding</i> |
| 7 | <i>10:10 AM</i> | <i>8' 3"</i> | <i>Holding</i> |
| 8 | <i>10:20 AM</i> | <i>8' 3"</i> | <i>Holding</i> |
| 9 | <i>10:25 AM</i> | <i>8' 3"</i> | <i>Holding</i> |
| 10 | <i>10:30 AM</i> | <i>8' 3"</i> | <i>Test Held</i> |

Additional Remarks:

Repaired 2 leaks found on Dehy #1 & Dehy #3

TEST IS: ACCEPTED REJECTED

RECORDED BY: *GARY COLE* *Dunkard*
(TEST CONTRACTOR)

VERIFIED BY: *Charlie Lane*
(LOCATION SUPERVISOR)

APPROVED BY: *Darayne Valdez*
(TEST INSPECTOR)

**Environmental Waste Water Line
Test Report**



7 Straddle compressors

| | |
|-------------------------------|--------------------|
| LOCATION: | Middle Mesa COP |
| DATE: | 7-28-06 |
| Sec, Range and Township | Sec 10 R7W T31N |

| | | |
|-----------------------|---------------|----------------|
| START OF WATER FILL: | DATE: 7-27-06 | TIME: 2:30 PM |
| START OF TEST PERIOD: | DATE: 7-28-06 | TIME: 10:30 AM |
| END OF TEST PERIOD: | DATE: 7-28-06 | TIME: 11:30 AM |

- TEST DATA:
1. Water height by manual measurement at the datum.
 2. Test to commence when maximum fill is reached and first manual measurement is recorded.
 3. Test time 1 hour at 3lbs

| No. | Time | Water Height | Remarks: |
|-----|----------|--------------|-----------|
| 1 | 10:30 AM | 6' 7" | Holding |
| 2 | 10:35 AM | 6' 7" | Holding |
| 3 | 10:40 AM | 6' 7" | Holding |
| 4 | 10:45 AM | 6' 7" | Holding |
| 5 | 10:50 AM | 6' 7" | Holding |
| 6 | 11:00 AM | 6' 7" | Holding |
| 7 | 11:10 AM | 6' 7" | Holding |
| 8 | 11:20 AM | 6' 7" | Holding |
| 9 | 11:25 AM | 6' 7" | Holding |
| 10 | 11:30 AM | 6' 7" | Test Held |

Additional Remarks:

NO leaks were found or repaired
Good steel system

A 4" brass gate valve was installed at fiberglass tank & another 4" brass gate valve was installed above ground at the steel tank for isolation of piping to tanks

TEST IS: ACCEPTED REJECTED

RECORDED BY: GARY COLE SUNLAND
(TEST Contractor)

VERIFIED BY: _____
(LOCATION SUPERVISOR)

APPROVED BY: Dwayne Valle
(Test Inspector)

**Environmental Waste Water Line
Test Report**



Train 5

| |
|----------------------------------|
| LOCATION: <i>Milagro Plant</i> |
| DATE: <i>6-15-06</i> |
| Sec, Range <i>Sec. 12 A 11 W</i> |
| and Township <i>29 N</i> |

| | | |
|--------------------------------|----------------------|-----------------------|
| START OF WATER FILL: | DATE: <i>6-13-06</i> | TIME: <i>11:00 Am</i> |
| START OF TEST PERIOD: | DATE: <i>6-15-06</i> | TIME: <i>12:30 Pm</i> |
| END OF TEST PERIOD: | DATE: <i>6-15-06</i> | TIME: <i>1:30 Pm</i> |

- TEST DATA:
1. Water height by manual measurement at the datum.
 2. Test to commence when maximum fill is reached and first manual measurement is recorded.
 3. Test time 1 hour at 3lbs

| No. | Time | Water Height | Remarks: |
|-----|-----------------|--------------|------------------|
| 1 | <i>12:30 Pm</i> | <i>6' 0"</i> | <i>Holding</i> |
| 2 | <i>12:35 Pm</i> | <i>6' 0"</i> | <i>Holding</i> |
| 3 | <i>12:40 Pm</i> | <i>6' 0"</i> | <i>Holding</i> |
| 4 | <i>12:45 Pm</i> | <i>6' 0"</i> | <i>Holding</i> |
| 5 | <i>12:55 Pm</i> | <i>6' 0"</i> | <i>Holding</i> |
| 6 | <i>1:05 Pm</i> | <i>6' 0"</i> | <i>Holding</i> |
| 7 | <i>1:15 Pm</i> | <i>6' 0"</i> | <i>Holding</i> |
| 8 | <i>1:20 Pm</i> | <i>6' 0"</i> | <i>Holding</i> |
| 9 | <i>1:25 Pm</i> | <i>6' 0"</i> | <i>Holding</i> |
| 10 | <i>1:30 Pm</i> | <i>6' 0"</i> | <i>Test Held</i> |

| |
|---|
| Additional Remarks: |
| <i>No leaks found or repaired</i> |
| <i>good steel system</i> |
| <i>Test on Train 5 Laterals & 6" Header</i> |
| |
| |

TEST IS: ACCEPTED REJECTED

RECORDED BY: *GARY COLE SunLAND*
(TEST Contractor)

VERIFIED BY: _____
(LOCATION SUPERVISOR)

APPROVED BY: *Dwayne Valdez*
(Test Inspector)

**Environmental Waste Water Line
Test Report**



Trains 1, 2, 3 & 4 + Dehydrators & Boilers

| |
|--------------------------------|
| LOCATION: <i>Milagro Plant</i> |
| DATE: <i>6-20-06</i> |
| Sec, Range and Township |

| | | |
|-----------------------|----------------------|-----------------------|
| START OF WATER FILL: | DATE: <i>6-16-06</i> | TIME: <i>10:00 AM</i> |
| START OF TEST PERIOD: | DATE: <i>6-20-06</i> | TIME: <i>12:30 PM</i> |
| END OF TEST PERIOD: | DATE: <i>6-20-06</i> | TIME: <i>1:30 PM</i> |

- TEST DATA:
1. Water height by manual measurement at the datum.
 2. Test to commence when maximum fill is reached and first manual measurement is recorded.
 3. Test time 1 hour at 3lbs

| No. | Time | Water Height | Remarks: |
|-----|-----------------|---------------|------------------|
| 1 | <i>12:30 PM</i> | <i>19' 0"</i> | <i>Holding</i> |
| 2 | <i>12:35 PM</i> | <i>19' 0"</i> | <i>Holding</i> |
| 3 | <i>12:40 PM</i> | <i>19' 0"</i> | <i>Holding</i> |
| 4 | <i>12:50 PM</i> | <i>19' 0"</i> | <i>Holding</i> |
| 5 | <i>12:55 PM</i> | <i>19' 0"</i> | <i>Holding</i> |
| 6 | <i>1:00 PM</i> | <i>19' 0"</i> | <i>Holding</i> |
| 7 | <i>1:10 PM</i> | <i>19' 0"</i> | <i>Holding</i> |
| 8 | <i>1:20 PM</i> | <i>19' 0"</i> | <i>Holding</i> |
| 9 | <i>1:25 PM</i> | <i>19' 0"</i> | <i>Holding</i> |
| 10 | <i>1:30 PM</i> | <i>19' 0"</i> | <i>Test Held</i> |

Additional Remarks:

NO Leaks found or repaired

Good steel system

6" steel gate valve installed in collection Box for isolation

Laterals & headers for trains 1, 2, 3, & 4

Laterals & header for dehydrators & Bailer

TEST IS: ACCEPTED REJECTED

RECORDED BY: *GARY COLE* *SUNLAND*
(TEST Contractor)

VERIFIED BY: _____
(LOCATION SUPERVISOR)

APPROVED BY: *Dwayne Valdez*
(Test Inspector)

**Environmental Waste Water Line
Test Report**



Filter Drain System Train 5

| | |
|-------------------------------|-----------------------------|
| LOCATION: | <i>Milagro Plant</i> |
| DATE: | <i>6-30-06</i> |
| Sec, Range and Township | <i>Sec 12 R11W 29 N</i> |

| | | |
|-----------------------|----------------------|----------------------|
| START OF WATER FILL: | DATE: <i>6-30-06</i> | TIME: <i>9:45 AM</i> |
| START OF TEST PERIOD: | DATE: <i>6-30-06</i> | TIME: <i>1:15 PM</i> |
| END OF TEST PERIOD: | DATE: <i>6-30-06</i> | TIME: <i>2:15 PM</i> |

- TEST DATA:
1. Water height by manual measurement at the datum.
 2. Test to commence when maximum fill is reached and first manual measurement is recorded.
 3. Test time 1 hour at 3lbs

| No. | Time | Water Height | Remarks: |
|-----|----------------|--------------|------------------|
| 1 | <i>1:15 PM</i> | <i>6' 0"</i> | <i>Holding</i> |
| 2 | <i>1:20 PM</i> | <i>6' 0"</i> | <i>Holding</i> |
| 3 | <i>1:25 PM</i> | <i>6' 0"</i> | <i>Holding</i> |
| 4 | <i>1:30 PM</i> | <i>6' 0"</i> | <i>Holding</i> |
| 5 | <i>1:40 PM</i> | <i>6' 0"</i> | <i>Holding</i> |
| 6 | <i>1:45 PM</i> | <i>6' 0"</i> | <i>Holding</i> |
| 7 | <i>1:55 PM</i> | <i>6' 0"</i> | <i>Holding</i> |
| 8 | <i>2:05</i> | <i>6' 0"</i> | <i>Holding</i> |
| 9 | <i>2:10 PM</i> | <i>6' 0"</i> | <i>Holding</i> |
| 10 | <i>2:15 PM</i> | <i>6' 0"</i> | <i>Test Held</i> |

Additional Remarks:

NO leaks were found or repaired

Good steel system

Inlet filter drain system for train 5

TEST IS: ACCEPTED REJECTED

RECORDED BY: *SUNLAND* *Ly Cole*
(TEST CONTRACTOR)

VERIFIED BY: *David D. Jones*
(LOCATION SUPERVISOR)

APPROVED BY: *Dwayne Valdez*
(TEST INSPECTOR)

Environmental Waste Water Line
Test Report



| |
|---|
| LOCATION: <i>Prichard Straddle</i> |
| DATE: <i>5-24-06</i> |
| Sec. Range <i>Sec. 1 R9W</i> and Township <i>T 30 N</i> |

| | | |
|-----------------------|----------------------|----------------------|
| START OF WATER FILL: | DATE: <i>5-23-06</i> | TIME: <i>8:00 AM</i> |
| START OF TEST PERIOD: | DATE: <i>5-24-06</i> | TIME: <i>8:00 AM</i> |
| END OF TEST PERIOD: | DATE: <i>5-24-06</i> | TIME: <i>9:00 AM</i> |

- TEST DATA:
1. Water height by manual measurement at the datum.
 2. Test to commence when maximum fill is reached and first manual measurement is recorded.
 3. Test time 1 hour at 3lbs

| No. | Time | Water Height | Remarks: |
|-----|---------|--------------|-----------|
| 1 | 8:00 AM | 6' 8" | Holding |
| 2 | 8:05 AM | 6' 8" | Holding |
| 3 | 8:10 AM | 6' 8" | Holding |
| 4 | 8:20 AM | 6' 8" | Holding |
| 5 | 8:30 AM | 6' 8" | Holding |
| 6 | 8:35 AM | 6' 8" | Holding |
| 7 | 8:45 AM | 6' 5" | Holding |
| 8 | 8:50 AM | 6' 8" | Holding |
| 9 | 8:55 AM | 6' 8" | Holding |
| 10 | 9:00 AM | 6' 8" | Test Held |

Additional Remarks:

Repaired 1 leak on a 2" Flang on Compressor pad #2

TEST IS: ACCEPTED REJECTED

RECORDED BY: *Log Cole* *SUNLAND*
(TEST Contractor)

VERIFIED BY: _____
(LOCATION SUPERVISOR)

APPROVED BY: *Dwayne Valdy*
(Test Inspector)

**Environmental Waste Water Line
Test Report**



2 compressors & 3 dehy's North Lower section

| | |
|-------------------------|---------------------------------|
| LOCATION: | <i>Pump Mesa CDP</i> |
| DATE: | <i>8-21-06</i> |
| Sec. Range and Township | <i>Sec. 14 R 8 W T 31 N</i> |

| | | |
|-----------------------|----------------------|----------------------|
| START OF WATER FILL: | DATE: <i>8-21-06</i> | TIME: <i>7:30 AM</i> |
| START OF TEST PERIOD: | DATE: <i>8-21-06</i> | TIME: <i>1:00 PM</i> |
| END OF TEST PERIOD: | DATE: <i>8-21-06</i> | TIME: <i>2:00 PM</i> |

- TEST DATA:
1. Water height by manual measurement at the datum.
 2. Test to commence when maximum fill is reached and first manual measurement is recorded.
 3. Test time 1 hour at 3lbs

| No. | Time | Water Height | Remarks: |
|-----|----------------|---------------|------------------|
| 1 | <i>1:00 PM</i> | <i>9' 10"</i> | <i>Holding</i> |
| 2 | <i>1:05 PM</i> | <i>9' 10"</i> | <i>Holding</i> |
| 3 | <i>1:10 PM</i> | <i>9' 10"</i> | <i>Holding</i> |
| 4 | <i>1:15 PM</i> | <i>9' 10"</i> | <i>Holding</i> |
| 5 | <i>1:20 PM</i> | <i>9' 10"</i> | <i>Holding</i> |
| 6 | <i>1:25 PM</i> | <i>9' 10"</i> | <i>Holding</i> |
| 7 | <i>1:30 PM</i> | <i>9' 10"</i> | <i>Holding</i> |
| 8 | <i>1:40 PM</i> | <i>9' 10"</i> | <i>Holding</i> |
| 9 | <i>1:50 PM</i> | <i>9' 10"</i> | <i>Holding</i> |
| 10 | <i>2:00 PM</i> | <i>9' 10"</i> | <i>Test Held</i> |

Additional Remarks:

NO leaks were found or repaired

North Lower section of site

TEST IS: ACCEPTED REJECTED

RECORDED BY: *Styckle Sunland*
(TEST Contractor)

VERIFIED BY: *Ed Hoban*
(LOCATION SUPERVISOR)

APPROVED BY: *Dwayne Valdez*
(Test Inspector)

**Environmental Waste Water Line
Test Report**



8 compressors & 2 dehydrators Upper South side

| | |
|-------------------------------|--------------------------------|
| LOCATION: | <i>Pump Mesa COP</i> |
| DATE: | <i>8-23-06</i> |
| Sec, Range and Township | <i>Sec 14 R 8 W T 31 N</i> |

| | | |
|-----------------------|----------------------|-----------------------|
| START OF WATER FILL: | DATE: <i>8-22-06</i> | TIME: <i>8:00 AM</i> |
| START OF TEST PERIOD: | DATE: <i>8-23-06</i> | TIME: <i>9:00 AM</i> |
| END OF TEST PERIOD: | DATE: <i>8-23-06</i> | TIME: <i>10:00 AM</i> |

- TEST DATA:
1. Water height by manual measurement at the datum.
 2. Test to commence when maximum fill is reached and first manual measurement is recorded.
 3. Test time 1 hour at 3lbs

| No. | Time | Water Height | Remarks: |
|-----|-----------------|--------------|------------------|
| 1 | <i>9:00 AM</i> | <i>6' 0"</i> | <i>Holding</i> |
| 2 | <i>9:05 AM</i> | <i>6' 0"</i> | <i>Holding</i> |
| 3 | <i>9:10 AM</i> | <i>6' 0"</i> | <i>Holding</i> |
| 4 | <i>9:15 AM</i> | <i>6' 0"</i> | <i>Holding</i> |
| 5 | <i>9:20 AM</i> | <i>6' 0"</i> | <i>Holding</i> |
| 6 | <i>9:25 AM</i> | <i>6' 0"</i> | <i>Holding</i> |
| 7 | <i>9:30 AM</i> | <i>6' 0"</i> | <i>Holding</i> |
| 8 | <i>9:40 AM</i> | <i>6' 0"</i> | <i>Holding</i> |
| 9 | <i>9:50 AM</i> | <i>6' 0"</i> | <i>Holding</i> |
| 10 | <i>10:00 AM</i> | <i>6' 0"</i> | <i>Test Held</i> |

Additional Remarks:

NO Leaks were found or repaired

TEST IS: ACCEPTED REJECTED

RECORDED BY: *GARY Cole Sunkard*
(TEST Contractor)

VERIFIED BY: *[Signature]*
(LOCATION SUPERVISOR)

APPROVED BY: *Dwayne Valdez*
(Test Inspector)

**Environmental Waste Water Line
Test Report**



| |
|---|
| LOCATION: <u>Trunk B Booster</u> |
| DATE: <u>8-17-06</u> |
| Sec, Range <u>Sec. 28 R 8W</u> and Township <u>31 N</u> |

| | | |
|-----------------------|----------------------|-----------------------|
| START OF WATER FILL: | DATE: <u>8-17-06</u> | TIME: <u>8:00 AM</u> |
| START OF TEST PERIOD: | DATE: <u>8-17-06</u> | TIME: <u>10:50 AM</u> |
| END OF TEST PERIOD: | DATE: <u>8-17-06</u> | TIME: <u>11:50 AM</u> |

- TEST DATA:
1. Water height by manual measurement at the datum.
 2. Test to commence when maximum fill is reached and first manual measurement is recorded.
 3. Test time 1 hour at 3lbs

| No. | Time | Water Height | Remarks: |
|-----|----------|--------------|-----------|
| 1 | 10:50 AM | 6' 9" | Holding |
| 2 | 10:55 AM | 6' 9" | Holding |
| 3 | 11:00 AM | 6' 9" | Holding |
| 4 | 11:05 AM | 6' 9" | Holding |
| 5 | 11:10 AM | 6' 9" | Holding |
| 6 | 11:15 AM | 6' 9" | Holding |
| 7 | 11:25 AM | 6' 9" | Holding |
| 8 | 11:35 AM | 6' 9" | Holding |
| 9 | 11:45 AM | 6' 9" | Holding |
| 10 | 11:50 AM | 6' 9" | Test Held |

Additional Remarks:

Installed 4" brass gate Valve at tank to isolate piping from tank

No leaks were found or repaired

TEST IS: ACCEPTED REJECTED

RECORDED BY: [Signature]
(TEST CONTRACTOR)

VERIFIED BY: [Signature]
(LOCATION SUPERVISOR)

APPROVED BY: [Signature]
(TEST INSPECTOR)

**Environmental Waste Water Line
Test Report**



| |
|---|
| LOCATION: <u>Trunk M CDP</u> |
| DATE: <u>6-12-06</u> |
| Sec, Range <u>Sec 29 R 6 W</u> and Township <u>T 30 N</u> |

| | | |
|-----------------------|----------------------|-----------------------|
| START OF WATER FILL: | DATE: <u>6-8-06</u> | TIME: <u>10:30 AM</u> |
| START OF TEST PERIOD: | DATE: <u>6-12-06</u> | TIME: <u>8:25 AM</u> |
| END OF TEST PERIOD: | DATE: <u>6-12-06</u> | TIME: <u>9:25 AM</u> |

- TEST DATA:
1. Water height by manual measurement at the datum.
 2. Test to commence when maximum fill is reached and first manual measurement is recorded.
 3. Test time 1 hour at 3lbs

| No. | Time | Water Height | Remarks: |
|-----|---------|--------------|-----------|
| 1 | 8:25 AM | 6' 4" | Holding |
| 2 | 8:30 AM | 6' 4" | Holding |
| 3 | 8:35 AM | 6' 4" | Holding |
| 4 | 8:45 AM | 6' 4" | Holding |
| 5 | 8:55 AM | 6' 4" | Holding |
| 6 | 9:00 AM | 6' 4" | Holding |
| 7 | 9:10 AM | 6' 4" | Holding |
| 8 | 9:15 AM | 6' 4" | Holding |
| 9 | 9:20 AM | 6' 4" | Holding |
| 10 | 9:25 AM | 6' 4" | Test Hold |

Additional Remarks:

Repaired 5 leaks total on compressor pads, Hot start pad, & Day tank pad

TEST IS: ACCEPTED REJECTED

RECORDED BY: Laycab Sunkard
(TEST Contractor)

VERIFIED BY: _____
(LOCATION SUPERVISOR)

APPROVED BY: Dwayne Valdez
(Test Inspector)

**Environmental Waste Water Line
Test Report**



| |
|---|
| LOCATION: <i>Wild Horse Compressor</i> |
| DATE: <i>7-19-06</i> |
| Sec, Range <i>Sec 27 Range 4 W</i> and |
| Township <i>T 26 N</i> |

| | | |
|-----------------------|-------------|-------------|
| START OF WATER FILL: | DATE: _____ | TIME: _____ |
| START OF TEST PERIOD: | DATE: _____ | TIME: _____ |
| END OF TEST PERIOD: | DATE: _____ | TIME: _____ |

- TEST DATA:
1. Water height by manual measurement at the datum.
 2. Test to commence when maximum fill is reached and first manual measurement is recorded.
 3. Test time 1 hour at 3lbs

| No. | Time | Water Height | Remarks: |
|-----|------|--------------|----------|
| 1 | | | |
| 2 | | | |
| 3 | | | |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |

Additional Remarks:

Wild Horse Compressor station has one compressor with 3' of steel pipe that is 6" deep. Hand dug all piping & performed a visual inspection.

Replaced threaded collar on skid drain with a stainless steel repair clamp & wrapped line with polyken tape.

TEST IS: ACCEPTED REJECTED

RECORDED BY: _____
(TEST Contractor)

VERIFIED BY: _____
(LOCATION SUPERVISOR)

APPROVED BY: *Dwayne Vold*
(Test Inspector)