

GW – 093

**GENERAL
CORRESPONDENCE**

YEAR(S): 2008 - 2013

Lowe, Leonard, EMNRD

From: Lowe, Leonard, EMNRD
Sent: Thursday, October 16, 2008 3:32 PM
To: 'Wurtz, Jack G'
Subject: GW-093, Rattlesnake Compressor Station

Mr. Gregg Wurtz,

Good afternoon.

I have a few questions pertaining to the Rattlesnake Compressor Station, GW-093.

1. Your process sump (*T-8, noted on last submitted facility schematic*) can you provide the following information for this sump?
 - What fluids are usually contained in this sump (waste water, etc.)?
 - Does the sump contain fluids indefinitely (yes/no)?
 - What is the volumetric capacity (gals)?
 - Does this sump have a secondary containment with leak detection (tank within a tank, visual or sensor detection)?
2. At the time of permit renewal OCD was made aware of a business ownership change from Burlington to ConocoPhillips. Who is the "owner" of this permit? Please submit a notification to the OCD of this status.
3. According to our records the last time this facility had an inspection of its sump and lines was on September 2001. These are tested every five years. If they were done please submit to the OCD the results of these test.
4. How many discharge permits does Burlington have? Please provide the GW numbers and name of these facilities.
5. What is the status of putting liners under all your unlined AST's at this facility?

Thank you for your attention.

llowe

Leonard Lowe

Environmental Engineer
Oil Conservation Division/EMNRD
1220 S. St. Francis Drive
Santa Fe, N.M. 87505
Office: 505-476-3492
Fax: 505-476-3462
E-mail: leonard.lowe@state.nm.us
Website: <http://www.emnrd.state.nm.us/ocd/>