



DCP Midstream
10 Desta Drive, Suite 400 West
Midland, TX 79705

JUL -9 2009

July 7, 2009

State of New Mexico Oil Conservation Division
Region II

via certified mail 7008 3230 0002 0986 0512

Attn: Gerry Guye
1301 W. Grand Ave.
Artesia, New Mexico 88210

30-015-25271

**RE: Monthly AGI Readings
Artesia Gas Plant Gas Injection Well**

To Whom it May Concern:

Enclosed are monthly readings for the Acid Gas Injection well at Artesia Gas Plant for the month of June 2009. These are being submitted on a monthly basis due to the request by the OCD in lieu of the requirement to perform a yearly mechanical integrity test on the well. DCP Midstream LP (DCPM) understands that we will be required to perform a mechanical integrity test on the well once every five years.

DCPM performed the Mechanical Integrity Test (MIT) on September 9, 2008 and the results are filed at the facility.

If you have any questions about this information, feel free to contact me at (432) 620-4207 or via email at jdbebbington@dcpmidstream.com.

Respectfully,

DCP Midstream, LP

Jon D. Bebbington
Sr. Environmental Specialist

Cc: Artesia Facility File 3.3.4
Corporate File 3.3.4
Regional Env. File 3.3.4

Jul 1 2009 00:01:03 ARTESIA ACID GAS INJ WELL

PAGE: 1

DAY OF MONTH	PT-6185 WELLHEAD PRESS PSIG	PT-6188 INNER CASING PRESS PSIG	PT-6189 OUTER CASING PRESS PSIG	FQI-6101 ACID GAS FLOW TO COMPRESSOR MSCFD
1	1854	223	96	716
2	1848	232	97	684
3	1845	219	95	772
4	1849	224	97	739
5	1847	232	99	746
6	1840	241	101	718
7	1840	244	102	711
8	1837	244	101	707
9	1836	235	100	752
10	1838	234	100	754
11	1839	242	102	737
12	1843	251	107	787
13	1847	262	111	778
14	1841	262	107	687
15	1841	259	108	790
16	1842	263	110	740
17	1836	259	106	716
18	1830	248	103	723
19	1826	237	99	697
20	1822	234	100	773
21	1828	249	105	753
22	1827	251	106	748
23	1823	252	106	746
24	1823	255	107	763
25	1821	264	109	744
26	1820	269	111	742
27	1823	271	112	733
28	1818	249	103	707
29	1815	248	104	734
30	1810	244	103	740

MONTHLY AVG 1834

247

104

MONTHLY TOTAL22137
