

NEW-TEX LAB

PHONE 505/393-3561

P. O. BOX 1161

611 W. SNYDER

HOBBS, NEW MEXICO 88240

ANALYSIS CERTIFICATE

CLIENT: JARREL WILL 15-1008 104
ADDRESS: P.O. 1884
CITY, STATE: HOBBS NM 88240

ANALYSIS NUMBER:
DATE OF ANALYSIS:
DATE RECEIVED:

5.103
8-10-81
10-10-80

SAMPLE IDENT: EX-104 USA - LUBRIC PLATE FEDERAL #1
SAMPLE PRESS: SAMPLE TEMP:

***** GAS ANALYSIS *****

	MOLE PERCENT	GRAM PERCENT
NITROGEN	3.718	
CARBON DIOXIDE	0.170	
METHANE	92.856	
ETHANE	0.953	1.251
PROPANE	1.157	1.318
ISO-BUTANE	0.143	0.251
NORMAL BUTANE	0.234	0.374
ISO-PENTANE	0.254	0.331
NORMAL PENTANE	0.257	0.321
HEXANES	0.243	0.220
HEPTANES PLUS	2.164	3.075
TOTAL	100.000	1.543

PROPANE GPM: 0.32 BUTANES GPM: 0.13
ETHANE GPM: 1.05 PENTANES PLUS GPM: 0.13

SPECIFIC GRAV (CALC): 0.6108
MOLE WEIGHT: 17.70

HHV-BTU/CD FT	PRESSURE (PSIA)	WET	DRY
14.696	1246	1065	
14.652	1243	1061	
14.730	1248	1067	
14.725	1349	1067	

ANALYZED BY: R. - ANALYST

APPROVED BY: 