formations encountered during drilling operations. The method and interval of sampling and the quantities required will be specified by the State Engineer.

- 4-13. WELL CONSTRUCTION. Every well shall be constructed with an opening of at least three fourths (¾) inch in diameter in the casing above ground level to allow a measuring line to be inserted between the outside casing and the pump column, in order that the water level in the well may be measured. A removable cap shall be provided for such openings.
- 4-13.1. CAPACITY MEASUREMENTS DISCHARGE PIPE TURNOUT APPROVED CAPACITY. In order that capacity measurements may be made, all pumps other than those connected directly into an underground system shall have a discharge pipe unrestricted for at least five (5) diameters in length from the flange of the pump, elbow, or other obstruction. Those connected to an underground system shall have a turnout at the well into which the entire flow can be diverted with an unrestricted pipe as above. This turnout may be equipped with a valve or removable cap. Flowing wells must be equipped with a discharge pipe as described above and a cap or valve approved by the State Engineer.
- 4-14. SHALLOW WELLS-CONSTRUCTION-REPAIR-PLUGGING. The State Engineer has not adopted any general specifications for the construction, repair, or plugging of non-artesian or shallow wells. Any specific requirements and provisions made by the State Engineer shall be set forth in the permit. Application for Permit to Repair is required for all repair work, cleaning, scaling, deepening, modification of casing, or other work requiring the use of a well rig. Any specific requirements or conditions governing the repair will be set out in the approval of the permit. If plugging is required (Article 2-13), shallow wells shall be plugged by filling to the ground surface or, if the casing is not to be removed, by welding a steel plate or cap to the casing.
- 4-15. ARTESIAN WELLS-CONSTRUCTION. The casing for artesian wells shall be inspected by the State Engineer or his representative and shall meet or exceed the specifications as set forth in 4-15.1. All casing and collars must be in good condition. A standard casing shoe shall be used in all instances. The casing shall not be perforated in a manner that would allow the commingling of water from the artesian formation with water in overlying formations.
- 4-15.1. CASING AND COUPLING—API TABLE OF SPECIFICATIONS. Only threaded casing shall be used. Casings and couplings shall meet minimum American Petroleum Institute (API) specifications for the following sizes:

Outside Diameter Inches	Weight With Couplings (lbs/ft)	Wall Thickness Inches	O.D. Inches	Coupling Length Inches	Threads Per Inch	Grade Of Casing
41/2	9.50	0.205	5.000	5	8	F-25
51/2	13.00	0.228	6.050	63/4	8	F-25