

WASTE WATER INJECTION LOG

Dates: From 11/27/95 to _____

		Obtained from Rustrak Recorder			P-670 DISCHARGED TOTALIZER READING	OILERS LEVEL	CRANKCASE LEVEL	CHART CHANGED	TIME	OPERATOR INITIALS
		P-670 FLOW RATE	P-670 PRESSURE	ANNULAR PRESSURE						
Monday	1	84.0	743.3	16.0	202461	/	/		12:30	AL
	2	75.2	725.3	16.6	202756	/	/	Yes	2345	AL
Tuesday	1	99.1	784.7	21.9	203325	/	/		14:55	AL
	2	99.4	788.7	29.3	203735	/	/	Yes	2300	AL
Wednesday	1	95.0	777.5	29.5	204378	/	/		Noon	AL
	2									
Thursday	1									
	2									
Friday	1									
	2									
Saturday	1									
	2									
Sunday	1									
	2									

NOTES: (valve lineup at ponds, unusual conditions, etc.) Maintain @ 75 GPM - 11/27/95

11-28 - TRIED to Close out filter, went from 130 ft
to 90 lbs. (Shut pump down @ 16:00 Switch
problemis) pumped out tank