

WASTE WATER INJECTION LOG

Dates: From 1/1/96 to 1/7/96

Obtained from Rustrak Recorder				Gal x 100	OILERS LEVEL	CRANKCASE LEVEL	CHART CHANGED	TIME	OPERATOR INITIALS
	P-670 FLOW RATE	P-670 PRESSURE	ANNULAR PRESSURE	P-670 DISCHARGED TOTALIZER READING					
Monday	1 110.3	838.6	1.1	229617	✓	✓	YES	9:30	415
	2 142.6	959.6	6.2	230553	-	-	Yes	23:30	34
Tuesday	1 124.5	889.9	0.1	231259	✓	✓		10:40	ML
	2 132.9	923.1	2.5	232088	✓	✓	yes	23:10	Rick
Wednesday	1 142.7	947.0	0.4	233137	✓	✓	NO	14:30	5
	2 140.9	961.4	0.4	233703	✓	✓	yes	23:00	Rick
Thursday	1 129.9	925.5	-0.1	234512	✓	✓		10:45	ML
	2 119	891.9	-0.1	235268	✓	✓	yes	23:00	Rick
Friday	1 118.6	895.0	0.6	236087	-	-	-	12:10	34
	2 118.9	895.0	0.2	236756	-	-	yes	23:00	Rick
Saturday	1 114.8	894.5	0.6	237918	-	-	-	16:30	34
	2 114.9	893.4	-0.1	238291	✓	✓	yes	23:15	ML
Sunday	1 112.1	895.3	-0.1	239235	-	-	-	14:40	34
	2 109.2	889.7	-0.0	239704	✓	✓	yes	23:30	AR

1-5-96 110.5 891.3
69.0 893.3

NOTES: (valve lineup at ponds, unusual conditions, etc.)

Started pump at 9:30 am - Change & Back to 110.3