

WASTE WATER INJECTION LOG

Dates: From 3-6-96 to _____

		Obtained from Rustrak Recorder			P-670 DISCHARGED TOTALIZER READING	OILERS LEVEL	CRANKCASE LEVEL	CHART CHANGED	TIME	OPERATOR INITIALS
		P-670 FLOW RATE	P-670 PRESSURE	ANNULAR PRESSURE						
Monday	1	156.0	950.8	141.9	298084	✓	—	yes	11:00	RLR
	2	151.9	951.0	10.8	299096	✓	✓	yes	23:55	ML
Tuesday	1	146.4	944.0	9.8	300091	✓	—		12:45	AL
	2	149.4	960.3	9.5	300954	—	—	yes	11:50	JA
Wednesday	1	142.0	938.0	11.7	301893	✓	—		12:45	AL
	2	140.6	938.3	10.3	302664	✓	✓	yes	23:25	JA
Thursday	1									
	2									
Friday 3-8	1									
	2									
Saturday 3-9	1									
	2									
Sunday 3-10	1									
	2									

NOTES: (valve lineup at ponds, unusual conditions, etc.) System down for Fiac.

Maintain slightly less than 950#.

Back on at 11 AM

{ 3 way valve started leaking again at 18:30
3/8/96 and is getting worse.