

District I  
1625 N. French Dr., Hobbs, NM 88240  
District II  
811 S. First St., Artesia, NM 88210  
District III  
1000 Rio Brazos Road, Aztec, NM 87410  
District IV  
1220 S. St. Francis Dr., Santa Fe, NM 87505

State of New Mexico  
Energy Minerals and Natural Resources  
Oil Conservation Division  
1220 South St. Francis Dr.  
Santa Fe, NM 87505

**RECEIVED**

By **JKeyes** at 9:15 am, Oct 27, 2015

Form C-141

Submit 1 Copy to appropriate District Office in accordance with 19.15.29 NMAC.

**Release Notification and Corrective Action**

**OPERATOR**

Initial Report  Final Report

Name of Company: Regency Field Services LLC.	Contact: Rose Slade
Address: 800 East Sonterra Road San Antonio, TX 78258	Telephone No. 210-403-6525
Facility Name: Jal #3 Plant	Facility Type: Natural Gas Processing Plant

Surface Owner: Regency Field Services	Mineral Owner:	API No.
---------------------------------------	----------------	---------

**LOCATION OF RELEASE**

Unit Letter	Section	Township	Range	Feet from the	North/South Line	Feet from the	East/West Line	County
E	33	24 South	37 East					Lea County

**Latitude** 32 degrees 10'35.16" North - **Longitude** 103 degrees 10'20.67" West

**NATURE OF RELEASE**

Type of Release: Mixture of Produced water & Crude oil	Volume of Release: 6 barrels	Volume Recovered: 0
Source of Release: Vent Pipe	Date and Hour of Occurrence: 10/20/15 Time Unknown	Date and Hour of Discovery: 10/21/15 @ 8:00 AM
Was Immediate Notice Given? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Not Required	If YES, To Whom? Kellie Jones & Jamie Keyes	
By Whom? Rose Slade	Date and Hour: 8/22/15 2:30 PM	
Was a Watercourse Reached? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	If YES, Volume Impacting the Watercourse.	

If a Watercourse was Impacted, Describe Fully.\*

Describe Cause of Problem and Remedial Action Taken.\*

Severe weather in the area resulted in a power outage in the city of Jal, NM. This caused the plant to shut-down and pressure up with gas and liquids. The plant was overwhelmed, resulting in the release of approximately 6 barrels of crude oil and produced water through a vent pipe. A majority of the release appeared to have been overspray, affecting an area measuring approximately 750 square feet in the northeast portion of the plant. Remedial action taken: Affected soil has been excavated and placed on a plastic liner, pending final disposition.

Describe Area Affected and Cleanup Action Taken.\*

The release affected an area measuring approximately 750 square feet in the northeast portion of the plant. The release will be remediated according to NMOCD regulatory guidelines.

I hereby certify that the information given above is true and complete to the best of my knowledge and understand that pursuant to NMOCD rules and regulations all operators are required to report and/or file certain release notifications and perform corrective actions for releases which may endanger public health or the environment. The acceptance of a C-141 report by the NMOCD marked as "Final Report" does not relieve the operator of liability should their operations have failed to adequately investigate and remediate contamination that pose a threat to ground water, surface water, human health or the environment. In addition, NMOCD acceptance of a C-141 report does not relieve the operator of responsibility for compliance with any other federal, state, or local laws and/or regulations.

Signature: <i>Rose Slade</i>		<b>OIL CONSERVATION DIVISION</b>	
Printed Name: Rose Slade		Approved by Environmental Specialist: <i>Jamie Keyes</i>	
Title: Sr. Environmental Specialist		Approval Date: 10/27/2015	Expiration Date: 12/27/2015
E-mail Address: <a href="mailto:Rose.Slade@energytransfer.com">Rose.Slade@energytransfer.com</a>		Conditions of Approval:	
Date: 10/26/15 Phone: 210-425-6525		Discrete site samples required. Delineate and remediate per NMOCD guidelines.	
		Attached <input type="checkbox"/> 1RP 3940	

\* Attach Additional Sheets If Necessary

Geotagged photos of remediation required.