

District I
1625 N. French Dr., Hobbs, NM 88240
District II
1301 W. Grand Avenue, Artesia, NM 88210
District III
1000 Rio Brazos Road, Aztec, NM 87410
District IV
1220 S. St. Francis Dr., Santa Fe, NM 87505

State of New Mexico
Energy Minerals and Natural Resources
Oil Conservation Division
1220 South St. Francis Dr.
Santa Fe, NM 87505

Form C-141
Revised October 10, 2003

Submit 2 Copies to appropriate
District Office in accordance
with Rule 116 on back
side of form

1AB 1435830421

Release Notification and Corrective Action

NAB1526737877

OPERATOR Initial Report Final Report

Name of Company OXY USA WTP LP	Contact CAMPBELL, RODNEY
Address 329 Marathon Rd, Lakewood	Telephone No. (575) 628-4167
Facility Name INDIAN BASIN GAS PLANT	Facility Type GAS PROCESSING FACILITY

Surface Owner	Mineral Owner INDIAN BASIN	Lease No.
---------------	----------------------------	-----------


LOCATION OF RELEASE

Unit Letter	Section	Township	Range	Feet from the	North/South Line	Feet from the	East/West Line	County
G	23	21-S	23-E					Eddy

32.598111 *104.598444*
Latitude 32°27'52.502" Longitude 104°34'28.004"

NATURE OF RELEASE

Type of Release Gas	Volume of Release 17616.1 MCF	Volume Recovered 0
Source of Release Residue Flare	Date and Hour of Occurrence 3/12/2014 11:35:00 AM	Date and Hour of Discovery 3/12/2014 11:35:00 AM
Was Immediate Notice Given? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Not Required	If YES, To Whom? MIKE BRATCHER	
By Whom? RODNEY CAMPBELL	Date and Hour 03/13/2014 8:52 AM	
Was a Watercourse Reached? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	If YES, Volume Impacting the Watercourse. N/A	



If a Watercourse was Impacted, Describe Fully.*
N/A

Describe Cause of Problem and Remedial Action Taken.*
Cause:
OXY INDIAN BASIN GAS PLANT FLARED RESIDUE SALES GAS FOR 587 MINUTES DUE TO HIGH OXYGEN CONTENT.
Remedial Action Taken:
OPERATIONS TOOK DOWN SIB COMPRESSORS TO ELIMINATE ENTERPRISE GAS, AND O2 LEVEL STARTED TO CLIMB. SIB COMPRESSORS WERE BUT BACK ON. PLANT VRU WAS TAKEN DOWN TO ELIMINATE OUR VRU. PLANT TECH SHUT IN AGAVE GAS. BUT THAT WAS NOT THE SOURCE OF OXYGEN. PLANT TECH DETERMINED THE OXYGEN WAS COMING FROM NEARBURG LINE. LINE WAS SHUT IN AT THE DCP CONNECTION NEARBURG METER.

Describe Area Affected and Cleanup Action Taken.*
N/A

I hereby certify that the information given above is true and complete to the best of my knowledge and understand that pursuant to NMOCD rules and regulations all operators are required to report and/or file certain release notifications and perform corrective actions for releases which may endanger public health or the environment. The acceptance of a C-141 report by the NMOCD marked as "Final Report" does not relieve the operator of liability should their operations have failed to adequately investigate and remediate contamination that pose a threat to ground water, surface water, human health or the environment. In addition, NMOCD acceptance of a C-141 report does not relieve the operator of responsibility for compliance with any other federal, state, or local laws and/or regulations.

Signature: <i>R. Campbell</i>		OIL CONSERVATION DIVISION	
Printed Name: RODNEY CAMPBELL		Approved by District Supervisor Signed By <i>Mike Bratcher</i>	
Title: <i>HES Specialist</i>	Approval Date: <i>3/24/15</i>	Expiration Date: <i>N/A</i>	
E-mail Address: RODNEY_CAMPBELL@OXY.COM		Conditions of Approval: <i>FINAL</i>	Attached <input type="checkbox"/>
Date: <i>3-28-14</i>	Phone: (575) 628-4167		

* Attach Additional Sheets If Necessary

2RD-3297