



STATE OF NEW MEXICO

STATE ENGINEER OFFICE

ROSWELL

S. E. REYNOLDS
STATE ENGINEER

September 17, 1985

DISTRICT II
909 E. 2nd STREET
P.O. BOX 1717
ROSWELL, NEW MEXICO 88201

Hamilton Pumping
PO Box 2461
Roswell, New Mexico 88201

Gentlemen:

Please be advised that the analysis of a water sample collected from your well in the SE $\frac{1}{4}$ NE $\frac{1}{4}$ SW $\frac{1}{4}$ NW $\frac{1}{4}$, Section 29, Township 10 South, Range 28 East, on September 6, 1985 has yielded the following results:

Chloride Content: 76 parts per million

Specific Conductance: 1492 micromhos at 25°C

The total dissolved solids content of the above cited water sample can be approximated by multiplying the specific (electrical) conductance by 0.65.

Yours truly,

A handwritten signature in cursive script that reads "Art Mason".

Art Mason
Field Engineering Unit

AM/tmg
cc Santa Fe

