

District I
1625 N. French Dr., Hobbs, NM 88240
District II
811 S. First St., Artesia, NM 88210
District III
1000 Rio Brazos Road, Aztec, NM 87410
District IV
1220 S. St. Francis Dr., Santa Fe, NM 87505

State of New Mexico
Energy Minerals and Natural Resources
Oil Conservation Division
1220 South St. Francis Dr.
Santa Fe, NM 87505

Form C-141
Revised August 8, 2011

Submit 1 Copy to appropriate District Office in accordance with 19.15.29 NMAC.

Release Notification and Corrective Action

nJMW1229750010

OPERATOR

XX Initial Report ☐ Final Report

Name of Company Parallel Petroleum LLC 230387	Contact John Pennell
Address 1004 N. Big Spring, Ste 400, Midland, TX 79701	Telephone No. 432-254-9770
Facility Name Pandora's Box 1921 1-8 Federal	Facility Type Natural Gas Well

Surface Owner	Mineral Owner	API No. 30-015-35166
---------------	---------------	----------------------

LOCATION OF RELEASE

Unit Letter P	Section 8	Township 19	Range 21E	Feet from the 300	North/South Line SOUTH	Feet from the 700	East/West Line EAST	County EDDY
------------------	--------------	----------------	--------------	----------------------	---------------------------	----------------------	------------------------	----------------

Latitude _____ Longitude _____

NATURE OF RELEASE

Type of Release: Fire *Produced Water*	Volume of Release: 3 bbls water	Volume Recovered: zero
Source of Release: Act of nature/Lightening	Date and Hour of Occurrence 8/7/11 @ UNK	Date and Hour of Discovery 8/4/11 notified about 2pm
Was Immediate Notice Given? Yes XX No Not Required	If YES, To Whom? Notified Legion Brumley / BLM-Carlsbad Field Office on 8/8/11	
By Whom? John Pennell	Date and Hour 8/8/11	
Was a Watercourse Reached? <input type="checkbox"/> Yes XX No	If YES, Volume Impacting the Watercourse.	

If a Watercourse was Impacted, Describe Fully.*
NA

RECEIVED

OCT 22 2012

NMOCD ARTESIA

Describe Cause of Problem and Remedial Action Taken.*

Lightening caused a fire and burned the top of the tank, resulting in a minor spill at the water facility. Called Basic Energy to haul off water from tank & SB to pull chat and haul off tank. All remedial work was complete on 8/8/11.

Describe Area Affected and Cleanup Action Taken.*

Water tank contained 177 bbls per gauges before the fire and 174 bbls after the fire. Lost water from the fire was contained in plastic lined containment and a vac truck was called and sucked up the burn. Basic made two trips, 1st pulled 122 bbls water, 2nd the rest of the water from the tank. The burnt tank was removed and replaced with a frac tank pending arrival of a new tank. The location has been cleaned and disposal of tank and contaminated chat is complete.

I hereby certify that the information given above is true and complete to the best of my knowledge and understand that pursuant to NMOCD rules and regulations all operators are required to report and/or file certain release notifications and perform corrective actions for releases which may endanger public health or the environment. The acceptance of a C-141 report by the NMOCD marked as "Final Report" does not relieve the operator of liability should their operations have failed to adequately investigate and remediate contamination that pose a threat to ground water, surface water, human health or the environment. In addition, NMOCD acceptance of a C-141 report does not relieve the operator of responsibility for compliance with any other federal, state, or local laws and/or regulations.

Signature: Mary Ann Martinez

Printed Name: Mary Ann Martinez

Title: Regulatory Analyst

E-mail Address: mmartinez@plll.com

Date: 9/2/11

Phone: 432/685-6563

OIL CONSERVATION DIVISION

Approved by Environmental Specialist

Signed By Mike Brumley

OCT 23 2012

Approval Date:

Expiration Date:

Conditions of Approval:

Remediation per OCD Rules &
Guidelines. SUBMIT REMEDIATION

Attached ☐ 2RP-1336

PROPOSAL NOT LATER THAN:

1 or C-141 Final by 11/24/12