

and further provided that;

1. A Surety Bond in the amount of \$5,000.00 guaranteeing plugging of said well upon abandonment be filed in the Office of the State Engineer or in the Office of the State Oil Conservation Commission.
2. 150 feet of 10 inch 40-pounds-per-foot pipe be set and cemented with 10 sacks of oil-well cement.
3. The 7 inch O.D. pipe to be used must conform with A.P.I. specifications, shall weigh not less than 24 pounds per foot and shall be inspected and approved by the Artesian Well Supervisor prior to its use in well.
4. The 7 inch pipe shall be cemented into the limestone below the artesian aquifer by means of oil well cement, and sufficient quantity of said cement shall be used in order that a cement plug around the 7 inch pipe shall extend upward through the artesian aquifer to a point above its caprock. Said cement plug shall be placed only after 12-pound mud has been circulated around said pipe from its bottom to the surface.
5. The driller shall take periodic samples while drilling, and furnish them to the Artesian Well Supervisor.
6. The Artesian Well Supervisor shall be notified of commencement of drilling and be present at all occasions when pipe is being set or cemented.

IN WITNESS WHEREOF, I hereby issue this permit to -----T. S. Stanfield-----
this ----27th----day of ----October, 1959-----.

THOMAS M. McCLURE
STATE ENGINEER

By: Willard C. Smith
Assistant State Engineer.