District I 1625 N. French Dr., Hobbs, NM 88240 District II 1301 W. Grand Avenue, Artesia, NM 88210 District III 1000 Rio Brazos Road, Aztec, NM 87410 District IV 1220 S. St. Francis Dr., Santa Fe, NM 87505

## State of New Mexico Energy Minerals and Natural Resources

Oil Conservation Division 1220 South St. Francis Dr. Santa Fe, NM 87505

## **AMENDED**

Form C-144 June 1, 2004

For drilling and production facilities, submit to appropriate NMOCD District Office.
For downstream facilities, submit to Santa Fe office

## Pit or Below-Grade Tank Registration or Closure Is pit or below-grade tank covered by a "general plan"? Yes \( \subseteq \) No \( \subseteq \)

Type of action: Registration of a pit	or below-grade tank \(\overline{\text{Closure of a pit or below}}\)	v-grade tank
Operator: COG Operating LLC To	elephone: <u>432-685-4372</u> e-mail ac	ddress: dkuykendall@conchoresourses.com
Address: 550 W. Texas Ave., Suite 1300 Midland, TX 79701		
Facility or well name: Prohibition "12" Fed #3 API #: 30 - D2	5-3722 6/L or Qtr/Qtr F Sec 12	T_22S_R_32E_
County: Lea Latitude 32'24' 29.88" N Longitude 103'37' 5		
<u>Pit</u> <u>Type:</u> Drilling ⊠ Production □ Disposal □	Below-grade tank  Volume:bbl Type of fluid:	
Workover  Emergency	Construction material:  Double-walled, with leak detection? Yes  If not, explain why not.	
Lined 🛮 Unlined 🗌		
Liner type: Synthetic ☑ Thickness <u>12</u> mil Clay ☐  Pit Volume <u>15M</u> bbl		
Depth to ground water (vertical distance from bottom of pit to seasonal high water elevation of ground water.) 360'	Less than 50 feet	(20 points)
	50 feet or more, but less than 100 feet	(10 points)
	100 feet or more X'	( 0 points) 0
Wellhead protection area: (Less than 200 feet from a private domestic water source, or less than 1000 feet from all other water sources.)	Yes	(20 points)
	No X	( 0 points) 0
Distance to surface water: (horizontal distance to all wetlands, playas, irrigation canals, ditches, and perennial and ephemeral watercourses.)	Less than 200 feet	(20 points)
	200 feet or more, but less than 1000 feet	(10 points)
	1000 feet or more X	( 0 points) 0
	Ranking Score (Total Points)	0 points
If this is a pit closure: (1) attach a diagram of the facility showing the pit		
your are burying in place) onsite 🔲 offsite 🔲 If offsite, name of facility_	. (3) Attach a gene	eral description of remedial action taken including
remediation start date and end date. (4) Groundwater encountered: No $\square$	•	ft. and attach sample results. (5)
Attach soil sample results and a diagram of sample locations and excavation	ns.	
Additional Comments:		
- And the state of		
	,	
I hereby certify that the information above is true and complete to the best been/will be constructed or closed according to NMOCD guidelines   Date: 5/16/05		
Printed Name/Title <u>Diane Kuykendall, Regulatory Analyst</u>	Signature	Jan Denda
Your certification and NMOCD approval of this application/closure does n otherwise endanger public health or the environment. Nor does it relieve the regulations.	ne operator of its responsibility for compliance wi	ents of the pit or tank contaminate ground water or th any other federal, state, or local laws and/or
Approval: Printed Name/Title MAY 1 8 2005 ETROLEUM ENGIN	Z EER <sub>signature</sub>	Date: