

MATERIAL

ITEM	REQ'D	DESCRIPTION
1	1	Pole, _____ Length, Class _____
2	2	Anchor, 8"
3	2	Anchor Rod, 5/8" x 7'
4	2	Guy Attachment, P133A
5	24 #	Guy Cable, 3/8" U.G.
6	2	Guy Insulator, 506
7	2	Epoxy Insulator, Kearney # 323015-24
8	2	Clamp, 3-Bolt
9	6	Guy Grip, 3/8"
10	4	Cross Arm, 8'
11	8	Brace, 38" Spa. WOOD
12	6	Lag Screw, 1/2"
13	2	Steel, Pin 5/8" x 5"
14	2	Rack, 1-Point
15	2	Spool Insulator, 3"
16	6	Bolt, D.A., 5/8" x 18"
17	8	Bolt, Mach., 3/8" x 4 1/2"
18	2	Bolt, Mach., 5/8" x 10"
19	2	Bolt, Mach., 5/8" x 12"
20	6	Eye Nut, 5/8"
21	22	Washer, 2 1/4" Flat
22	2	Washer, 3" Curved
23	8	Lock Nut, 3/8"
24	10	Lock Nut, 5/8"
25	—	Phase Conductor N° _____
26	—	Neutral Conductor N° _____
27	6	Pref. DE, N° _____
28	2	Pref. DE, N° _____
29	6	Clevis, Thimble
30	2	Jumper Sizeve, N° _____
31	2	Connector, S.O., Sml. Al.
32	2	Insulator, 9KV Pin
33	12	Insulator, 6" Disc
34	1/2 #	Tie Wire, N° 6 Al.

REVISIONS		DATE: 4-22-77	TITLE: MATERIAL FOR PRIMARY Angle STRUCTURE 60°-90°	
NO.	DESCRIPTION	DATE BY	DRAWN BY:	CONOCO PRODUCTION DEPT. HOBBS DIVISION JOB: ELK SPECS DRAWING NO.: ES 23A
			DESIGN BY:	
			CHECKED BY: SK	
			APPROVED BY:	
			SCALE:	

RECEIVED

MAY 17 1977

OIL CONSERVATION COMM.
HOBBS, N. M.